

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
NEW SHILLONG DISTRIBUTION SUB DIVISION

No.MePDCL/NSDSD/T- 04/2025-26/

Dated ____ August, 2025 .

To.

The Executive Engineer,
Shillong East Distribution Division
MePDCL,Shillong..

Sub:- **Completion report on charging of 11KV Lines and 11/0.4KV, 25 KVA S/S of Pump House (DTW-XIV),at Itshyrwat New Shillong.**

Sir,

With reference to the above, I am to inform you that the 11 KV Lines and 11/0.4Kv 25KVA, S/S of Pump House (DTW-XIV), at Itshyrwat New Shillong was charged on the 08th January, 2025.The details of Consumer are as under:-

Name	: Pump House (DTW-XIV),
Address	: Itshyrwat
Date of Charging	: 08 th January 2025
Transformer capacity	: 25 KVA
Transformer Maintenance:	
Connected Load	: 22KW
Category	: WSLT
Metering	: Meter No.MEB 99534
Rating	: 3x`240V (415V) 50Hz, 40 Amp Max 200 Amp
Type	: Thread Through
Make	: Secure
Meter Property	: MePDCL
Initial Reading	
Kwh: 0000	

This is for favour of your information.

Yours faithfully

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.

Memo No.MePDCL/NSDSD/T-04/2025-26/235 @

Dated 12 ¹⁵ August 2025.

Copy to:-

1. AEE, RSD-II,MePDCL ,Shillong with a request to commence at the earliest for information and necessary action

✓ 2. The JE, (Revenue), NSDSD, MePDCL,Shillong.

3. The Executive Engineer Electrical Division PHE Shillong. For information

4. R/F

Assistant Executive Engineer
New Shillong Distribution Sub-Division,
MePDCL,New , Shillong.