



ISO: 9001: 2015. & ISO 14001: 2015.

HPL Electric & Power Ltd.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter

METER SL. NO. : 507102

RATING : 5-30A 240V, 50Hz

CLASS : 1.0
METER

CONSTANT : 6400 Impulses per kWh

STANDARD : IS 13779 :1999


The Meter was tested & has passed following routine tests as per IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading

000004


CERTIFIED

Signature: 

Date: 15/01/2022



Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong


Assistant Engineer
Meter Testing Laboratory
MePDCL, Shillong

Pa Natjeng Ch. Sangma

(Traditional Chief) Nokma

Watregre A-king II-20 (05)

P.O. Rangsakona,

Dist. South West Garo Hills,

Meghalaya.



Date: _____

Subject:- Nokma document sue on-ani.

Anga shri Natjeng ch. Sangma anga
an-tangan A-king Nokma onge Watregre
Catholic Gilja Nokma mamingba badigre
current diposita ka-na gita anga
documentko sue onanga.

sa Gilja nokma angni kopako
darangba badi dongja.

Sako sue onangipa

Shri. Natjeng ch. Sangma
Pa N. Ch. Sangma
Nokma II-20 (05)
Watregre A-king
South West Garo Hills

MEGHALAYA POWER DISTRIBUTION CORPORATION LTD.

TEST REPORT

This is to certify that repaired/ renewed/ additional/ new electrical installation at the premises of

(Full Name)

CATOLIK CHURCH

(Address)

MATREURE

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows.

Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3	
		No. of Points	Total Watt	No. of Points	Total Watt	No. of Points	Total Watt
A) Light Points							
i) Fluorescent Tube							
ii) Incandescent Lamp							
iii) CFL	led	15	21	NS	315		
iv) Halogen							
v) Others							
) Fan Points	—	80	10	NS	800		
) Plug Points (3-Pin)							
i) 6 Amps Socket	—	100	5	NS	500		
ii) 16 Amps Socket							
) Electrical Gadgets							
i) Water Heater (Geyser)							
i) Refrigerator							
i) Air Condition							
) Others							
Welding Transformers							
Motors							
al	Total load. 1615 W						
ase of load enhancement Existing							
d							
il load in the premises							

5:

- Details of any apparatus (other than the above mentioned) should be given.
- Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to enclosed)

APPENDIX -1

Form of application for Supply of Electricity at Low Tension/High Tension

to,

The Sub-Divisional Officer,
MePDCL Sub-Division
Tura/ Bajengdoba, Barengapara.

Sir,

I/We request to supply electricity at Low Tension/High Tension at to my/our premises situated at

The requisite information is furnished below

(i) Name of the applicant (consumer)

(ii) Address for communication.

(iii) Status of the consumer (applicant should state the legal status i.e. whether he is an individual owner or lawful occupant of the premises for which the supply is required, partnership firm or limited company or any other local person and in case of partnership firm it should be stated whether it is registered or unregistered, location of its head office, names and addresses of all partners and copy of the partnership deed should be stated whether it is a Private Ltd. or Public Ltd., names of present Directors and copy of the memorandum of articles of association should be furnished. In case of any other type of articles of association should be furnished. In case of any other type of local person, full details and name and address of the person competent to represent the consumer should be stated)

(iv) Location of the premises where supply is required.

(v) Character of Supply: 230/250 Volts.

(vi) Purpose for which supply is required
Domestic/Commercial

(vii) Contracted load

1615.44

(viii) Details of the connected load (The consumer should furnish the requirement for a period not less than 2 years and preferably for a period of 5 years)

2 I/We hereby agree to take supply and to pay all charges such as for energy, service connection and including deposit of such security as may be demanded in accordance with the rates and condition of the MePDCL in force time to time. I/We further declare and agree to take supply of electric Power for the period of not less than 2 years from the date of commencement of supply and in case of disconnection of supply after a period of 6 month from the date of disconnection for not less than one year date of re-connection.

Catholic Church,
Vt: Madnaga
P.O Rangdaboma.
South west Garo hills
Meghalaya,
Pin No. 794105.

Catholic Church,
Madnaga.

3. I/We also undertake to receive supply within 3 months from the date of MePDCL intimates that it give supply to our premises, failing which I/We undertake to pay MePDCL the minimum charges as applicable.

4. This application is for,

(a) A new service connection. ✓

(b) Re-connection.

~~(c) Alteration to my existing installation~~

(d) Temporary service connection

(e) Change of service connection in name of:

Sri _____

(In case of change of name, the particulars regarding the new consumer should be furnished in a separate sheet and attached to the application)


5. I/ We request that the MePDCL should provide necessary meter/meters, metering equipments.

6. The details of wiring carried out by a licensed wiring contractor shall be furnished after completion of wiring. The Test Report shall be submitted as per the "Test Report" attached to the conditions of the Meghalaya Power Distribution Corporation Ltd.

Name of the licensed wiring contractor :

His License No.

His Address


S. Ch. Marak
Electrical Contractor
Jengjai, West Garo Hills.
Regd. No. 1327

7. I/ We shall undertake to execute and agreement in the prescribed form if so called upon by MePDCL. Whether such an agreement was executed or not the application itself shall oblige me / us to confirm the term and condition of supply in force / notified by the MePDCL from time to time.


Signature of a

Name of the applicant (consumer)

APPENDIX - II
AGREEMENT FOR SUPPLY AT LOW TENSION

Agreement executed this.....day of 200.....by.....
for themselves/himself/itself and for their/his/her its assign and successors infavour of the Meghalay
Electricity Board Statutory corporation constituted under Section 5 of the Electricity Supply Act. 19
its successors and assign herein after called the BOARD.

2. Supply of Power :

I/We the above mention have requested the Board to supply electricity at High
sion for the purpose ofDomestic..... and the Maghalaya State Electricity
has agreed to afford such supply on the terms and conditions notified by them from time to time
Section 49 of the Electricity (Supply) Act, 1984 and

Details of Supply :-

(a) Purpose

Domestic

(b) Category

Cabbing

3. Load

1615 W

I/We agree to take from Meghalaya State Electricity Board Electric Power for a load not
ing.....7.6..... HP/KW exclusive use for the purpose as mentioned above at o
factory/premises situated at.....Udaipur.....

The contract demand agreed between the board and myself/ourselves are1.6.....
for first year.

..... KW/HP for.....year

4. Obligation to Comply with Requirement of Acts, Terms and Conditions of Supply
I/We further undertake to comply with all the requirements of the Indian Electricity Act.
Electricity (Supply) Act, 1984, the rules thereunder, the provisions of the schedule of Miscellaneous
the terms and conditions of supply prescribed by the Board from time to time and agree not to di
same.

5. Date of coming into Force of the Agreement :-

I/We undertake to receive the supply within 3 months from the date of the Board intima
ready to give the supply to my/our premises, failing which I/We under take to pay Board miniu
as may be applicable and decided by the Board Further, the provisions of this contract shall b
have come into force from the date of commencement of the supply or the date of expiry of
notice above refered the whichever is earlier.

6. Period of Agreement :-

I/We undertake to avail supply for a minimum period of0.00..... years from
agreement has come into force.

7. Detrmination of the Agreement :-

I/We shall be at liberty to determine the contract by giving one month's notice expres
sions at any time after the expiry of years, I/We agree Meghalaya State E
may terminate the contract at any time giving 7 days notice if I/We violate the terms of this ag
terms and conditions of supply notified by the Meghalaya State Electricity Board from
provision of any law touching this agreement including the Electricity (Supply) Act, 1948
tricity Act, 1910 and the rules thereunder. This agreement shall remain into force until i
indicated above.

8. Obligation of the Consumer to pay All Charges Levied by the Board :

From the date this agreement come into force, I/We shall be bound by and pay
charges, surcharges, meter-rents and other charges if any, in accordance with the charge