

APPLICATION FORM FOR PROVIDING LT SERVICE CO
(FOR ALL CATEGORY AND FOR ALL PURPOSE)



To,

The Area Manager/ Asstt. Executive Engineer.

Service Connection Sub-Division/ Umjarian Distribution Sub-Division

Me. SEB _____

(Indicate the local area of the jurisdiction of the Engineer of the licensee)

Sir,

1. ✓ I/We hereby request you to supply electricity to the premises located at the address more fully described below. I/We are the owner/lawful occupier of the premises.
2. ✓ I/We agree to abide by the terms and conditions relating to the supply of electricity by Me. SEB and to make all payments as may be required and also to pay regularly all charges as may become due.

a). Full name and address of the applicant with contact telephone number.

b). Status in relation to the premises

Owner

☒

Occupier

☐

c). Location and address of the premises including Police Station.

d). Nature of LT supply :

Commercial

☐

Domestics

☒

Industrial

☐

General Purpose

☐

WSLT

☐

PL

☐

Agriculture

☐

KJ

☐


Date:

Applicant's Signature

NB : The following documents are to be enclosed :

- 1). Test Report from Licensed contractor.
- 2). Agreement Form duly filled in.
- 3). Proof of ownership (in case applicant is owner).
- 4). Number of nearest Electric Pole.
- 5). NOC of the owner of the premises (incase the application is an occupier).
- 6). Attested copy of permission obtained from Pollution Control Board.
- 7). Building permission from the concerned authority.

**AGREEMENT FOR SUPPLY OF ELECTRICITY
LOW TENSION.**



AN AGREEMENT made this the _____ day of _____ 20____
between _____ and his successors and assigns
(hereinafter referred to as the Consumer) of the One Part and the Meghalaya State Electricity Board
and electricity distribution licensee under the Electricity Act, 2003 and its successors and assigns
(hereinafter referred to as the Board) of the Other Part.

Note: The term 'consumer' includes and individual person (whether male or female), a body of persons, a company, society, firm, association or organization.

WHEREAS, the consumer has applied to the Board for supply of electricity to its premises and the Board has agreed to give the supply under the terms and conditions hereinafter appearing.

NOW, THEREFORE, the agreement witnesses-

- 1) That the supply shall be given to the premises located at Maulai Mausangrim with the consumer as owner/occupier of;
- 2) That the supply shall be for the purpose of domestic, the load whereof shall not exceed 2000 Watts watt(s);
- 3) That the provisions of the Electricity Act, 2003 and the Regulations, Code and Orders, including Tariff Orders, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply and bind the consumer and the Board alike;
- 4) That the consumer shall regularly and timely pay to the Board all charges and may be due for the supply of electricity;
- 5) That the Agreement shall be for a period of two years and may be renewed for a further period: Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;
- 6) That the Agreement shall be terminated if the consumer on its part desires it so and give to the Board a prior notice of not less than one month or, on the part of the Board, if the consumer has violated any of the terms and conditions of the agreement:

Provided that on the part of the Board notice shall be given to the consumer stating in reasons for the proposed termination and giving him opportunity to state his case and his statement, I any, duly considered before the agreement is terminated and the supply of electricity cut off;

- 7). That the terms and conditions of this Agreement shall be effective from the date supply of electricity I commenced.

IN WITNESS WHEREOF the parties hereto have set their hands and seals the date, month and year first above written.

R. Dymkhor

The Consumer

()
For and on behalf of the Board.

Witnesses :-

1. Signature :

B

Name :

B. Khongvir

Address :

Mawlae Mawlong Rim

1. Signature :

A. J. Dkhon

Name :

A. J. Dkhon

Address :

Mawlae Mawlong Rim

P. No 81318 41172

MALAYALA ENERGY CORPORATION LTD

TEST REPORT.

This is to certify that repaired/renewed/additional/new electric installation at the premises of

R I S I N A L Y N G K H O I

(Please leave one block between name & surname)

(Full name)

M A W L A I M A W I O N G R I M B L O C K - 3

(Address)

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Voltage of each item	Phasi - 1		Phasi - 2		Phasi - 3		Total Watt of all 3 phases
1. Light Points								
(i) Fluorescent								
(ii) Incandescent								
(iii) CFL								
(iv) Halogen								
(v) Others LED bulbs	15W x 16nos		240W	—		—		240W
2. Fan Points	60W x 3nos		180W	—		—		180W
3. Plug Points (3-pin)								
✓ (i) 6Amps	100 x 5nos		500W	—		—		500W
(ii) 16Amps								
4. Electrical gadgets								
(i) Water Heater (geyser)								
(ii) Refrigerator								
(iii) Air Conditioner								
✓ (iv) Other Room Heater	1000 x 1nos		1000W	—		—		1000W
Blender	80 x 1no		80W					80W
5. Welding Transformer								
6. Motor								
Total			2000W					2000W
In case of load enhancement								
Existing load (in watts)								
Total load in the premises (in watts)								

Notes :-

- (a) Details of any apparatus (other than the above mentioned) should be given.
 (b) Rating of capacitor used in Induction Motor and Welding Transformer (Test report of capacitor is to be enclosed)



KVAR

I. Type of wiring

OK

Casing Casing Type

III. Voltage and system of supply

(~~500V Megger~~) 240V and Single Phase Supply

IV. Test Result: OK

Date of Testing by Licensed Contractor:

06 06 25

Type of Test	Result of test carried out by licensed contractor In (M Ω)/ Ω	Result of test carried out by the supplier under relevant IE Rules, In (M Ω)/ Ω
a. Insulation resistance between earth and whole system of conductor	30M Ω	
b. Insulation resistance between all conductors	30M Ω	
c. Earth continuity between earth electrode and earth continuity conductor.	0.7 Ω	
d. Polarity on non-linked SP switches.	OK	

V. Full Name with signature of Licensed Contractor

LIC No.

S. Langstieh
Electrical Contractor
Regd. No: 652

VI. Full Name with signature of supervisor
(with date)

D. RYMBAI
Electrical Supervisor
Govt. Regd. No.- 1593.

VII. Full Name with signature of wireman
(with date).

W. Ryntathiang
Electrical Wireman
Regd. No. 4770

PERMIT NO.

VIII. Signature of the authorized official who tested
The installation of behalf of supplier.

IX. Date of connection of supply to the installation