

APPENDIX - I

Form of application for supply of electricity at Low Tension / High tension

To,

The S.D.O. HEPDCL (Elect)

P.O. Gurobachi

Dist. South West Garo Hills

Sir,

I/We request you to supply electricity at Low Tension/High Tension to my/our premises situated at Bansali

The requisite information is furnished below :-

- Name of the applicant (consumer)
- Address for communication.
- Status of the consumer (applicant should state the legal status i.e. whether he is an individual owner or lawful occupant of the premises for which the supply is required, partnership firm or limited company or any other local person and in case of partnership firm it should be stated whether it is registered, or unregistered, location of its head office, names and address of all partners and a copy of the partnership deed should be filled. In case of company it should be stated whether it is a Private Ltd. or Public Ltd. names of present Directors and a copy of the memorandum of articles of association should be furnished. In case of any other type of articles of association should be furnished. In case of any other type of local person, full details and name and address of the person, competent to represent the consumer should be stated.
- Location of the premises where supply is required
- Character of Supply
- Purpose for which supply is required
- Contracted load
- Details of the concerned load (The consumer should furnish the requirement for a period not less than 2 years and preferably for a period of 5 years)

Jebathi ch. Morak
Vill:- Bansali
P.O. Gurobachi
Dist. South West Garo Hills
Heghalye

Bansali

230001 A/c 8/8/80

Commercial

2.5 KVA

L.P.	15X60W.	900 W
P.P.	8X100W.	800 W
F.P.	8X100W.	800 W
		<u>Total = 2500 W</u>

- I/We hereby agree to take supply and to pay all charges such as for energy, service connection and other dues including deposit of such security as may be demanded in accordance with the rates and conditions of supply of the Board in force from time to time. I/We further declare and agree to take supply of electric power for the above-mentioned purpose for a period of not less than 2 years from the date of commencement of supply and, in case of reconnection of supply after a period of 6 months from the date of disconnection for not less than one year from the date of re-connection.
- I/We also undertake to receive supply within 3 months from the date of Board intimates that it is ready to give supply to our premises failing which I/We undertake to pay the Board the minimum charges as may be applicable.
- This application is for
 - A new service connection
 - Re-connection
 - Alteration to may existing installation
 - Temporary Service Connection
 - Charge of Service Connection in the name of



MPS, Gate No. 1, Plot No 324-330, KIADB Industrial Area, Hebbal-Hootagali, Mysuru - 570 018.

TEST CERTIFICATE

ITEM : Single Phase Static Watthour Meter
METER SL NO. : U5218567
RATING : 5-30A, 240V, 50Hz
METER CLASS : 1.0
CONSTANT : 3200 Impulses per kWh
STANDARD : IS 13779

The Meter was tested & has passed following routine tests as per
IS: 13779 at reference conditions:

	TEST	RESULT
01	No Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading

00001

CERTIFIED

Signature

Date

30/03/2025

Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong

Executive Engineer
MTI Division
MePDCL, Shillong

