

**TEST CERTIFICATE**

ITEM : Single Phase Static Watthour Meter

METER SL NO. : U5219446

RATING : 5-30A, 240V, 50Hz

METER CLASS : 1.0

CONSTANT : 3200 Impulses per kWh

STANDARD : IS 13779

The Meter was tested & has passed following routine tests as per IS: 13779 at reference conditions:

	TEST	RESULT
01	No-Load Conditions	Passed
02	AC Voltage Test	Passed
03	Insulation Resistance Test	Passed
04	Starting Test	Passed
05	Meter Accuracy Test	Passed Meter Accuracy Observed within $\pm 1\%$

Initial Reading

00001

CERTIFIED

Signature:

Date: 30/03/2025

Meter Tester Gr - I  
MTI Laboratory  
MePDCL, Lumjingshal  
Shillong

Executive Engineer  
MTI Division  
MePDCL, Shillong

# APPENDIX - I

## FORM OF APPLICATION FOR SUPPLY ELECTRICITY AT LOW TENSION / HIGH TENSION

To,

The

S.D.O.

Me. E.C.L. Distribution Sub-Division

M/e. P. D. C. L. Garobadha Southwest Garo Hills.

Sir,

I/We request you to supply electricity at Low Tension/High Tension to my I/our premises situated at the Requisite inform action is furnished below :-

- (i) Name of the applicant (Consumer) Smt Anupama Koch.
- (ii) Address for communication Gandhipora P.O. Garobadha  
Southwest Garo Hills Nigh
- (iii) Status of the consumer (applicant should state the legal status i.e. whether he is an individual owner or lawful occupant of the Premises for which the supply is required partnership firm or limited company or any other local person and in case of partnership unregistered location of its head office, names and address of all partners and copy of the Partnership deed should be filled in case of a company it should be stated whether it is a Private Ltd. names of Present Directors and a copy of the memorandum and/or articles of association should be furnished. In case of any other type of articles of association should be furnished. In case of any other type of local person full details and name and address of the person competent to represent the consumer should be stated)
- (iv) Location of the premises where supply is required Same as above
- (v) Character of supply 230/250 V
- (vi) Purpose of which supply is required Domestic use
- (vi) Contracted load 700 Wt.
- (viii) Details of the connected load (The Consumer should furnish the requirement for a period not less than 2 years and preferably for a period of 5 years)
- |                                       |                  |
|---------------------------------------|------------------|
| $11 - 100 \times 3 = 300 \text{ Wt.}$ | } <u>700 Wt.</u> |
| $F - 80 \times 3 = 240 \text{ Wt.}$   |                  |
| $CFL - 20 \times 8 = 160 \text{ Wt.}$ |                  |
2. I/We hereby agree to take supply and to pay all charges such as energy service connection and other dues including deposit of security as may be demanded in accordance with the rates and conditions of supply of the Board in force time to time.

I/We further declare and I agree to take supply of electric power for the above mentioned purposes for a period of not less than 2 years from the date of commencement of supply and in case of reconnection of supply after a Period of 9 months from the date of disconnection for not less than one year from the date of reconnection.

# Meghalaya State Electricity Board

## TEST REPORT

This is to certify that repaired / renewed / additional / new electric Installation at the premises of

SMT ANUPOMA KOCH

(Full Name)

GANDHI PARA PO GAROBADHA

(Address)

SOUTH WEST GARO HILLS

is duly completed, tested and is ready for your Engineer to test and connect on your main line.

1. The load has been arranged as follows :-

Details of Load	Wattage of each item	Phase - 1		Phase - 2		Phase - 3		Total Watt of all 3 phases
		No. of Points	Total Watt	No. of Points	Total Watt	No. of Points	Total Watt	
1. Light Points	60 W							
<input checked="" type="checkbox"/> [i] 6 Amps	100 W	3	300					
[ii] Fluorescent	40 W							
[iii] Incandescent								
<input checked="" type="checkbox"/> [iv] CFL	20 W	8	160					
[v] Halogen	500 W							
[vi] Others								
<input checked="" type="checkbox"/> 2 Fan Points	80 W	3	240					
3. Plug Points (3-Pin)								
[i] 16 Amps	1000 W							
4. Electrical Gadgets								
[i] Water Heater (Geyser)								
[ii] Refrigerator								
[iii] Air Conditioner								
[iv] Others								
5. Welding Transformer								
6. Motor								
Total			700					
In case of load enhancement								
Existing load			/					
Total load in the premises			700					

Notes :-

- [a] Details of any apparatus (other than the above mentioned) should be given.
- [b] Rating of capacitor used in Induction Motor and Welding Transformer  
(Test report of capacitor is to be enclosed)



# NOTICE OF COMMANCEMENT OF WORKS

Smt. Trymelline Sangma  
P.O. & P.S. Baghmara.  
South Garo Hills

Date: 7/7/25

To, *The Senior Electrical Inspector,  
Meghalaya, Shillong*

Subject: *Notice before the commencement of Works under clause 36 of Electrical Licensing Board Regulations and conditions prescribed under Rule 29(1) of the Central Electricity Authority of Safety Regulation, 2010*

Sir,

I have the honour to inform you that the Additional / Alteration / Repair / New Electrical installation will be executed by me/us in the under mentioned premises and the particulars are as stated below

1. Owner of premises *Smt. Anupama Koch*  
with address *Gandhinagar P.O. Garobadha S/W Garo Hills.*

2. Details of Load.

A. Light points.	No. of Points	Watts	Total Watts
i) Fluorescent tube			
ii) Incandescent lamp			
<input checked="" type="checkbox"/> iii) CFL	8	20	160
iv) Halogen			
v) Others			240
<input checked="" type="checkbox"/> B. Fan point	3	80	
C. Plug points			
<input checked="" type="checkbox"/> i) 5/6 Amp. Socket	3	100	300
ii) 15/16 Amp. socket			
D. Electrical gadgets			
i) Water heater			
ii) Refrigerator			
iii) Air condition			
iv) Others			
3. Type of Wiring	<u><i>Single Phase Looping in System.</i></u>		
4. Date of Commencement	<u><i>4/7/25</i></u>		
5. Name of Supervisor	<u><i>Sri Helwistone A. Narak d/no. 998</i></u>		
6. Name of Workman	<u><i>Sri Helwistone A. Narak, d.no. 2110</i></u>		
7. Insulation Tester Sl. No.	<u><i>398411/500 Volt.</i></u>	Make	<u><i>wako.</i></u>
8. Earth Tester Sl. No.	<u><i>231236/100 MΩ</i></u>	Make	<u><i>wako.</i></u>

Yours faithfully,

Electrical contractor *T. Sangma*  
Lic. Trymelline Sangma  
Govt. Regd. Electrical Contractor  
South Garo Hills, Baghmara

भारत निर्वाचन आयोग  
ELECTION COMMISSION OF INDIA  
मतदाता फोटो पहचान पत्र - ELECTOR PHOTO IDENTITY CARD

TRD0057224

ANUPOMA KOCH

HUSBAND'S NAME NIPEN KOCH

SEX : FEMALE  
DATE OF BIRTH/AGE : 25/03/1995

ADDRESS : 4, GANDHIPARA, GANDHIPARA,  
WEST GARO HILLS, 794105

Date : 07/01/2014 Electoral Registration Officer.

AC No & Name : 52-RANGSAKONA  
Part No & Name: 20-GANDHIPARA

नोट / Note :

1. इस कार्ड को धारण करने मात्र से यह कोई गारंटी नहीं है कि आप वर्तमान निर्वाचक नामावली में निर्वाचक हैं। कृपया अपना नाम प्रत्येक चुनाव से पहले वर्तमान नामावली में जांच लें।  
Mere possession of this card is no guarantee that you are elector in the current electoral roll. Please check your name in the current electoral roll before every election.

2. इस कार्ड में उल्लिखित जन्मतिथि को निर्वाचक नामावली में पंजीकरण के अलावा अन्य किसी भी स्थिति में आयु के प्रमाण के रूप में नहीं माला जाएगा।  
Date of Birth mentioned in this Card shall not be treated as proof of age / D.O.B. for any purpose other than registration in electoral roll.

8837094920

Anupoma Koch

OFFICE OF THE  
**GAON BURA TANGABARI ELAKA**  
P.O.-GARODOBA-794105  
DIST.-SOUTH-WEST GARO HILLS (MEGHALAYA)

Regd. No. GDC-REV/258/93/417-422 Dt. 19th Aug., 2003

From: J. Hajong  
Gaon Bura  
Tangabari Elaka (Circle)

Date 08.07.25



TO WHOM IT MAY CONCERN

This is to certify that Sri. / Smt. Amupoma Koeh

S/o, D/o, H/o, W/o. Sri. / Smt. / Lt. Nipem Koeh

of Village H. Samdhipara P.O. Garobadha / Garodoba / Teporpara, P.S. Ampati, in

the district of South-West Garo Hills, Meghalaya is well known to me since his / her childhood / longtime.

He / She is the permanent resident of Village H. Samdhipara

in the district of South-West Garo Hills, Meghalaya.

a) EPIC No. Self / Father / Mother / Brother / Sister / Other Relatives Enrolled

..... Date .....

b) Admit Card / T.C. No. .... Date .....

I wish him / her every success in life.

c) For New Electricity line connection: (Resident)

J. Hajong

(Shri. Jawaharlal Hajong)

Ex.-Hav. (GAR)

Gaon Bura

Tangabari Elaka (Circle)

South West Garo Hills (Me)

Dated 08 July 25