

APPLICATION FORM FOR PROVIDING LT SERVICE CONNECTION
(FOR ALL CATEGORY AND FOR ALL PURPOSE)



The Area Manager/ Asst. Executive Engineer

Service Connection Sub-Division/

Distribution Sub-Division

Me.S.E.B/Me POU Garobadha.

Sir,

1. I / We hereby request you to supply electricity to the premises located at the address more fully described below. I / we are the owner / lawful occupier of the premises.

2. I / We agree to abide by the terms and conditions relating to the supply of electricity by Me.S.E.B and to make all payments as may be required and also to pay regularly all charges as may become due.

3. a) Full name and address of the applicant with contact telephone number.

Shri. Radha Dalu, Dalupara P.O. Garobadha / Mukdangra
South West Garo Hills.

b) Status in relation to the premises.

Owner

Occupier

c) Location and address of the premises including Police Station.

Dalupara, P.O. Mukdangra P.S. Garobadha
South West Garo Hills Meghalaya.

d) Nature of LT supply :

Commercial	<input type="checkbox"/>	Domestic	<input checked="" type="checkbox"/>
Industrial	<input type="checkbox"/>	General Purpose	<input type="checkbox"/>
WSLT	<input type="checkbox"/>	PL	<input type="checkbox"/>
Agriculture	<input type="checkbox"/>	KJ	<input type="checkbox"/>

Date :


Applicant's Signature

NB: The following documents are to be enclosed:

- 1) Test Report from Licensed contractor.
- 2) Agreement Form duly filled in.
- 3) Proof of ownership (in case applicant is owner)
- 4) Number of the nearest Electric Pole.
- 5) NOC of the owner of the premises (in case the application is an occupier)
- 6) Attested copy of permission obtained from Pollution Control Board.
- 7) Building permission from the concerned authority.

AGREEMENT FOR SUPPLY OF ELECTRICITY
LOW TENSION

AN AGREEMENT made this the day of.....
26..... BETWEEN and his

Successors and assigns (hereinafter referred to as the Consumer) of the one Part and The Meghalaya State Electricity Board an electricity distribution licensee under the Electricity Act, 2003 and its successors and assigns (hereinafter referred to as the Board) of the Other Part.

Note: The term 'consumer' includes an individual person (weather male or female), a body of person, a company, society, firm, association or organization.

WHEREAS, the consumer has applied to the Board for supply of electricity to its premises and the Board has agreed to give the under the terms and conditions hereinafter appearing.

NOW, THEREFORE, the agreement witnesses –

- (1) That the supply shall be given to the premises located at
Salupore P.O. Mukhdangra S/W/G Hills Meghalaya,
With the consumer as owner / occupier of ... Owner Sant Radho Dalu
- (2) That the supply shall be for the purpose of ... Domestic use
the load whereof shall not exceed 1.0 Kw.
watt(s).
- (3) That the provisions of the Electricity Act, 2003 and the Regulations, Code and Order, including Tariff Order, as may be made from time to time by the Meghalaya State Electricity Regulatory Commission shall apply and bind the consumer and the Board alike.
- (4) That the consumer shall regularly and timely pay to the Board all charges as may be due for the supply of electricity.
- (5) That the Agreement shall be for a period of two years and may be renewed for a further period:

Provided that supply shall not be terminated by mere efflux of time if the consumer is willing that the agreement is renewed;

NOTICE OF COMMANCEMENT OF WORKS

Smt. Trymelline Sangma
P.O. & P.S. Baghmara.
South Garo Hills

Date: 17/12/23

To, The Senior Electrical Inspector,
Meghalaya, Shillong

Subject: Notice before the commencement of Works under clause 36 of Electrical Licensing Board Regulations and conditions prescribed under Rule 29(1) of the Central Electricity Authority of Safety Regulation, 2010

Sir,

I have the honour to inform you that the Additional / Alteration / Repair / New Electrical installation will be executed by me/us in the under mentioned premises and the particulars are as stated below

1. Owner of premises Smt. Radha Daku
with address Dalupara P.O. Mardangra S/W/B Hills.

2. Details of Load.

A. Light points.

- i) Fluorescent tube
- ii) Incandescent lamp
- iii) CFL
- iv) Halogen
- v) Others

No. of Points

Watts

Total Watts

8

20

160W

2

80

160W

C. Plug points

- i) 5/6 Amp. Socket
- ii) 15/16 Amp. socket

2

100

200W

D. Electrical gadgets

- i) Water heater
- ii) Refrigerator
- iii) Air condition
- iv) Others

Total: 520W

3. Type of Wiring Single Phase wiring in System

4. Date of Commencement 15/12/23

5. Name of Supervisor Helmstone A. Manak, L.M. 398

6. Name of Workman Helmstone A. Manak, L.M. 2110

7. Insulation Tester Sl. No. 238414 / 500 Volt Make Wako

8. Earth Tester Sl. No. 231236 / 100 M-Ω Make Wako.

Yours faithfully,

T. Sangma
Electrical contractor
Mrs. Trymelline Sangma
Govt. Regd. Electrical Contractor
South Garo Hills, Baghmara

भारत निर्वाचन आयोग
ELECTION COMMISSION OF INDIA
मतदाता फोटो पहचान पत्र - ELECTOR PHOTO IDENTITY CARD

TRD0058958



NAME : **RADHA DALU**

HUSBAND'S NAME : **KHUDU DALU**

SEX : **FEMALE**
DATE OF BIRTH/AGE : **02/05/1994**
ADDRESS : **43 , DALUPARA, DALUPARA,
WEST GARO HILLS, 794105**

[Signature]
Date : **22/03/2014** Electoral Registration Officer.
AC No & Name : **52-RANGSAXONA**
Part No & Name : **27-HARIGAON**

नोट / Note
1. इस कार्ड को धारण करने मात्र से यह कोई गारंटी नहीं है कि आप वर्तमान निर्वाचक मतदाता की सूची में निर्वाचक हैं। कृपया प्रत्येक मतदान के पक्षों पर मतदान करने से पहले वर्तमान मतदाता की सूची में जांचें।
2. Mere possession of this card is no guarantee that you are elector in the current electoral roll. Please check your name in the current electoral roll before every election.
3. इस कार्ड में उल्लिखित जानकारी को निर्वाचक मतदाता की सूची में पंजीकरण के प्रमाण के रूप में नहीं माना जाएगा।
Date of Birth mentioned in this Card shall not be treated as proof of age / D.O.B. for any purpose other than registration in electoral roll.

9366601001

Serial Number: SS17919262

Customer: M/S MAMTA ELECTRICALS

Customer P.O Number: MAMTA/23-24/017

Customer P.O Date: 16-DEC-2024

Voltage: 240V

Current: 05-30A

Accuracy Class: 1.0

Ref. Standard: IS : 13779

Meter Constant: 6400

1. AC VOLTAGE TEST: **PASS**
2. TEST OF NO LOAD CONDITION: **PASS**
3. TEST OF STARTING CURRENT: **PASS**
4. INSULATION TEST: **PASS**
5. METER ACCURACY:-

Reference Conditions: Vref = 240V/50Hz Ib = 05-30A Amb. Temp = 27 +/- 2 Deg. C

METER ACCURACY


% Active Import Errors

Load % Ib	0.5 Lag	0.8 Lead	UPF
600	0.3	0.0	0.0
100	0.1	0.0	0.0
10	0.1	0.0	0.0
5			0.0

0000-1.0

TEST DATE: 19/02/2025

This is computer generated test report no signature required


Meter Tester Gr - I
MTI Laboratory
MePDCL, Lumjingshal
Shillong


Executive Engineer
MTI Division
MePDCL, Shillong