



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಸಂಪೂರ್ಣಕರ್ತೃತ್ವದ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಸಂಖ್ಯೆ: ಅಇಂ(ವಿ)/ರಾವ್ಯ/ಕಾಇಂ(ಕ)/ಸಕಾಇಂ/2025-26/

ಲಗತ್ತ:

3513-15

Email: sermgc.work@gmail.com

Phone No. 080-28488780 / 723

BESCOM GST NO: 29AACCB1412G1Z5

ರವರಕಥೇರಿ,

ಅಧೀಕ್ಷಕಇಂಜಿನಿಯರ್(ವಿ),

ಪಾಣಿಪತ್ರಿಕೆ, ಕಾರ್ಯಾಚರಣೆ ಪಾಲಿಸಾ ರಾಮನಗರ ವೃತ್ತ,

ಬೆಂಗಳೂರು, ಟಿಪ್ಪಣಿ ಸೆಟ್ಟರ್, ಕೆಂಗೇರಿ,

ಬೆಂಗಳೂರು-560060.

To

Sri. Srinivasa Reddy S/o

GR Ramaiah Reddy,

Plot. No. 23 & 24 of BIA,

Anekal Taluk,.

23 JUL 2025

ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ

ಮಾನ್ಯರೇ,

ವಿಷಯ: ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ 62 ಹೆಚ್.ಪಿ (ಕೈಗಾರಿಕ) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಬಗ್ಗೆ. (ಒಟ್ಟು ಹಾಲಿ 24 ಕಿ.ವ್ಯಾ + ಅಧಿಕ 62 ಹೆಚ್.ಪಿ.). (Total Load=24KW On Existing RR No CDPBCMS5556 + 62 HP for New connection).

ಉಲ್ಲೇಖ: ಕಾನಿಇಂ(ವಿ)/ಚಂದಾಪುರ /ಸಕಾನಿಇಂ(ಕ)/ಸಇಂ(ತಾಂ)/2025-26/3527-28 ದಿ: 11.07.2025 ಚಂದಾಪುರ ವಿಭಾಗ.

Application ID: 1322103250254

ನಿಮ್ಮ ಮನವಿಯಲ್ಲಿ ನೀವು ಕೋರಿರುವಂತೆ ಅಧಿಕ 62 ಹೆಚ್.ಪಿ (ಕೈಗಾರಿಕ), ವಿದ್ಯುತ್ ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿಯಮ 3.1.5ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಷರತ್ತುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿವಸಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ. (ಹಾಲಿ 24 ಕಿ.ವ್ಯಾ+ ಅಧಿಕ 62 ಹೆಚ್.ಪಿ : ಒಟ್ಟು ಹಾಲಿ 24 ಕಿ.ವ್ಯಾ + ಅಧಿಕ 62 ಹೆಚ್.ಪಿ.).

1. ತಾವು ಹಾಲಿ ಕಟ್ಟಿರುವ ಕಟ್ಟಡದ ವಿಷ್ಣು 2016.5 ಚ.ಮೀ, **Ground Floor** ಇರುತ್ತದೆ. ಹೊಸದಾಗಿ ನೀವು ಕೋರಿರುವ ಅಧಿಕ ವಿದ್ಯುತ್ ಪ್ರಮಾಣ 62 ಹೆಚ್.ಪಿ (ಕೈಗಾರಿಕ)
2. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಹಾಲಿ ಇರುವ **F-05 Feeder, 220/66/11 KV Yarandanahalli MUSS** ಉಪಸ್ಥಾವರದಿಂದ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
3. ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಟಿ.-5 ಜಕಾತಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲ್ಪಡುತ್ತದೆ.
4. ಈ ಕೆಳಕಂಡ ಠೇವಣಿ/ಶುಲ್ಕಗಳನ್ನು ಸ.ಕಾ.ನಿ.ಇಂ(ವಿ),ಚಂದಾಪುರ ಉಪ-ವಿಭಾಗದಲ್ಲಿ **DD** ಮೂಲಕ ಪಾವತಿಸುವುದು.

SI No	Particulars	Amount (in Rs.)	Amount in Rs.
	2MMD		
1	62HP * 01 Nos: Tariff LT-5 (38684*01=38684/-)	38684/-	38684/-
Total Amount (Thirty Eight Thousand and Six Hundred and eighty four Only)			38684/-

5. As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC- 11 / 2024 -25 /Cys-141, dt: 05.12. 2024.Dry **type transformers required to create infrastructure shall be purchased from BESCOM approved Vendors only.**
6. If **Dry type LBS/500KVA/CSS/transformer** has been installed under self-execution, an under taking shall be furnished that the same shall be **maintained for life time by the applicant.**
7. As per **BESCOM** order No: **BESCOM/CGM(OP)/DGM (OP--1)/FY 2021-2022/CYS-19 Dt:17.05.2021.** The sub divisional officers ensure the **transformer quality** and rating at the authorized test bench/ Divisional stores **duly collecting transformer test certificate** issued by the concerned MT division before servicing of installation.
8. As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC- 11 / 2024 -25 /Cys-15, dt:19.04.2024. **All dry type transformers procured under Self-execution shall be got tested at the nearest test bench center** and duly collecting transformer test certificate issued by the concerned MT division.
9. As per **BESCOM** Circular vide ref:-BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates:-15.02.2025 & CYS-102 dated 25-03-2025, **The power supply shall be arranged to the above said installations through "Smart Energy Meter in line with its capacity and quantum of load requirement in BESCOM jurisdiction".**