



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No. SEE/BRC/EE(O)/F-1(B)/2025-26/ 6564-66

Office of the
Superintending Engineer (Ele),
(C, O&M), B'lore Rural Circle,
BESCOM, KSSCL, 5th Floor,
"Beeja Bhavan", Bellary Road,
Hebbal, Bangalore -560024.

Date: 24 NOV 2025

Encl:

Ph No. 080-28482437 / 94482 79007

Email ID: sebrce@bescom.co.in

To,

**M/s. Indian Oil Corporation Limited represented by it's
Retail Manager Saurabh, [HVM Petrol Bunk], Sy No. 16/6,
Melena Nayakarahandahalli Village, Tubagere Hobli,
Doddaballapura Taluk-561205.**

Sir,

Sub: Arranging power supply to an extent of **60 KW EV Charging Station under LT-6(c)** which already have a SL of 25KW under LT3(a) bearing RR No: TBP-9703 in favour of **M/s. Indian Oil Corporation Limited represented by it's Retail Manager Saurabh, [HVM Petrol Bunk], Sy No. 16/6, Melena Nayakarahandahalli Village, TubagereHobli, Doddaballapura Taluk in Tubagere Sectoin of Doddaballapura Rural Sub-division of Nelamangala Division, "Under DCW Basis". (Application ID: 111111250001)**

- Ref:**
- As per 7th Amendment & 11th Amendment of ROE.
 - Corporate office circular No. BESCOM/CGM(O)/DGM(OP-3)/AGM-1/21-22/Cys-134 Dated: 09.11.2021.
 - KERC/COS/DDD/1/2018-19/908, Bengaluru Dated: 22.10.2019.
 - Meeting Proceeding Ltr No. BESCOM/CGM(OP)/DGM(EV)/BC-3/2023-24/716 Dated: 12.12.2023.
 - BESCOM/BC-53/CGM(OP)/DGM(EV)/2023-24/362 Dated: 18.08.2023.
 - BESCOM/CGM(OP)/DGM(OP3)/AGM(OP)/2024-25/CYS-70 Dated: 07.10.2024.
 - EEE/NEL/AEE(O)/AET/2025-26/10182-83 Dated: 20.11.2025
 - T.O Note Approved Dated: 24.11.2025.

With reference to the above BESCOM is pleased to sanction power to execute the work of arranging power supply to an extent of 60 KW EV Charging Station under LT-6(c) which already have a SL of 25KW under LT3(a) bearing RR No: TBP-9703 in favour of M/s. Indian Oil Corporation Limited represented by it's Retail Manager Saurabh, [HVM Petrol Bunk], Sy No. 16/6, Melena Nayakarahandahalli Village, Tubagere Hobli, Doddaballapura Taluk in Tubagere Sectoin of Doddaballapura Rural Sub-division of Nelamangala Division, "Under DCW Basis". subject to the following conditions:

- The 11 kV line of DF-16 Kantanakunte NJY feeder feeding from 66/11KV DCross MUSS. The Station installed Capacity of 2x20 MVA & the Station peak load is 14.5 MW. The feeder peak load of 60 Amps. The HTVR works out 5.69%.
- You have to pay the following amount at **Doddaballapura Rural** Sub-division, BESCOM within a period of 90 days from the date of this power sanction.
- The Total Estimate Costing of **Rs. 10,13,989/- "Under DCW basis"**. (Application ID: 111111250001)

SINo	Deposit details	Amount in Rs
1	2MMD for 60 KW under LT-6(c)	Rs. 54,840/- x 01
2	DCW Cost	Rs. 10,13,989/-
3	5% Tender Premium on DCW Cost	Rs. 50,699/-
4	9% CGST	Rs. 4,562/-
5	9% SGST	Rs. 4,562/-
6	5% ESCOM Establishment Cost on Total DCW Cost	Rs. 50,699/-
7	9% CGST	Rs. 4,562/-
8	9% SGST	Rs. 4,562/-

- The clause 8.14(ii) is applicable defined in COS of KERC.

As per reference-5, the Metering arrangements for consumer availing load between 50 KW to 150 KW at low tension shall be as follows:

- O1 No of CT & PT operated 0.2S accuracy class meter with provision for check meter.
- 03 Nos of LT CT's of 0.2s accuracy class with burden of 2.5 VA and secondary current IA.
- 03 Nos of LT PT's of 0.2 accuracy class with burden of 5 VA and ration 440/3/110/3 volts.
- 01 No. 9f Modem
- 02 No of test terminal Block and suitable bus bar.