

AEE/KALLAMBELLA OMU / (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, KALLAMBELLA OMU Sub Division
BESCOM , KALLAMBELLA OMU

To
PROJECT DIRECTOR NHAI
572137

Sir/Madam

Sub : Arranging power supply to an extent of **20.00 KW** in favor of PROJECT DIRECTOR NHAI 572137 in KALLAMBELLA OMU OMU, KALLAMBELLA OMU

Ref: 1) Your application registration **62212206250001** dated **03-JUN-2025**

2) AEE/KALLAMBELLA OMU /AE(T) a/ **01-JUL-2025**

With reference to your application dated **03-JUN-2025** . Requesting for arranging power supply to an extent of **20.00 KW** power installations in favor of PROJECT DIRECTOR NHAI 572137 in KALLAMBELLA OMU OMU, KALLAMBELLA OMU Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M KALLAMBELLA OMU sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
62212206250001	3742728	LT6(B)SL-PUBLIC LIGHTING - LT6B	20.00 KW	47.6037-47.6037 - MSD+CGST(46.9977)9%+SGST(46.9987)9%=(3450 + (3450*0.09) + (3450*0.09))	3450
62212206250001	3742728	LT6(B)SL-PUBLIC LIGHTING - LT6B	20.00 KW	61.9047-61.9047 - SC CHARGES(SUPERVISION CHARGES)+CGST(46.9977)9%+SGST(46.9987)9%=(150 + (150*0.09) + (150*0.09))	150
62212206250001	3742728	LT6(B)SL-PUBLIC LIGHTING - LT6B	20.00 KW	55.1067-55.1067 - SERVICE LINE CHARGES+CGST(46.9977)9%+SGST(46.9987)9%=(7200 + (7200*0.09) + (7200*0.09))	7200
62212206250001	3742728	LT6(B)SL-PUBLIC LIGHTING - LT6B	20.00 KW	48.1037-48.1037 - ASD+CGST(46.9977)9%+SGST(46.9987)9%=(108000 + (108000*0.09) + (108000*0.09))	108000
Total Amount in Rupees					118800

b. The power supply will be arranged at 0V .

c. The Tariff applicable to your installation will be LT6(B)SL, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM KALLAMBELLA OMU .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., KALLAMBELLA OMU Sub division, BESCOM for information and further needful.

Your's Faithfully,

Your's Faithfully