



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/ATBL/ (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, CHANDAPURA Sub Division
BESCOM , CHANDAPURA

To
M/S VENKATESHWARA SILKS
No 73 BOMMASANDRA INDL AREA

Sir/Madam

Sub : Arranging power supply to an extent of **0.0 KVA 100 HP** in favor of M/S VENKATESHWARA SILKS No 73 BOMMASANDRA INDL AREA in CHANDAPURA OMU, CHANDAPURA

Ref : 1) Your application registration **1322103250231** dated **15-MAR-2025**

2) AEE/ATBL /AE(T) a/ **15-MAR-2025**

With reference to your application dated **15-MAR-2025** . Requesting for arranging power supply to an extent of **0.0 KVA 100 HP** power installations in favor of M/S VENKATESHWARA SILKS No 73 BOMMASANDRA INDL AREA in CHANDAPURA OMU,CHANDAPURA Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M CHANDAPURA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1322103250231	13221032502310001	LT5-Urban- INDUSTRIAL POWER - LT5A-ULB	0.0 KVA/100.00HP	61.9067-61.9067- TRANSFORMER TESTING FEE	1000
1322103250231	13221032502310001	LT5-Urban- INDUSTRIAL POWER - LT5A-ULB	0.0 KVA/100.00HP	61.9067-LT METERING CUBICAL TESTING CHARGES	4080
1322103250231	13221032502310001	LT5-Urban- INDUSTRIAL POWER - LT5A-ULB	0.0 KVA/100.00HP	61.9047-5% Supervisory Charges (61.904)	51047
1322103250231	13221032502310001	LT5-Urban- INDUSTRIAL POWER - LT5A-ULB	0.0 KVA/100.00HP	48.1017-48.1017 - ISD	93920
Total Amount					150047

- b. The power supply will be arranged at 400V .
- c. The Tariff applicable to your installation will be LT5-Urban, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE RSD-01 BESCOM CHANDAPURA .
- i. Intimation is valid up to 90 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., CHANDAPURA Sub division, BESCOM for information and further needful.

Your's Faithfully,

**Assistant Executive Engineer Ele.,
CHANDAPURA , BESCOM**

Copy to:

- 1.The Executive Engineer Ele. C, O&M CHANDAPURA Division, BESCOM.
- 2.The Asst. Executive Engineer Ele., C,O&M CHANDAPURA Sub division, BESCOM.