



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly Owned Government of Karnataka Undertaking)

NO : EEE/HKTD/AEE(O)/AE-1/2025-26/9093

Date : 31/12/25

Encl:

O/o Executive Engineer (Elec),
C, O&M Hoskote Division,
Hosakote-562114.

Email ID: eehosakotedivision@bescom.co.in
☎: 080-27931033 / 9448279024

To,

Sri. K. P. Narayanaswamy
S/o Late Puttanna,
Sy No. 68/33,
Kannuru Village,
Bangalore East Taluk.

Sir,

Sub: Arranging power supply to an extent of **20 HP** to commercial installation (Water Sale purpose) in favour of **Sri. K. P. Narayanaswamy S/o Late Puttanna at Sy No. 68/33, Kannuru Village, Bangalore East Taluk** in Doddagubbi O&M unit of Avalahalli Sub division.

Ref: 1. Your Online Application Registration I.D No. **1125111250138** dt:19.11.2025.
2. Estimate No. PJK(HP)-268 dt.20.12.2025.
3. Ltr.No. AEE(Ele)/AVL/AE(T)/2025-26/4551 dt:22.12.2025 of AEE (Ele), Avalahalli.
4. ಪತ್ರ ಸಂಖ್ಯೆ: ಬೆವಿಕಂ/ ಬಿಸಿ-35/ ಪ್ರವ್ಯ(ವಿ)/ಗು,ಪ್ರ &ಸು/2022-23/CYS-06 ದಿನಾಂಕ: 30.04.2022

With reference to your application, requesting for power supply to an extent of **20 HP** for above address, we are pleased to convey Power supply will be sanctioned to **20 HP under Self Execution as a optional based on your request** subject to the following conditions.


1. The power supply will be arranged at 400 Volts.
2. The tariff applicable to your installation will be under **LT-3** Tariff in force.
3. You have to enter into an agreement with the Company in the prescribed form as per Electrical supply regulations within 21 days failing which this intimation lapses.
4. You have to pay the following amounts in the form of DD in favour of Assistant Executive Engineer Ele., BESCOM, Avalahalli Sub Division within 90 days from the date of this power sanction.
 - a. **Rs. 24,510/-** towards Security Deposit.
 - b. **Rs. 14,016/-** towards 5% Supervision charges on estimate cost of Rs. 2,80,325/-.
 - c. **Rs. 1,000/-** towards on MRT transformer testing charges.
 - d. **Rs. 5,000/-** towards on Material Inspection charges.
5. **Smart Meter should be purchased by consumer** from retail outlet of BESCOM.
6. Submit the contractor's completion-cum-test report along with wiring diagram in duplicate.
7. You should provide circuit breaker as prescribed by the Corporate BESCOM which must be erected within one meter of the Company's meter Board or in such other position as shall be approved by the Corporation as per Regulation 409. No fuses shall be provided on the neutral conductor.
8. The Materials to be procured by the agencies for execution of works on Total Turnkey, Partial Turnkey and Self execution works shall be invariable got inspected by TA&QC or BESCOM authorities as the case may be before commencement of work.
9. All the Major Materials shall be procured by the agencies only from the BESCOM approved vendors and other materials may be procured from authorized dealers of approved vendors of BESCOM.
10. The firms shall submit copies of the invoices / bills in respect of materials purchased by them for this work.
11. Transformer installed under Self execution scheme has to be tested by the concerned MT Section as per circular cited under reference (4).

12. Power supply will be arranged to you only after erection of **25 KVA oil type Transformer.**

This is provisional intimation, In case the above requirements are not complied WITH IN 90 Days from the date of this letter, sanction of power as well as registration will STAND CANCELLED and registration fee paid will stand forfeited.

You are requested to contact the Asst. Executive Engineer(El.), BESCOM, O&M Sub Division, Avalahalli for further needful.

Yours faithfully,


Executive Engineer, El.,(C, O&M),
BESCOM, Hosakote Division.