

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ
(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)
ಕಾರ್ಯ ಮತ್ತು ಪಾಲನೆ ವಿಭಾಗ, ಚಂದಾಪುರ,
ಬಿ.ವಿ.ಕಂ, ಬೆಂಗಳೂರು-560081
ದೂರವಾಣಿ: 080-2781003



BANGALORE ELECTRICITY SUPPLY COMPANY
(A Government of Karnataka Undertaking)
O&M Division, CHANDAPURA
BESCOM, Bangalore-560081
E-Mail: eechndpr.work@gmail.com

NO : EE(E)/CDP/AEE(O)/AET-1/2025-26 / 3042-43

Date : 30 JUN 2025

-: OFFICIAL MEMORANDUM :-

Sub: Arranging tapping power supply to an extent of 17 KW through a sub meter under LT-3 tariff from existing HT Installation bearing RR No. CDPHT870 (HT-2a tariff) to the proposed installation in favour of Mr. Abdul Jabbar Khan, Plot No 28, BIA, Anekal Taluk.

- Ref: 1. Online Application Ref No: 1322105250031 Dated: 16-05-2025.
2. Ltr No. EE/CDP/AEE(O)/AE-T/25-26/2564-65 dt: 13-06-2025.
3. Superintending Engineer (E), BESCOM, O&M Ramanagara Circle Office Approval Letter Ref No: SEE/RMGC/EE (O)/AEE (O)/2025-26 / 1678-79 Dated: 17-06-2025.
4. BESCOM/CGM(O)/DGM(O)-3/AGM(O)-3/F-332/20-21/CYS-83 dated 28.10.2020
5. BESCOM/CGM(O)/DGM(OP-3)/AGM-1/F-332/20-21/ CYS-110 dated 22.12.2020
6. BESCOM/CGM(O)/DGM(OP-3)/AGM-1/21-22/ CYS-134 dated 09-11-2021
7. COS 5th Amendment-2016, Clause :8.14 (ii)

With reference to the above, as per the recommendation of this office vide ref letter No(2), approval was accorded by Superintending Engineer (E), BESCOM, O&M Ramanagara Circle vide Ref(3) for Arranging tapping power supply to an extent of 17 KW through a sub meter under LT-3 tariff from existing HT Installation bearing RR No. CDPHT870 (HT-2a tariff) to the proposed installation in favour of Mr. Abdul Jabbar Khan, Plot No 28, BIA, Anekal Taluk, as per the clause No. 8.14(ii) ERC Conditions of Supply of Electricity of Distribution licensees in the State of Karnataka, subject to the following conditions:

Existing details are as follows:

Name & Address of the applicant	Mr. Abdul Jabbar Khan, Plot No 28, Bommasandra I/A, Anekal Taluk.
RR No / tariff / CD	CDPHT870/ HT2(a) /50 KVA
Date of Service	25-07-2023.
Total CD	50 KVA
Deposit Required for 50 KVA CD as per Tariff Order 01-04-2025.	1,00,500/-
Arrears	Nil
Existing deposit	6,23,610/-
Sub meter requested load and tariff	17 KW / LT3(a)
Estimate cost	NIL

1. **Deposit:** As per the Clarification letter issued from corporate office cited under ref(5), the 2MMD / deposit for the requested sub meter under LT shall not be collected, Since there is a sufficient deposit collected for the main meter.

(Wholly owned Government Undertaking)

SEE/RMGC/EB101/AB101/2025-26/
ed: 152-79

66-8291

mail ID: scitmc_worlkg@gmail.com

one No. 1180-28488723

SCOM GST NO: 29AACCB1412G1Z5

17 JUN 2025

The Executive Engineer (Ele),
C. O & M Division
Chandapura

五

Sub: - Arranging power supply to an extent of **17 KW** through a sub meter under LT-3 tariff from existing RR No. CDPHT-870 (HT-2a tariff) to the proposed installation in favor of Sri Abdul Jabbar Khan, Plot No 28/B, SY No 270, Dommasandra Industrial Area, Anekal taluk

Ref: - 1, BE/CDP/AEE(O)/AET/2025-26/2564-65 Dtd: 13.06.2025.

2. Lir No. CGM(O)/DGM(OP-3/AGM-1/F-332/23-24/CYS-101 dt: 02.11.2023.

新新新新新

With reference to the above, approval is hereby accorded for arranging power supply to extent of 17 KW through a sub meter under LT3 tariff to the proposed installation at sub-meter to existing HT installation bearing RR No. CDPHT-870 (HT-2a tariff) tariff having a CD 50 KVA.

Existing details are as follows:

Name & Address of the applicant	Sri Abdul Jabbar Khan
RR No / tariff / CD	CDPHT-870/ HT2(a) /50 KVA
Date of Service	25-07-2023
Total CD	50 KVA
Arrears	Nil
Existing deposit	Rs 6,23,610/-
Sub meter requested load and tariff	17 KW / LT3
Estimate Cost	NIL

1216

1. As per the proceedings vide letter cited under ref (2), the 2MMD / deposit for the re-meter under HT installation shall not be collected, provided there is a sufficient deposit for main meter.
2. You have to execute the following works under self-execution.
 - a) You should execute an agreement in the prescribed form and shall be submitted to Executive Engineer Ele., of concerned division.
 - b) Produce necessary Licensee/permit /No. objection Certificate, etc. issued by the co-ordinating authorities as required under statute.
 - c) Submit the completion-cum-test report from Class-I Licensed Electrical Contractor with lists in duplicate showing details of machinery, make, capacity and the lay-out of your premises within which you intend to use the power. The capacity of any individual machinery equipment installed /connected shall not be more than the contract demand.
 - d) You should produce the approval of competent authority of Electrical inspectorate to connect the equipment installed by you.
3. You are liable to pay the tariff minimum charges from the date of commencement of supply i.e., actual date of ailment of the power supply or expiry of 30 days of notice issued by BESCOM whichever is earlier as indicated in the agreement even if you fail to avail power supply.
4. The power tariff applicable to your installation will be LT3 as in force from time to time. The Metering equipment to be installed is to be conspicuously visible at the main entrance of the premises preferably with an independent entrance and shall mandatorily provide a featured DLMS protocol ETV meter.
5. As per Circular CGM(O)/DGM(O)-3/AGM(O)-3/F-332/23-24/CYS-101 dated 01.11.2023. Arranging power supply under sub-meter with a condition: the maximum load of sub-meter / meter requested shall not be more than 49% of Contract demand or the Sanctioned load of main meter.
6. Billing of Sub meter / meters: Vide Ltr No. BESCOM/DGM(O)-3/AGM(O)-3/F-332/21/CYS-83 dated 28.10.2020 procedures for arranging power supply under sub meter applications.

7. Deposit: In proceeding vide letter CGM(O)/DGM(OP-3)/AGM-1/F-332/20-21/ CYS-110 dated 22.12.2020 the 2MMD / deposit for the requested sub meter under HT shall not be collected, provided there is a sufficient deposit collected for main meter.
8. In proceeding vide letter BESCOM/DGM(O)-3/ AGM(O)-3/F-332/20-21/CYS-83 dated 28.10.2020 the clause no.4 & 8.14(ii) of CoS shall be applicable.

Yours faithfully,



Superintending Engineer (Ele),
Ramanagara Circle.

Copy to:

1. The Assistant Executive Engineer (Ele), C,O&M **Chandapura** sub-division.
2. EE(O)/AEE(O) for information.