

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ., ( ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ )

**Bangalore Electricity Supply Company Limited** 

No.EE(E)  $\triangle$  AEE(O)  $\triangle$  AE(T)-2/24-25/

12951-53

Office of the Executive Eng, (Ele)., C O & M Division, BESCOM, Tiptur Date:

## Official Memorandum for Work Execution 1 3 FFR 2025

**Sub:** Arranging HT power supply to an extent of load enhancement of existing contract demand 450KVA of RRNo.: CHT-10 requesting additional load 200KVA total (450KVA+200KVA=650KVA) in favor of Manager, N R Cements Pvt Ltd., Salakatte Cross, Thimmanahalli section, C N Halli Sub Division. (Under Self Execution Basis).

**Ref**:1)BESCOM Corporate Office Order No: BC-47/GM(P)/(O)/2762/CYS- 21/07.06.2010. 2) T.OPower sanctioned letter No: EE(E)/AEE(O)/2024-25/11260-62/Dt: 04.01.2025.

3) Payment Certificate No: AEE(E)/AAO/CNH/7315 Date:27.01.2025.

\*\*\*\*\*\*

"This estimate is sanctioned vide letter cited under ref-(2) for Arranging HT power supply to an extent of load enhancement of existing contract demand 450KVA of RRNo.: CHT-10 requesting additional load 200KVA total (450KVA+200KVA=650KVA) in favor of Manager, N R Cements Pvt Ltd., Salakatte Cross, Thimmanahalli Thimmanahalli section, C N Halli Sub Division (Under Self Execution Basis).

The applicant has paid of the following deposits at the office of the AEE(E), C N Halli Sub Division.

Account Head	Amount	Receipt No.	<b>Amount Paid Date</b>
ISD Charges	412000.00	0615	
5% of Supervision	2283.00	0613	
charges on EC Charges			27.01.2025
Supervisory Charges	250.00	0614	

The materials purchased by the consumer shall be inspected by Q.S & S wing, BESCOM, as per circular No: BESCOM/GM(QS&S)/DGM-3/BC-11/F-1425/2013-14/CYS-125/19.02.2014. Testing of all Self Execution Transformers irrespective of capacities at Transformer Testing Centers of BESCOM jurisdiction as per circular CGM(OP)DGM(OP-1)AGM(OP-3)/AE-1/BC-05/2020-21/CYS-164/29.03.2021 and before execution this certificate shall be given to the concerned A.E.E(E) of the Sub- Division. Take Necessary safety precautions while executing the work by Class-1 electrical contractor. If any Electrical / Mechanical accidents occurred without any safety precautions by the Electrical Contractor the BESCOM is not responsible. You should submit the relevant documents and details of Class-1 Electrical contractor to the concerned Sub division Officer & Section Officer before commencement of the work.

The materials like CT/PT are to be procured from approved BESCOM vendors. After completion of the work joint survey is to be taken by the Consumer/Section nofficer/Sub-division officer. Pre commission test has to be conducted by HT rating officials. After commissioning of the equipment, HT installation, the asset like new line and their equipment drawn up to metering cubicle is to be handede over to BESCOM as per regulation code 8.09 of conditions of supply of electricity. The applicant has to furnish a guarantee certificate, inspect of line materials and work for a period of one year from the date of service.

This work should be completed within a period of 90 Days. The installation will be serviced duly observing BESCOM formalities & prevailing KERC regulations. The applicant has to give guarantee for the materials and work for a period of one year from the date of completion of the work. The materials shown in the estimate are vide work order No F-48667 dated 31.01.2025 and credit materials shown in the estimate are vide work order No F-49667 dated 31.01.2025 to be returned back to stores.

Junior Engineer(Ele). BESCOM,Tiptur.

Asst. Executive Engineer (Ele) BESCOM, Tiptur.

Accounts Officer (F8 BESCOM, Tiptur.

Executive Engineer,(Ele.,) C,O&M,Division,BESCOM,Tiptur.

Copy:

1.Asst. Executive Engineer(Ele) BESCOM, Sub-Division Office, C N Halli.

2. Asst. Executive Engineer(Ele) BESCOM, Division Office, Tiptur.

3. Junior. Engineer(Ele) BESCOM, Division Office, Tiptur.

4. Senior Assistant C Register O&M Division, BESCOM Tiptur.

5. O/C.