



NO : EE(E)/CDP/AEE(O)/JET-2/2025-26 / 5155-59

Date :

7 1 AUG 2025

**-: OFFICIAL MEMORANDUM :-**

Subj: Enhancement of contract demand of the existing HT installation from 65 KVA to 250 KVA (Addition 185 KVA) bearing RR No. JGNHT-873 under HT-2(a)(i) tariff in favour of Sri M Babu, S/o Muniswamy, Rajapura village, in Jigani Link Road O&M, Jigani sub Division Anekal Taluk - under self-execution.

- Ref:
1. Online Application Ref No: 61324107250048 Dated: 23-07-2023.
  2. Executive Engineer (Ele), BESCOM, C O&M Chandapura Division Intimation Letter Ref No: EEE/CDP/AEE(O)/AET/2025-26/4373-74 Dated: 01-08-2025.
  3. Payment Certificate Letter No: AEE/JIG/AAO/SA/25-26/2318, Dated: 18-08-2025.
  4. Circular No. BESCOM/GM(QS&S)/BC-35/DGM-4/AGM-5/23-24/CYS-186 Dated 12.02.2024.
  5. This office Self-execution Work Certificate Ref No: EE(E)/CDP/AEE(O)/AET/2025-26 / 5060-62 Dated : 19-08-2025.

....

With reference to the above, as per the recommendation from Jigani sub division office, approval was accorded by Executive Engineer (Ele), BESCOM, C O&M Chandapura Division vide Ref(2) & (5) for Enhancement of contract demand from 65 KVA to 250 KVA (Addition 185 KVA) bearing RR No. JGNHT-873 under HT-2(a)(i) tariff in favour of Sri M Babu, S/o Muniswamy, Rajapura village, in Jigani Link Road O&M, Jigani sub Division, as per the clause No. 34.01 KERC Conditions of Supply of Electricity of Distribution licensees in the State of Karnataka, subject to the following conditions :

1. The Consumer has supplied the necessary CTs and in presence of AEE, MT division, BRAZ & the MT Staff, the existing 11 KV, CTs of ratio 5/ 1A, 0.2S class of accuracy is replaced by new CTs of ratio 15 /1A, 0.2s class of accuracy. The cost of the Sanctioned estimate is Rs. 46,970 /-(Total rupees Forty six thousand nine hundred seventy only)
2. Metering standards is as per BESCOM circular cited under ref -5.
3. The Consumer has paid the following amounts in favour of AEE, BESCOM, Jigani sub division

Sl No	A/C Head	Amount in Rs	RT No	Date
1	ISD	1,42,500-00	1324101019793	18-08-2025
2	supervision charges @ 5% on estimate cost of Rs. 46,970 /-	2,349-00	1324101019792	
3	CGST 9 % on SC	211-00	1324101019792	
4	SGST 9 % on SC	211-00	1324101019792	
Total Amount Paid		1,45,271-00		

4. The consumer is liable to pay the tariff minimum charges from the date of commencement of supply ( i.e Actual date of availing of power supply or expiry of 30 Days' notice period issued by the BESCOM whichever is earlier) as indicated in the agreement even if consumer fail to avail power supply.
5. The Additional contract demand is final and it will not be revoked at later date.
6. The Additional contract demand shall be with effect from the Date of CT Replacement ( MRI Date) for Enhancement of contract demand / sanctioned load along with fresh agreement to Additional contract demand & to obey Section 32.04 & its amendments from time to time.
7. The energy entitlement shall be re-fixed on Pro-rata basis (applicable during Power cut period).

8. Signature of the consumer shall be tallied with the signature in the original docket effecting the Additional Contract Demand as per Norms.
9. The Consumer has to pay arrears and audit short claims, if any, detected at a later date.
10. The Consumer has to give an undertaking that he will abide by the above Conditions / of the appellate authority in respect of pending appeal/ court cases, if any.
11. The installation shall be rated by M.T Staff before & after implementation of Additional load.
12. The Consumer shall abide by the rules/regulations, if any, left out and regulations issued on dates.
13. The capacity of any individual machinery / equipment installed / connected shall not be, than the approved CD.
14. If SRTPV Load is sanctioned to this Consumer, then the existing PPA has to be withdrawn immediate effect and Supplementary PPA to be executed as per prevailing KERC / BES Norms.

All Other formalities shall be observed as per the prevailing KERC regulations.

**Executive Engineer(Ele),  
C, O&M Chandapura Division,  
BESCOM.**

**Copy to:**

1. The Executive Engineer Ele, MT, BRAZ, BESCOM, Bangalore for information
2. The Accounts Officer, BESCOM, Chandapura Division for information
3. The Accounts Officer (I/A), BESCOM, Chandapura Division for information.
4. The Assistant Executive Engineer Ele, BESCOM, C, O&M Jigani Sub Division, for information along with file.
5. Sri M Babu, S/o Muniswamy, Rajapura village, Jigani hobli, Anekal Taluk -560105.
6. AE(T) / M.F / OC.

Ref Credit Wo No & Date	461/WDV/16.206.7/ S-61504 Dated : 19-08-2025
Ref ACK No & Date	



11 KV CT 11  
12.5/1A MC-1250  
MC-1250

ocket be  
date.  
ns / deci

(ಕಂಪನಿಯ ಉಪಯೋಗಕ್ಕಾಗಿ)

HT 2.0) ಆರ್.ಆರ್.ಸಂ.ಬರೆಯಲಾಗಿದೆಯೇ?  
Cyl 65KVA ಮಾಪಕದಲ್ಲಿ ಹಾಕಿಯನ್ನು ಇರಲಾಗಿದೆಯೇ?  
ADDL 185.5 KVA ಪ್ರಸ್ತುತ ಸಂಖ್ಯೆ  
70.5-250 KVA ದಿನಾಂಕ  
ಸಂವತ್ಸರ

Yes  
Yes  
Add Load  
JG NHT-872  
22-08-25

ಪ್ರಾಣಾ ಟ್ರಾನ್ಸ್‌ಫಾರ್ಮರ್‌ಗಳು

ಇರುವ ಸ್ಥಳ

ವೈಲ್ಡ್‌ನ ಪರಮಾಣು

ಸಾಮರ್ಥ್ಯ

ಸಂವತ್ಸರ ಪರಮಾಣು

ಸಾಮರ್ಥ್ಯ

ಮಾಪಕ ಮತ್ತು ತಯಾರಿಕೆ

ಸಾಮರ್ಥ್ಯ

ವ್ಯಾಪ್ತ ರೀತಿಗಾಗಿ

ತರ

ಮಾಪಕವನ್ನು ಸರಿಯಾಗಿ ಮೊದಲು ಮಾಡಿದೆಯೇ

ಮಾಪಕ ಬಿಡಿಭಾಗಗಳ ಕವರನ್ನು ಮೊದಲು ಮಾಡಿದೆಯೇ

ಕಟಾಪಿಟ್ ಮೊದಲು ಮಾಡಿದೆಯೇ

ಈ ಇನ್‌ಸ್ಟಲೇಷನ್ ವೈರಿಂಗ್

ನಿಯಮಗಳಿಗೆ ಅನುಸಾರವಾಗಿದೆಯೇ

ಯಾವುದಾದರೂ ಸ್ಥಳಗಳನ್ನು ಗಮನಿಸಲಾಗಿದೆಯೇ

ಮಾಪಕ ಅರವರವನ್ನು ಪರಿಶೀಲಿಸಲಾಗಿದೆಯೇ?

ಸರಿಯಾಗಿದೆಯೇ ಮತ್ತು ಅದು

ಮಾಪಕ ಕಾರ್ಯವನ್ನು ಹಾಕಿದೆಯೇ

Rajapur  
11KV/433V DT  
17800KVA  
250. (KVA)

ಮೊಸ  
ಟ್ರಾನ್ಸಿಂಗ್  
ಮೂಲದ ಕಾಸಿಂಗ್  
ಯಾವ ಸಂಖ್ಯೆಯ ಕಂಬದಿಂದ  
ಈ ಆರ್. ಆರ್. ಸಂಖ್ಯೆ ನುಡುರು

LET  
1A

CKWH:-465.82

SKNo:-1713025

ಮಾಪಕ ಓದುವ ದಿನಾಂಕ  
ಸೇವಾ ಮಾರ್ಗ  
ಕಂಬಕ್ಕೆ ಸಿಯು/ಎ  
ಕೇಬಲ್ ಮಲ್ಟಿಪ್ಲಿ/ದಿನಾಂಕ/ಸಿಯು/ಎ

Add Load  
JG NHT-872

BKWH:-463.97

AS PW

HT, MRT

Report

Add Load

No

ಪರಿಶೀಲನೆ

Yes

ಘಟನೆಯ ನೆಲೆಗೆ

Yes

ಸ್ಥಳೀಯ ನೆಲೆಗೆ

ದೃಢೀಕರಿಸುವುದೇನೆಂದರೆ, ನಾನು ಸ್ವಾಮ್ಯವನ್ನು ಪರಿಶೀಲಿಸಿದ್ದೇನೆ.

KALAYRAVESHWARA ELECTRICALS  
ಗುತ್ತಿಗೆದಾರ/ಕಾರ್ಮಿಕ (ಸಹಕಾರದ ಸಮಿತಿ) actor

Issued No. 10193467

No. 713/44-79, Rajapur (V), Taluk, District, Karnataka (India)

Phone - 560 105.

Mobile - 8892209959

ಕಛೇರಿ ಉಪಯೋಗಕ್ಕೆ ಮಾತ್ರ

ಮಂಜೂರಾತಿ ಸಂಖ್ಯೆ

ಮಾತೆ ಪ್ರಸ್ತುತ ಪುಟ ಸಂಖ್ಯೆ

ಮಾತೆ ಸಂಖ್ಯೆ

ಕಾರ್ಯ ಆದೇಶ ಸಂಖ್ಯೆ ಮತ್ತು ದಿನಾಂಕ

ಇನ್‌ಸ್ಟಲೇಷನ್

ಸಂವತ್ಸರ ಸಂಖ್ಯೆ

ಪರಿಶೀಲಿಸಿದೆ

ವಾಯಕ ಇಂಜಿನಿಯರ್

ಸಹಾಯಕ ಕಾರ್ಯ ನಿ. ಇಂಜಿನಿಯರು

ಹಿರಿಯ ಸಹಾಯಕ/ಸಹಾಯಕ ಲೆಕ್ಕಾಧಿಕಾರಿ



## Bangalore Electricity Supply Company Ltd.

Page 1 of 3  
Format F-09-14

EE MT / AEE(O) / BRAZ / AEE HTR /

HT Rating Report

2864

Asst. Executive Engineer (Ele.),  
Jigani O&M Sub-Division  
SCOM, JiganiOffice of the  
Executive Engineer (Ele.),  
MT Division, BRAZ, BESCOM  
3rd Floor, Crescent Tower  
Bangalore - 560 001.

Date 22/8/25

Addl. load  
Exst + Addl: Total  
65 + 185 = 250 kVA  
CTR s/l by 12.5/1A  
MC 500 to 1250

Subject : Rating Report of HT / EHT Installation

e H.T. Installation having the following details has been rated for periodical rating / complaint on 22/8/25  
 u are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent  
 this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

## DETAILS OF H.T. INSTALLATION :

R.R. No. JENHT-873 CD. 65+185=250 KVA

Previously rated on 5/02/2025

Name &amp; Address of the Consumer.....

Meter Constant. South 1250. Activity. HT2(a)

## OBSERVATION &amp; ADVICE ON TECHNICAL MATTER :

The installation meter is calibrated before & After replacement  
 of CTRs on account of addl load the error recorded found to  
 be within permissible limits.

## ADVICE ON REVENUE MATTER :

Tariff HT2(a)

New CD = 250kVA

MC = 1250

DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint.....

Yours faithfully,

Asst. Executive Engineer (Ele.),

HT Rating Sub Division, R/S

BRAZ, BESCOM, Bangalore.

Copy for kind information to :

The Executive Engineer Ele., MT Division, BRAZ, Bangalore.

Executive Engineer Ele, O&amp;M Chandapura Division, BESCOM, Chandapura

case of discrepancies :

Chief Engineer Ele., BRAZ, B'lore.

Superintendent of Police, Vigilance

Accounts Officer, Internal Audit.

# DETAILS OF SEALS :

## ANNEXURE

JGNTF-872(A/L) 2864

Seals Provided to	Sl. No. of Seals Found		Sl. No. of Seals Left	
	Lead	Plastic	Lead	Plastic
M.C. of Meter				
TC of Meter		BM 232822 / EA 22261		
M.D. Reset Knob		BA 2A 53253		3 Retained
Optical Port		BA 2-56510		
T.T.B.				RM 1623587
Meter Chamber Main Door		BA 2R 33487		
Meter Reading Window		BA 2R 33488		RM 1623588
C.T. / P.T. Chamber				RM 1623589
Cable Entry Chamber		BA 2-56513		RM 1623590
		BA 2-56516		RM 1623591

# DETAILS OF THE EQUIPMENTS :

- a) Cubicle Type : Cable Entry / 6 bushing / 3 bushing / LBS. Make..... AS Existing  
b) Cubicle Conditions & Location..... Good Sl. No. ....  
c) Supply side G.O.S. : In Service / Direct / Removed  
d) Lightning Arrestor - Provided / Not Provided

# DETAILS OF CTs / PTs :

	Existing	After Replacement	Existing	After Replacement
Make	Kalpa	Kalpa	Kalpa	
Type	WP	WP	Earthed	
Class	0.2	0.25	0.2	
Insulation Level	15/38/95	15/38/95	15/38/95	
Burden	2.5	2.5	25	
Ratio Available	5/1A	12.5/1A	11kV/15/11kV/15	
Ratio Connected	5/1A	12.5/1A	or	
Sl. No. 1.	2652	5509	276028	
2.	2653/22	5510/25	276029	
3.	2654	5512	276030	

# DETAILS OF METERS :

## ETV Meter

	Existing	After Replacement
Make	LGT	
Type	WP300ERR11KARS	
Class	0.25	
Voltage	24.63.5	
Ampere	1A	
Pulse / Unit	50000	
Dial Constant	1	
Sl. No.	17130525	

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ  
ಕಾರ್ಪೊರೇಷನ್ ಸ್ವಾಮ್ಯ, ಒಳಪಟ್ಟಿದೆ)  
ಯು.ಎಂ.ಪು. ಪಾಲಿಸ್ ವಿಭಾಗ, ಚಂದಾಪುರ,  
ಬೆಂ.ಕಂ. ಬೆಂಗಳೂರು-560081



BANGALORE ELECTRICITY SUPPLY COMPANY  
(A Government of Karnataka Undertaking)  
O&M Division, CHANDAPURA  
BESCOM, Bangalore-560081  
E-Mail: eechndpr.work@gmail.com

1-50  
88

NO: EE(E)/CDP/AEE(O)/AET/2025-26/

5060-62  
**SELF EXECUTION WORK CERTIFICATE**

Date:

9 AUG 2025

The line work is proposed for arranging additional power supply to an extent of 185KVA to the existing 55KVA total 250KVA bearing RR.No.JGNHT-873 in the name of Sri M Babu, S/o Muniswamy, Rajapura village, Jigani Link Road O&M, Jigani Sub-Division is here by sanctioned. You are requested to complete the Line Work through a Valid class-I Licensed Electrical Contractor as per the approved sanctioned estimate costing Rs.46,970/- under self-execution. The work shall be carried under the supervision of Asst. Executive Engineer (Ele)/ Asst. Engineer (Ele) of Jigani Sub-Division.

Supervision Charges of Rs.2349/- vide Rept No.1324101019792 Dated:18-08-2025 at 5% on the cost of the estimate is collected. No work order is assigned under any Head of Account of the Corporation to this work. This Certificate itself is treated as sanction for execution of work. After completion of work, joint inventory as prescribed vide Chief Controller of Accounts circular No. A0/Sa.4/Cys-10/92-93, dated 20-04-92 (page 246 of Compendium vol.1) will be taken and asset accounted in the books.

The applicant has to maintain the following corridor width, based on the voltage of EHV line, if any EHT line passes through the layout/M.S Building.

66KV	220KV	400KV
18 mtrs (9 mtrs on either side from the center of the line)	35 mtrs (17.5 mtrs on either side from the center of the line)	51 mtrs (25.5 mtrs on either side from the center of the line)

All the electrical equipment such as LBS, Transformers and Metering cubicle shall be provided in Ground floor only.

As per circular No. BESCOM/BC-33/ F-2338/ CYS-11/05.05.09 vide Sl. No. 15(a); the materials procured by the contractors for execution of total turnkey/ Partial turnkey and self-execution, works shall be invariably be subjected to inspection by competent authority for its quality and specification as approved by BESCOM before commencement of works. The material placed by you is of 1-year guarantee and you have to maintain the same for year.

Consequent to the amendments to the regulation by the Hon'ble KERC vide reference, the work shall be executed, completed and shall avail service within 90 days from the date of this work order as per KERC supply regulation Code 8.05, else the application for power supply will be deemed as CANCELLED. On cancellation of the application, registration/re-registration cum processing charges paid if any shall stands forfeited. For any further details you may contact Asst. Executive Engineer (E), Jigani Sub-Division.

**Important Conditions:-**

- Materials to be procured by BESCOM approved vendors and materials to be inspected by competent authority before execution / commencement of the work.
- Vide ref no:GM(QS&S)/DGM(EI)-3/Mgr/BC-11/21-22/CYS-39/Date:12.07.2021.Incase of all Self execution works where dry type transformer, cable entry transformers are installed but not commissioned (for which there is no vendor approval) shall be commissioned only after getting specific approval from GM(QS&S).
- Applicant has to follow the rules & Regulations as per the circular No: CGM(OP)/ DGM-3/BC-05/F-341/25-26 / CYS-02 Dated : 04-04-2025 for availing power supply.

AE (T),  
BESCOM, CDP

AEE (O),  
BESCOM, CDP

AO (F&C),  
BESCOM, CDP

Executive Engineer (Ele)  
BESCOM, Chandapura.

A/C Head	Amount in Rs.	Receipt No	Date
ISD	1,42,500-00	1324101019793	18-08-2025
5% SC	2,349-00	1324101019792	18-08-2025
9% CGST	211-00	1324101019792	18-08-2025
9% SGST	211-00	1324101019792	18-08-2025

- Ref No:-
- Intimation Ltr. No.EEE/CDP/AEE(O)/AE(T)/25-26/4373-74/Dated:01-08-2025.
  - Payment certificate No.AEE/JGN/ AAO/SA/25-26/2318/ Dated: 18-08-2025.
  - KERC/COS/D/13/14-15, Bangalore, dated 25th August, 2014.

**Copy to.**

- Account Officer (F&C), BESCOM, Chandapura Division, Chandapura.
- Asst. Executive Engineer (Ele), BESCOM, Jigani Sub-Division.
- Sri M Babu, S/o Muniswamy, Rajapura village, Jigani
- AE(T)/MF.

ಕಛೇರಿ: ನಂ. 204, ಪಾರ್ಕ್ ರಸ್ತೆ, 1ನೇ ಹಂತ, ಸೂರ್ಯನಗರ, ಚಂದಾಪುರ, ಬೆಂಗಳೂರು-560081  
Red Office: No-204, Park Road, 1st Phase, Suryacity, Chandapura, Bengaluru-560081