



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly owned Government of Karnataka undertaking)

No:AEE/HTR/DVG/2025-26/06

Email:aeehtr.bescomdvg@gmail.com

Cell No: 9448279331

Date:29.07.2025

Office of the

Assistant Executive Engineer

HT Rating Sub-division, BESCOM

Davangere

OPEN ACCESS METERING ARRANGEMENT TEST REPORT

SUB: Providing Open Access Metering Arrangement in the existing HT Installation of RRNo:KTGHT-01, of M/s Sri. Revanasiddeshwara Stone Crusher SyNo:107/1, Kattige village limits Kattige, Nyamathi Tq. Providing tariff meter (Check Meter) under self execution basis.

REF 1	CEE/SLDC/SEE/TBC/EEE-2/AEE-3/5582-87	Dt:26.06.2025
2	EE(Ele), MTD, BMAZ, Blore LtrNo:1557	Dt:09.07.2025
3	AEE(Ele), QS&S, Davanagere LtrNo:7709-11	Dt:26.06.2025
4	AEE(Ele), O&M Sub-division, Nyamathi Ltr No:21221	Dt:17.07.2025

Dt.of Rating	29.07.2025
Division	Harihara
Sub-Division	Nyamathi
RRNo	KTGHT-01
Consumer	M/s Sri. Revanasiddeshwara Stone Crusher at Kattige
Ex.CD(KVA)	1100KVA
Ex.CT Ratio	60/1A
Ex.MF	6000
Tariff	HT-2(a)

DETAILS OF EXISTING 11KV HTMC (3CT/3PT)

Sl No	Technical Specifications	Equipments Details
1	Make	M/s Vyoma SG
2	Type	Outdoor (Double Window)
3	Sl No/YOM.	211129K252
4	Cubicle Type	Cable, (Without LBS)

DETAILS OF EXISTING 11KV HTMC CT's & PT's

Sl. No.	Technical Specifications		Equipments Details	
			C.T's	P.T's
1	Make		M/s Vyoma	M/s Vyoma
2	Type		RC/WP	RC/WP/Earthed
3	Class of Accuracy		0.2S	0.2
4	Burden in VA		2.5VA	25VA
5	Ratio Available		60 /1A	11KV/ $\sqrt{3}$ /110V/ $\sqrt{3}$
6	Sl No.	R Ø-	VYCP-5861	VYP-M 4374
		Y Ø-	VYCP-5862	VYP-M 4375
		B Ø-	VYCP-5863	VYP-M 4376
7	YOM		2025	2021