



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

NO: EEE(Ele)/MGD/AEE(O)/AE(T)/2025-26/4285
Encl:

E-mail: eemagadi@gmail.com

Office of the
Executive Engineer Ele.,
C, O&M Division, BESCOM
Bychapura road,
Magadi-562120
Date: 14 NOV 2025

OFFICIAL MEMORANDUM

Sub:- Approval for additional load of 175KVA HT power supply to existing 425KVA additional 175KVA (Ex:425+addl:175=600KVA) HT installation bearing RR no.RNHTMGD-15.

- Ref:-1. Power sanction letter no:-SEE/RMGC/EE(O)/AEE(O)/2025-26/3248-50, dated:- 21.08.2025.
2. Payment certificate no:-AEE(Ele)/AET/KSD/2025-26/1016 dated:29.08.2025.
3. Approval letter no:- SEE/RMGC/EE(O)/AEE(O)/2025-26/3925-26, dated:- 15.09.2025.
4.T.O. OM no:-EEE/MGD/AEE(O)/AET/2025-26/3405-06, dt:-22.09.2025.

With reference to the above subject, approval is here by accorded for an additional load of 175KVA to existing 425 KVA (Exi:425+addl:175=600KVA) HT installation bearing RRno: RNHTMGD-15 in the name of M/s Bharath Petroleum at Solur village, Solur hobli, Magadi taluk in Solur O&M section o Kudur Sub-division of Magadi Division.

The total contract demand of the installation will be (existing 425KVA + additional load of 175KVA) 600KVA.

The additional load shall be given effect from the date of pre-comission test.

Yours Faithfully,

Executive Engineer (Ele.)
C, O&M Division, BESCOM
Magadi.

Copy to: -

1. The Asst. Executive Engineer (Ele), BESCOM, C, O&M Sub division, Kudur.
2. M/s Bharath Petroleum at Solur village, Solur hobli, Magadi taluk.
3. M/F.



Bangalore Electricity Supply Company Ltd.

Page 1 of 3
Format F-09-14

HT Rating Report

11859

Office of the
Executive Engineer (Ele).,
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

EE MT / AEE(O) / BRAZ / AEE HTR

Asst. Executive Engineer (Ele).,
Tavarekere

O&M Sub-Division
SCOM,

Date..... 10.11.25

Ref : AEE/AEEI/KSD/25-26/1290/31.10.25

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 10.11.25
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent
to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

DETAILS OF H.T. INSTALLATION : 425+175

Previously rated on 01.04.25

R.R. No. PNHMED-15 CD 600 KVA.

Meter Constant 2500 to 3000 Activity Gas filling Gater (H2A)

Name & Address of the Consumer 60KWP Bhavat Petroleum Industries Ltd

LPG Bottling plant

Solar

OBSERVATION & ADVICE ON TECHNICAL MATTER :

The installation meter is calibrated before & after CT replacement
work on account of additional load, the error records were found to be

ADVICE ON REVENUE MATTER : Within permissible limits.

New MC-3000

DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint.....

Yours faithfully,

(Signature)
Asst. Executive Engineer (Ele.)
HT Rating Sub-Division,
BRAZ, BESCOM, Bangalore.

Copy for kind information to :

The Executive Engineer Ele., MT Division, BRAZ, Bangalore.

Executive Engineer Ele, O&M Division, BESCOM,

Case of discrepancies :

Chief Engineer Ele., BRAZ, B'lore.
Superintendent of Police, Vigilance
Accounts Officer, Internal Audit.

