



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಸಂಪೂರ್ಣ ಕರ್ನಾಟಕ ರಾಜ್ಯ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಸಂಖ್ಯೆ: ಅಇ(ಡಿ)/ರಾಜ್ಯ/ಅಇ(ಇ)/ಸಇಇ/2025-26/ 8055-57
ಲಗತ್ತು:
Email: sermgc.work@gmail.com
Phone No. 080-28488780
BESCOM GST NO: 29AACCB1412G1Z5

ಆಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್(ಡಿ)ರವರ ಕಛೇರಿ,
ವಾ, ಕಾ & ವಾ, ಬೆವಿಕಂ, ರಾಮನಗರ ವೃತ್ತ,
ನಂ.285, ಎಲ್.ಜಿ. ಆರ್ಕೇಡ್,
ಜ್ಞಾನಭಾರತಿ ಲೇಔಟ್, 2ನೇ ಹಂತ,
ವೆಂಕಟೇಶ್ವರ, 100 ಅಡಿ ಡಬಲ್ ರೋಡ್,
ಶಿರ್ಡಿ ಅಪಾರ್ಟ್‌ಮೆಂಟ್ ಹತ್ತಿರ,
ಕೆಂಪೇರಿ ಉಪನಗರ, ಬೆಂಗಳೂರು-560060.

22 JAN 2026

To
'M/s Rashtrothana Parishath,
Rep by Sri N Dinesh Hegde,
Sy no. 337/9, Hulimangala Village,
Jigani Hobli, Anekal Taluk,
Bangalore Urban District.

MS POWER SANCTION

ವಿಷಯ.

ವಿಷಯ: ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ 75ಕೆ.ವ್ಯಾ (ಶಿಕ್ಷಣ) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: 1. ಅಇ(ಡಿ)/ರಾಜ್ಯ/ಅಇ(ಇ)/ಸಇಇ(ಇ)/2025-26/ 11960-61 ದಿನ: 22.01.2026 ಚಂದಾಪತ್ರ ವಿಭಾಗ.

Application IDs: 1324111250064

ನಿಮ್ಮ ಮನೆಯಲ್ಲಿ ನೀವು ಕೋರಿರುವಂತೆ 75ಕೆ.ವ್ಯಾ (ಶಿಕ್ಷಣ) ವಿದ್ಯುತ್ ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿಯಮ 3.1.5 ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ನೂಚಿಸಿರುವ ಪರಮ್ಪುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿನಗಳವರೆಗೆ ಉಳಿಯಲಿರುತ್ತದೆ.

1. ಶಾಪ್ ಕಟ್ಟಿರುವ ಕಟ್ಟಡದ ವಿಸ್ತೀರ್ಣ 14357.41 ಚ.ಡಿ. Ground + 3 Upper Floor & Terrace Floor ಇರುತ್ತದೆ.
ನೀವು ಕೋರಿರುವ ಪ್ರಮಾಣ 75ಕೆ.ವ್ಯಾ (ಶಿಕ್ಷಣ)
2. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಹಾಲಿ ಇರುವ ಎಫ್- 2 Hulimangala ಫೀಡರ್. Hulimangala Muss ಉಪಸ್ಥಾಪಿಸಲಾಗಿದ್ದು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
3. ಉಳಿಯಲಿರುವ ಎಲ್.ಪಿ.-2 ಜಠಾತಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲಿರುವುದು.
4. ಈ ಕೆಳಕಂಡ ಡಿವೀಜ್/ಬಿಲ್ಡಿಂಗ್‌ನನ್ನು ಸ.ಕಾ.ವಿ.ಇ(ಡಿ),ಬೆಂಗಳೂರು ಉಪ-ವಿಭಾಗ ರವರ ಹೆಸರಿನಲ್ಲಿ DD ಯನ್ನು ತೆಗೆದು. 90 ದಿನಗಳೊಳಗೆ ಬಿಡುಗಡೆ ಉಪ-ವಿಭಾಗ ಕಛೇರಿಯಲ್ಲಿ ಪಾವತಿಸುವುದು.

Page 1 of 5

Appl ID:- 1324111250064

Name:- M/s Rashtrothna Parishatha Rep by Sri.N Dinesh Hedge,

SL No.	Particulars	Amount in RS	CGST in RS.	SGST in RS.	Total Amount RS
1	2MMD				
	a) 75KW*01 No.s Tariff LT- 2(74,250/-)	74,250/-	0.0/-	0.0/-	74,250/-
2	5% Supervision Charges on (Total Estimate Cost Rs. 21,63,797/-)	1,07,715/-	9,694/-	9,694/-	1,27,104/- 127103
3	Transformer Testing fees	1,000/-	0.0/-	0.0/-	1,000/-
4	LBS Testing fees	4,080/-	0.0/-	0.0/-	4,080/-
5	RMU Testing fees	4,080/-	0.0/-	0.0/-	4,080/-
6	LTMC Testing fees	4,080/-	0.0/-	0.0/-	4,080/-
Total Amount					2,14,594/-
(Two lakhs Fourteen thousand Five hundred ninety Four only)					214593

- As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- 1 /BC-11 / 2024 -25 /Cys-141, dt:05.12.2024.Dry type transformers required to create infrastructure shall be purchased from BESCOM approved Vendors only.
- If Dry type LBS/500KVA/CSS/transformer has been installed under self execution, an under taking shall be furnished that the same shall be maintained for life time by the applicant.
- As per BESCOM order No: BESCOM/CGM(OP)/DGM (OP-1)/FY 2021-2022/CYS-19 Dt:17.05.2021. The sub divisional officers ensure the transformer quality and rating at the authorized test bench/ Divisional stores duly collecting transformer test certificate issued by the concerned MT division before servicing of installation.
- As per BESCOM Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- 1 /BC-11 / 2024 -25 /Cys-15, dt:19.04.2024. All dry type transformers procured under Self-execution shall be got tested at the nearest test bench center and duly collecting transformer test certificate issued by the concerned MT division.
- As per BESCOM Circular vide ref:-BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates:- 15.02.2025 & CYS-102 dated 25-03-2025, The power supply shall be arranged to the above said installations through "Smart Energy Meter inline with its capacity and quantum of load requirement in BESCOM jurisdiction".

Appl ID:- 1324111250064

Name:- M/s Rashtrothna Parishatha Rep by Sri.N Dinesh Hedge,

11. Guarantee shall be furnished for a period of not less than one year for the materials used in the works as well as for the quality of the work carried out from date taking over of the lines and equipments by BESCO.
12. Provide 01 No ETV Meter with suitable CTs.
13. ಸಿಂಗಲ್ ಫೇಸ್ 0 ಸಂಖ್ಯೆ 5-30 ಅಂಪ್ಸ್ & ಮೂರು ಫೇಸ್ 0 ಸಂಖ್ಯೆ 3*5-30 ಅಂಪ್ಸ್ ಸಿ.ಟಿ ಗಳನ್ನು ತಾಪ್ತ ನಿಯಮಾನುಸಾರ ತಮ್ಮ ವೆಚ್ಚದಲ್ಲಿ ಅಳವಡಿಸಿಕೊಳ್ಳತಕ್ಕದ್ದು.
14. ಮುಖ್ಯ ವ್ಯಾಸಲ್ ಮತ್ತು ವಿತರಣಾ ವ್ಯಾಸಲ್‌ಗಳ ಸಕ್ರಿಯ ಮತ್ತು ದಿನ್ಯಾಸಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ನಿಗಮದ ವಿಭಾಗದಿಂದ ಅನುಮೋದನೆ ಪಡೆಯತಕ್ಕದ್ದು ಮತ್ತು ಮಾಸ್ಟರ್ ಮಾಪಕವನ್ನು ಅಳವಡಿಸುವುದು.
15. ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ Vendors ಗಳಿಂದ 5 ಸ್ಟಾರ್ ಹೊಂದಿರುವ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಪರಿವರ್ತಕವನ್ನು ಸ್ವಯಂ-ಕಾಮಗಾರಿ ಯೋಜನೆಯಡಿಯಲ್ಲಿ ಅನುಮೋದಿಸಿದ ಅಂದಾಜುಪಟ್ಟಿಯ ಪ್ರಕಾರ ಅಳವಡಿಸುವುದು.
16. Before commencement of work, all material shall be inspected from the BESCO authorities.
17. ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಅಳವಡಿಸುವ ಮುನ್ನ ನಿಯಮಾನುಸಾರ ಸೋಲಾರ್ ಪಾಟಿಲ್ ಹಿಟಿಲ್ ಗಳನ್ನು ಕಡ್ಡಾಯವಾಗಿ ಅಳವಡಿಸುವುದು.
18. ವಿದ್ಯುತ್ ಸಂಪರ್ಕಕ್ಕಾಗಿ ನೀವು ಸಲ್ಲಿಸಿರುವ ಬಿ.ಬಿ.ಎಂ.ಪಿ./ಬಿ.ಎಂ.ಆರ್.ಡಿ.ಎ./ಎಸ್ ಪಾಲಿಕೆ/ಗ್ರಾಮ ಪಂಚಾಯತಿಯಿಂದ ಅನುಮೋದನೆಗೊಂಡ ಸಕ್ರಿಯ/ಮಾಲೀಕತ್ವದ ದಾಖಲೆಗಳು ಹಾಗೂ ಇತರೆ ದಾಖಲಾತಿಗಳು ಸಕಲ/ಸುಳ್ಳು ಎಂದು ಕಂಡು ಬಂದಲ್ಲಿ ಯಾವುದೇ ಮುನ್ಸೂಚನೆ ನೀಡದೆ ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕವನ್ನು ಕಡಿತಗೊಳಿಸಲಾಗುವುದು ಮತ್ತು ನೀವು ಪಿ.ಬಿ.ಕೆ.ಗೆ ಪಾವತಿಸಿರುವ ಠೇವಣಿಗಳನ್ನು ಮುಟ್ಟುಗೋಲು ಹಾಕಿಕೊಳ್ಳಲಾಗುವುದು.
19. ನಿಮ್ಮ ಕಟ್ಟಡದ ಎತ್ತರ 15 ಮೀ ಮತ್ತು ಅದಕ್ಕಿಂತ ಜಾಸ್ತಿ ಇದ್ದರೆ ನಿಯಮಾನುಸಾರ ವಿದ್ಯುತ್ ಪರಿವೀಕ್ಷಕರ ಅನುಮತಿಯನ್ನು ಪಡೆಯಬೇಕು.
20. ಒಂದು ಕಂಬದ ವಿದ್ಯಾನುಸಲ್ಲಿ ಅಥವಾ ಪೆಡಿಸ್ಟಲ್ ಮೇಲೆ ಪರಿವರ್ತಕವನ್ನು ಅಳವಡಿಸಲು ನಿಮ್ಮ ಆವರಣದೊಳಗೆ ನೆಲ ಮಹಡಿಯಲ್ಲಿ ಮುಖ್ಯದ್ವಾರದ ಪಕ್ಕದಲ್ಲಿ 3 ಮೀ X 5 ಮೀ ಅಳತೆಯುಳ್ಳ ಆಕಾರಕ್ಕೆ ತೆರೆದಿರುವ ಸ್ಥಳವನ್ನು ಒದಗಿಸಬೇಕು. ಎಲ್ಲಾ ಸಾಮಗ್ರಿಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ BESCO authorities ರವರು ಪರಿಶೀಲಿಸಿದ ನಂತರ ಸ್ವಯಂ ಕಾಮಗಾರಿ ಕೆಲಸ ನಿರ್ವಹಿಸುವುದು.
21. ನಿಮ್ಮ ವತಿಯಿಂದ ನಿಮ್ಮ ಆವರಣದಲ್ಲಿ 1*250 ಕೆ.ವಿ. ಎ "5 STAR RATED" (Oil Cable Entry type) ಪರಿವರ್ತಕವನ್ನು ಸ್ಥಾಪಿಸಿ, ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸಲಾಗುವುದು.
22. ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಸ್ಯೂಪರ್ ಟ್ರಾನ್ಸಿಫರ್ಮರ್ ಮತ್ತು ಇ.ಎಲ್.ಸಿ.ಬಿ.ಯನ್ನು ಮಾಪಕ ಪಟ್ಟಿಯಿಂದ ಒಂದು ಮೀಟರ್ ಒಳಗೆ ಮತ್ತು ಭೂಮಿಯಿಂದ 0.6 - 1.6 ಮೀ ಎತ್ತರದ ಒಳಗೆ ನೆಲ ಮಾರ್ಚಿಯಲ್ಲಿ ಅಳವಡಿಸುವುದು.
23. ಈ ಪತ್ರದಲ್ಲಿ ನಮೂದಿಸಿರುವ ಠೇವಣಿಗಳನ್ನು ಪಾವತಿಸಿದ ನಂತರ, ವೈರಿಂಗ್ ಸಕ್ರಿಯ ಗುತ್ತಿಗೆದಾರರ ಸಮಾಪನಾ ವರದಿ ಮತ್ತು ಒಪ್ಪಂದ ಪ್ರತಿಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ಉಪ-ವಿಭಾಗದಲ್ಲಿ ಸಲ್ಲಿಸುವುದು.
24. ರೆಜಿಸ್ಟರ್ ದಾಖಲೆಗಾಗಿ ಚಂದಾಮರ ವಿಭಾಗದ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ಬಿ).ಜಿ.ಗಣೇಶ ಉಪ-ವಿಭಾಗದ, ನಾರಾಯಣ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್ (ಬಿ) ಅಪರನ್ನು ಸಂಪರ್ಕಿಸುವುದು.

25. ಸಮಿ ಸ್ಯಾಟರ್ನಿಗೆ ದಿವ್ಯಾತ್ ಸೂರ್ಯ ಕಲ್ಪಿಸುವ ಸೂರ್ಯವು KERC ರವರ clause-9 ರನ್ವಯ ಯಾಗೂ KERC upto date Amendment ಗಳನ್ವಯ ಕ್ರಮ ಕೈಗೊಳ್ಳಬೇಕು.

26. ಭದ್ರವು, ಯಾವುದೇ ವ್ಯತ್ಯಾಸವು ಮಾಡಬೇಕಾದಲ್ಲಿ ಕೂಡಲೇ ಅದನ್ನು ಬಿಡುಗಡೆ ಮಾಡಬೇಕು.

27. ಸಮಿ ಗ್ರಾಹಕರು ಅನುಮೋದಿತ ರನ್ವಯ ಕೂಡಲೇ ಯೆಕ್ಸ್‌ಪರಿಯಾಗಿ ಮುಖಾಂತಿಗಳನ್ನು ನಿರ್ಮಿಸಬೇಕು. ಸಮಿ ಸಂಬಂಧವಾಗಿ ಯಾವುದೇ ಯೆಕ್ಸ್‌ಪರಿ ಮಾಡಬೇಕು ಗ್ರಾಹಕರು: ಜವಾಬ್ದಾರಿಯಾಗಿರುತ್ತಾರೆ.

28. The released materials, if any as per 7th schedule credit estimate shall be handed over to the concerned divisional stores.

29. The materials used shall conform to the BESCO Specifications, joint inventory should be submitted after completion of work.

30. Before execution of work the above mentioned License Electrical contractor has to obtain consent letter from the AEE (Ele) of the concerned sub-division for execution of works taking up all the safety measures and the concerned section officer before issuing the Line Clear has to confirm the same with the AEE (Ele) of their respective sub-division & contractor.

31. Precommissioning report from cables from BESCO authorities, shall be obtained for the newly laid cables under self execution works before connecting to the net work.

32. As per Govt Notification No. KERC/COS/DDD/1/2018-19/908, Bengaluru dated:- 22.10.2019. In the conditions of supply of distribution licensees in the state of karnataka, 2006 after the existing clause 9.0, the following new clause shall be insertd, namely-
"9A.00-Applicable to Commercial/Residential Buildings (s)/Complex/MS Building (s) in Metropolitan areas/Urban Development Authority Areas of all Cities/City Corporation areas in the state of karnataka where:

a) The requested load is 250KW or More; or

b) The built-up area of the building is more than 5,000 Square meters

The Owner/Promoter/Occupier of the above building shall also provide not less than two number of charging points capable of Charging Electric Vechicles, i.e four/three/two-wheeler with adequate space in such buildings.

33. The following works are proposed under self-execution.

➤ BESCO portion.

➤ Tapping the 11 KV Line of F2 Hulimangala feeder by existing pole then extension of 11KV line using rabbit conductor to a distance 30mts upto proposed 11mtr spun pole with GOS near the applicant premises then extension of 11kv line using 95 Sqmm xlpe UG Cable to a distance of 80 meters double run up to proposed 3 Way RMU inside the applicant premises under self execution as shown in sketch.

➤ Proposed to Provide the 1x250 KVA5 Star Rated Oil Cable Entry Type Transformer with proposed to provide 01 No of LTMC & 01 No of LBS inside the capplicant premises under self execution as shown sketch.

➤ The out side existing 25KVA Transformer is released and returned to store.

Appl ID:- 1324111250064

Name:- M/s Rashtrothna Parishatha Ren h...

Page 1

34. As per the Circular No. BESCOM/GM(M&C)/DGM(M&C)/AGM-M1/2022-23/CYS-02 dt: 01.04.2022 The metering arrangement is mandatory w.e.f 01.04.2022 towards the consumer requisite load between 50KW to 150KW with LT metering cubicle having the specification and design as per the prototype approval comprising the following:

01 No. of CT & PT operated 02s accuracy class meter with provision for check meter.

03 Nos. of LT CTs of 0.2s accuracy class with burden of 2.5VA and secondary current 1A.

03 Nos. of LT PTs of 0.2 accuracy class with burden of 5VA and ratio 440/ 3 /110 3 volts.

01 No. of Modem.

02No. Test Terminal Block and a suitable bus bar.

Note:

1. Intimation shall be issued to consumers in the power sanction letter to purchase LT metering cubicle from BESCOM approved VENDORS only.
2. All installations serviced with sanctioned load of 50KW to 150KW from 01.09.2021 to till date shall be replaced with the newly mentioned LT metering system as stated vide OM. OM No. BESCOM/GM(M&C)/DGM(M&C)/AGM-M1/2021-22/CYS-19 dt: 01.09.2021.

35. "ನಿಗಮ ಕಛೇರಿಯ ಪತ್ರ ಸಂಖ್ಯೆ: ಮುಪವ್ಯ(ಐ)/ಉಪವ್ಯ-3/ದಿಸಿ-05/ಕ-341/25-26/CYS -02 ದಿನಾಂಕ 04-04-2025 ರ ಪ್ರಕಾರ ಎಲ್ಲಾ ಕ್ಷೇತ್ರಾಧಿಕಾರಿಗಳು ಮಾನ್ಯ ಘನ ಸರ್ವೋಚ್ಚ ನ್ಯಾಯಾಲಯದ ಸಿವಿಲ್ ಅಪೀಲ್ ಸಂಖ್ಯೆ: 14604/2024 ಮತ್ತು 14605/2024 ದಿನಾಂಕ: 17.12.2024 ರಲ್ಲಿ ನೀಡಿರುವ ತೀರ್ಪು/ಆದೇಶವನ್ನು ಯಥಾವತ್ತಾಗಿ ಪಾಲಿಸುವುದು".

NOTE:

For any 765/400/220/66/11 KV lines passing adjacent/near by/on the premises, mandatory clearance certificate should be obtained from the competent authority by the developer / concerned EE of BESCOM before servicing of the installation. In case of any deviation in this regard concerned officers will be held responsible.

ಕಮ್ ಡಿಜೈನ್
P. A. Dinesh Hedge
ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್(ಡಿ),
ಬೆಂಗಳೂರು, ರಾಮನಗರ ವ್ಯಕ್ತ

Appl ID:- 1324111250064

Name:- M/s Rashthrothna Parishatha Rep by Sri.N Dinesh Hedge,

Page 5 of 5



AEE/JIGANI(AET)

Office of the
Assistant Executive Engineer Ele-
C,O&M, JIGANI Sub Division
BESCOM, JIGANI

To
RASHTROTTHANA PARISHAT
SY NO.337/9 HULIMANGALA VILLAGE

Sir/Madam

Sub : Arranging power supply to an extent of 75.00 KW in favor of RASHTROTTHANA PARISHAT SY NO.337/9 HULIMANGALA VILLAGE in JIGANI OMU, JIGANI

Ref: 1) Your application registration 1324111250064 dated 19-NOV-2025

2) AEE/JIGANI /AE(T) a/ 02-FEB-2026

With reference to your application dated 19-NOV-2025 . Requesting for arranging power supply to an extent of 75.00 KW power installations in favor of RASHTROTTHANA PARISHAT SY NO.337/9 HULIMANGALA VILLAGE in JIGANI OMU, JIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1324111250064	13241112500640001	LT2-Rural- DOMESTIC LIGHTING & HEATING - LT2- B2	75.00 KW	61.9067-LT METERING CUBICAL TESTING CHARGES	4080
1324111250064	13241112500640001	LT2-Rural- DOMESTIC LIGHTING & HEATING - LT2- B2	75.00 KW	61.9067-61.9067 - RMU CHARGES	4080
1324111250064	13241112500640001	LT2-Rural- DOMESTIC LIGHTING & HEATING - LT2- B2	75.00 KW	61.9067-(WITH TAX) LBS TESTING FEES+CGST(46.9977)9%+SGST(46.9987)9%=(4080 + (4080*0.09) + (4080*0.09))	4814
1324111250064	13241112500640001	LT2-Rural- DOMESTIC LIGHTING & HEATING - LT2- B2	75.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
1324111250064	13241112500640001	LT2-Rural- DOMESTIC LIGHTING & HEATING - LT2- B2	75.00 KW	61.9047-(WITH TAX) 5% Supervisory Chrgs(61.904)+CGST(46.9977)9%+SGST(46.9987)9%= (107715 + (107715*0.09) + (107715*0.09))	127103
1324111250064	13241112500640001	LT2-Rural- DOMESTIC LIGHTING & HEATING - LT2- B2	75.00 KW	48.1017-48.1017 - ISD	74070
Total Amount in Rupees					215147

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT2-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE BESCOM JIGANI .
- i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., JIGANI Sub division, BESCOM for information and further needful.

Your's Faithfully,

Your's Faithfully,

**Assistant Engineer (Technical),
JIGANI, BESCOM**

**Assistant Executive Engineer Ele.,
JIGANI, BESCOM**

Copy to:

1. The Executive Engineer Ele. C, O&M CHANDAPURA Division, BESCOM.
2. The Asst. Executive Engineer Ele., C,O&M JIGANI Sub division, BESCOM.