



Bangalore Electricity Supply Company Limited

(Wholly owned by Government of Karnataka Undertaking)

No: EEE/HKTD/AEE(O)/AE-1/2025-26/ 10030

Office of
Executive Engineer
C, O&M BESCOM

To

31 JAN 2026

M/s United Projects
Sri. M. Panchasharaiah Hiremath & Others
RR No. AVHTTP57,
Sy No. 29 to 33, 37, 40/1, 42/2, 42/1A, 42/4C,
Huskuru Village,
Bidarahalli Hobli,
Bangalore East Taluk.

Sir/Madam,

Sub: Reduction of contract demand from 250 KVA to 75 KVA, Reduction of 175 KVA of existing HT Temporary installation bearing RR No. AVHTTP57 in favour of M/s United Projects represented by Sri. M. Panchasharaiah Hiremath & Others at Sy No. 29 to 33, 37, 40/1, 42/2, 42/1A, 42/4C, Huskuru Village, Bidarahalli Hobli, Bangalore East Taluk Manduru O&M Unit of Avalahalli Sub Division Under self execution.

Ref: 1) Your Application Reg. No. 61125112250134 dated: 31.12.2025.
2) Letter No:AEE(Ele)/AVL/AET/2025-26/4841 dt. 27.01.2026.

BESCOM is pleased to sanction for reduction of contract demand from 250 KVA to 75 KVA, Reduction of 175 KVA of existing HT Temporary installation bearing RR No. AVHTTP57 in favour of M/s United Projects represented by Sri. M. Panchasharaiah Hiremath & Others at Sy No. 29 to 33, 37, 40/1, 42/2, 42/1A, 42/4C, Huskuru Village, Bidarahalli Hobli, Bangalore East Taluk Manduru O&M Unit of Avalahalli Sub Division Under self execution.

Subject to below conditions:

1. This installation is feeding from F-11 VRKP feeder of 66/11 kV Hosakote MUSS
2. You are requested to pay the following charges by DD/Cash (above 10000/- only DD will be accepted) payable at the office of the Asst. Executive Engineer (C,O&M), BESCOM AVALAHALLI Sub-Division within 90 Days from the date of this intimation and furnish the payment certificate for taking further action in this matter

Payment Towards	Amount(Rs.)
I S D (Existing Deposit holds good for 75 kVA load)	0
5% Supervisory Charge(61.904)	2,340
CGST 9% on 5% Supervisory Charge	211
SGST 9% on 5% Supervisory Charge	211
Total	2,762/-

Amt In Words: Two thousand seven hundred sixty two only

3. To Submit payment certificate along with Self execution agreement on Rs. 500/- stamp paper regarding obtaining of necessary line clearance from field staff for safe execution of works & to comply with all safety procedure duly using safety equipment's during the course of work after which a works certificate / permit will be issued to take up the works on Self execution basis.
4. The metering equipment to be installed should be conspicuously visible and at the main inference to the premises preferably with an independent entrance.
6. You should own and install the necessary transformer at your end to receive and step it down to the required distribution voltage for your installation
It is proposed to replace existing 12.5/5 Amps CT's with 2.5/5 CT's.
7. a) You should execute an agreement in the prescribed form and shall be submitted to the Executive Engineer Ele. of concerned division along with payment certificate.
b) Produce necessary Licensee/permit /NOC objection Certificate, etc. issued by the competent authorities as required under statute.