



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/JIGANI/ (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, JIGANI Sub Division
BESCOM , JIGANI

To
KANISHKA ENTERPRISES
SYNO.227/1 S BINGIPURA

Sir/Madam

Sub : Arranging power supply to an extent of **40.00 KW** in favor of KANISHKA ENTERPRISES SY NO.227/1 S BINGIPURA in JIGANI OMU, JIGANI

Ref : 1) Your application registration **1324112250079** dated **22-DEC-2025**

2) AEE/JIGANI /AE(T) a/ **31-DEC-2025**

With reference to your application dated **22-DEC-2025** . Requesting for arranging power supply to an extent of **40.00 KW** power installations in favor of KANISHKA ENTERPRISES SY NO.227/1 S BINGIPURA in JIGANI OMU, JIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1324112250079	13241122500790001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	40.00 KW	61.9067-61.9067-(WITH TAX)TRANSFORMER TESTING FEE+CGST(46.9977)9%+SGST(46.9987)9%=(1000 + (1000*0.09) + (1000*0.09))	1180
1324112250079	13241122500790001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	40.00 KW	61.9047-(WITH TAX) 5% Supervisory Charge(61.904)+CGST(46.9977)9%+SGST(46.9987)9%=(25685 + (25685*0.09) + (25685*0.09))	30309
1324112250079	13241122500790001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	40.00 KW	48.1017-48.1017 - ISD	64000
Total Amount in Rupees					95489

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM JIGANI .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., JIGANI Sub division, BESCOM for information and further needful.

Your's Faithfully,

**Assistant Engineer (Technical),
JIGANI, BESCOM**

Your's Faithfully,

**Assistant Executive Engineer Ele.,
JIGANI, BESCOM**

Copy to:

- 1.The Executive Engineer Ele. C, O&M CHANDAPURA Division, BESCOM.
- 2.The Asst. Executive Engineer Ele., C,O&M JIGANI Sub division, BESCOM.



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಸಂಪೂರ್ಣ ಕಾರ್ಪೊರೇಟ್ ರಾಜ್ಯ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಸಂಖ್ಯೆ: ಅಇಂ(ವಿ)/ರಾವ್ಯ/ಕಾಇಂ(ಕ)/ಸಕಾಇ/2025-26/

ಲಗತ್ತು:

7500 - 01

E-mail: sermgc.work@gmail.com

Phone No. 080-28488780

BESCOM GST NO: 29AACCB1412G1Z5

ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್(ವಿ)ರವರ ಕಛೇರಿ,
ವಾ, ಕಾ & ಪಾ, ಬೆವಿಕಂ, ರಾಮನಗರ ವೃತ್ತ,
ನಂ.285, ಎಲ್.ಜೆ. ಆರ್.ಡ್,
ಜ್ಞಾನಭಾರತಿ ಲೇಔಟ್, 2ನೇ ಹಂತ,
ವಳಗೆರೆಹಳ್ಳಿ, 100 ಅಡಿ ಡಬಲ್ ರೋಡ್,
ಶಿರ್ಕೆ ಅಪಾರ್ಟ್‌ಮೆಂಟ್ ಹತ್ತಿರ,
ಕೆಂಗೇರಿ ಉಪನಗರ, ಬೆಂಗಳೂರು-560060.

30 DEC 2025

To

M/s Kanishka Enterprises,
Rep by Sri. Senthil kumar M,
Sy No. 227/1,
Bingipura village,
Jigani Hobli, Anekal Taluk,
Bangalore Urban District,
Jigani Sub Division.

MS POWER SANCTION

ವಸಾಹರೇ,

ವಿಷಯ: ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ 40ಕೆ.ವ್ಯಾ (ವಾಣಿಜ್ಯ) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: 1. ಕಾನಿಇಂ(ವಿ)/ಚಂದಾ/ಸಕಾನಿಇಂ(ಕ)/ಸಇಂ(ತ್ರಾಂ)/2025-26/ 10377-78 ದಿ: 26.12.2025 ಚಂದಾಮರ ವಿಭಾಗ.

Application IDs : 1324112250079

ನಿಮ್ಮ ಮನವಿಯಲ್ಲಿ ನೀವು ಕೋರಿರುವಂತೆ 40ಕೆ.ವ್ಯಾ (ವಾಣಿಜ್ಯ) ವಿದ್ಯುತ್ ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿಯಮ 3.1.5 ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಷರತ್ತುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿವಸಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ.

1. ತಾವು ಕಟ್ಟಿರುವ ಕಟ್ಟಡದ ವಿಸ್ತೀರ್ಣ 100 ಚ.ಮೀ, **Ground Floor** ಇರುತ್ತದೆ. ನೀವು ಕೋರಿರುವ ಪ್ರಮಾಣ 40ಕೆ.ವ್ಯಾ (ವಾಣಿಜ್ಯ)
2. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಹಾಲಿ ಇರುವ ಎಫ್-10 Podu ಫೀಡರ್, **HulimangalaMuss** ಉಪಸ್ಥಾವರದಿಂದ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
3. ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಟಿ.-3 ಜಕಾತಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲಿಲ್ಲ.
4. ಈ ಕೆಳಕಂಡ ರೇವಣಿ/ಶುಲ್ಕಗಳನ್ನು ಸ.ಕಾ.ನಿ.ಇಂ(ವಿ),ಜಿಗಣಿ ಉಪ-ವಿಭಾಗ ರವರ ಹೆಸರಿನಲ್ಲಿ **DD** ಯನ್ನು ತೆಗೆದು, 90 ದಿವಸಗಳೊಳಗೆ ಜಿಗಣಿ ಉಪ-ವಿಭಾಗ ಕಛೇರಿಯಲ್ಲಿ ಪಾವತಿಸುವುದು.
5. ತಮಗೆ ಸರಬರಾಜು ನೀಡಲು ತಗಲುವ ಸ್ವಯಂ ಕಾಮಗಾರಿ ಅಂದಾಜು ಪಟ್ಟಿಯ ವೆಚ್ಚ ರೂ. 5,13,696/-ಆಗಿರುತ್ತದೆ.

Page 1 of 4

Appl ID:- 1324112250079

Name:- **M/s Kanishka Enterprises,**

SL No.	Particulars	Amount in RS	CGST in RS.	SGST in RS.	Total Amount
1	2MMD				
	a) 40KW*01 No.s Tariff LT- 3(65,600/-)	65,600/-	0.0/-	0.0/-	65,600/-
2	5% Supervision Charges on (Total Estimate Cost Rs. 5,13,696/-)	25,685/-	2,312/-	2,312/-	30,308/-
3	Transformer Testing fees	1,000/-	90/-	90/-	1,180/-
Total Amount					97,088/-
(Ninety seven thousand eighty eight rupees only)					

6. As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys-141, dt:05.12.2024.**Dry type transformers required to create infrastructure shall be purchased from BESCOM approved Vendors** only.
7. If **Dry type LBS/500KVA/CSS/transformer** has been installed under self execution, an under taking shall be furnished that the same shall be **maintained for life time by the applicant.**
8. As per **BESCOM order No: BESCOM/CGM(OP)/DGM (OP--1)/FY 2021-2022/CYS-19 Dt:17.05.2021.** The sub divisional officers ensure the **transformer quality** and rating at the authorized test bench/ Divisional stores **duly collecting transformer test certificate** issued by the concerned MT division before servicing of installation.
9. As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys-15, dt:19.04.2024. **All dry type transformers procured under Self-execution shall be got tested at the nearest test bench center** and duly collecting transformer test certificate issued by the concerned MT division.
10. As per **BESCOM** Circular vide ref:-BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates:- 15.02.2025 & CYS-102 dated 25-03-2025, **The power supply shall be arranged to the above said installations through "Smart Energy Meter inline with its capacity and quantum of load requirement in BESCOM jurisdiction".**
11. **Guanatee** shall be furnished for a period of not less than one year for the materials used in the works as well as for the quality of the work carried out from date taking over of the lines and equipments by **BESCOM.**
12. Provide 01 No **ETV Meter** with suitable **CTs.**

Appl ID:- 1324112250079

Name:- **M/s Kanishka Enterprises,**

13. ಸುಂಗಲ್ ಫೇಸ್ 0 ಸಂಖ್ಯೆ 5-30 ಅಂಪ್ಸ್ & ಮೂರು ಫೇಸ್ 00 ಸಂಖ್ಯೆ 3*5-30 ಅಂಪ್ಸ್ ಸಿ.ಟಿ ಗಳನ್ನು ತಾವು ನಿಯಮಾನುಸಾರ ತಮ್ಮ ವೆಚ್ಚದಲ್ಲಿ ಅಳವಡಿಸಿಕೊಳ್ಳತಕ್ಕದ್ದು.
14. ಮುಖ್ಯ ಪ್ಯಾನೆಲ್ ಮತ್ತು ವಿತರಣಾ ಪ್ಯಾನೆಲ್‌ಗಳ ನಕ್ಷೆ ಮತ್ತು ವಿನ್ಯಾಸಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ನಿಗಮದ ವಿಭಾಗದಿಂದ ಅನುಮೋದನೆ ಪಡೆಯತಕ್ಕದ್ದು ಮತ್ತು ಮಾಸ್ಟರ್ ಮಾಪಕವನ್ನು ಅಳವಡಿಸುವುದು.
15. ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ **Vendors** ಗಳಿಂದ 5 ಸ್ಟಾರ್ ಹೊಂದಿರುವ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಪರಿವರ್ತಕವನ್ನು ಸ್ವಯಂ-ಕಾಮಗಾರಿ ಯೋಜನೆಯಡಿಯಲ್ಲಿ ಅನುಮೋದಿಸಿದ ಅಂದಾಜುಪಟ್ಟಿಯ ಪ್ರಕಾರ ಅಳವಡಿಸುವುದು.
16. Before commencement of work, **all material shall be inspected from the BESCOM authorities.**
17. ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಅಳವಡಿಸುವ ಮುನ್ನ ನಿಯಮಾನುಸಾರ ಸೋಲಾರ್ ವಾಟರ್ ಹೀಟರ್ ಗಳನ್ನು ಕಡ್ಡಾಯವಾಗಿ ಅಳವಡಿಸುವುದು.
18. ವಿದ್ಯುತ್ ಸಂಪರ್ಕಕ್ಕಾಗಿ ನೀವು ಸಲ್ಲಿಸಿರುವ ಬಿ.ಬಿ.ಎಂ.ಪಿ./ಬಿ.ಎಂ.ಆರ್.ಡಿ.ಎ./ನಗರ ಪಾಲಿಕೆ/ಗ್ರಾಮ ಪಂಚಾಯತಿಯಿಂದ ಅನುಮೋದನೆಗೊಂಡ ನಕ್ಷೆ/ಮಾಲೀಕತ್ವದ ದಾಖಲೆಗಳು ಹಾಗೂ ಇತರೆ ದಾಖಲಾತಿಗಳು ನಕಲಿ/ಸುಳ್ಳು ಎಂದು ಕಂಡು ಬಂದಲ್ಲಿ ಯಾವುದೇ ಮುನ್ಸೂಚನೆ ನೀಡದೆ ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ಏರ್ಪಡಿಸಿದ್ದ ವಿದ್ಯುತ್ ಸಂಪರ್ಕವನ್ನು ಕಡಿತಗೊಳಿಸಲಾಗುವುದು ಮತ್ತು ನೀವು ಬಿ.ವಿ.ಕಂ.ಗೆ ಪಾವತಿಸಿರುವ ಠೇವಣಿಗಳನ್ನು ಮುಟ್ಟುಗೋಲು ಹಾಕಿಕೊಳ್ಳಲಾಗುವುದು.
19. ನಿಮ್ಮ ಕಟ್ಟಡದ ಎತ್ತರ 15 ಮೀ ಮತ್ತು ಅದಕ್ಕಿಂತ ಜಾಸ್ತಿ ಇದ್ದರೆ ನಿಯಮಾನುಸಾರ ವಿದ್ಯುತ್ ಪರಿವೀಕ್ಷಕರ ಅನುಮತಿಯನ್ನು ಪಡೆಯಬೇಕು.
20. ಒಂದು ಕಂಬದ ವಿನ್ಯಾಸದಲ್ಲಿ ಅಥವಾ ಬೆಡ್ಡಿಂಗ್ ಮೇಲೆ ಪರಿವರ್ತಕವನ್ನು ಅಳವಡಿಸಲು ನಿಮ್ಮ ಆವರಣದೊಳಗೆ ನೆಲ ಮಹಡಿಯಲ್ಲಿ ಮುಖ್ಯದ್ವಾರದ ಹತ್ತಿರದಲ್ಲಿ 3 ಮೀ X 5 ಮೀ ಅಳತೆಯುಳ್ಳ ಆಕಾಶಕ್ಕೆ ತೆರೆದಿರುವ ಸ್ಥಳವನ್ನು ಒದಗಿಸಬೇಕು. ಎಲ್ಲಾ ಸಾಮಗ್ರಿಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ **BESCOM authorities** ರವರು ಪರಿಶೀಲಿಸಿದ ನಂತರ ಸ್ವಯಂ ಕಾಮಗಾರಿ ಕೆಲಸ ನಿರ್ವಹಿಸುವುದು.
21. ನಿಮ್ಮ ವತಿಯಿಂದ “ **1*100 ಕೆ.ವಿ.ಎ (Oil Cable entry type)**” ಪರಿವರ್ತಕವನ್ನು ಸ್ಥಾಪಿಸುವುದು.
22. ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಸರ್ಕ್ಯೂಟ್ ಬ್ರೇಕರ್ ಮತ್ತು ಇ.ಎಲ್.ಸಿ.ಬಿ.ಯನ್ನು ಮಾಪಕ ಪೆಟ್ಟಿಗೆಯಿಂದ ಒಂದು ಮೀಟರ್ ಒಳಗೆ ಮತ್ತು ಭೂಮಿಯಿಂದ 0.6 - 1.6 ಮೀ ಎತ್ತರದ ಒಳಗೆ ನೆಲ ಮಾರ್ಲಿಯಲ್ಲಿ ಅಳವಡಿಸುವುದು.
23. ಈ ಪತ್ರದಲ್ಲಿ ನಮೂದಿಸಿರುವ ಠೇವಣಿಗಳನ್ನು ಪಾವತಿಸಿದ ನಂತರ, ವೈರಿಂಗ್ ನಕ್ಷೆ, ಗುತ್ತಿಗೆದಾರರ ಸಮಾಪನಾ ವರದಿ ಮತ್ತು ಒಪ್ಪಂದ ಪ್ರತಿಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ಉಪ-ವಿಭಾಗದಲ್ಲಿ ಸಲ್ಲಿಸುವುದು.
24. ಹೆಚ್ಚಿನ ಮಾಹಿತಿಗಾಗಿ ಚಂದಾಪುರ ವಿಭಾಗದ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ವಿ), ಚಿಗಣಿ ಉಪ-ವಿಭಾಗದ, ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್ (ವಿ) ಅವರನ್ನು ಸಂಪರ್ಕಿಸುವುದು.
25. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಸಂದರ್ಭದಲ್ಲಿ **KERC ರವರ clause-9** ರನ್ವಯ ಹಾಗೂ **KERC upto date Amendment** ಗಳನ್ವಯ ಕ್ರಮ ಕೈಗೊಳ್ಳುವುದು.
26. ಭವಿಷ್ಯದಲ್ಲಿ, ಯಾವುದೇ ವ್ಯತ್ಯಾಸದ ಮೊತ್ತವು ಪಾವತಿಸಬೇಕಾದಲ್ಲಿ ಕೊಡಲೇ ಅದನ್ನು ಬೆವಿಕಂ ಗೆ ಪಾವತಿಸಬೇಕು.
27. ಸದರಿ ಗ್ರಾಹಕರು ಅನುಮೋದಿತ ನಕ್ಷೆಯ ಜೊತೆಗೆ ಹೆಚ್ಚುವರಿಯಾಗಿ ಮಹಡಿಗಳನ್ನು ನಿರ್ಮಿಸಿದ್ದರೆ, ಸದರಿ ಸಂಬಂಧವಾಗಿ ಯಾವುದೇ ಹೆಚ್ಚುವರಿ ಮೊತ್ತ/ದಂಡಕ್ಕೆ ಗ್ರಾಹಕರೇ ಜವಾಬ್ದಾರಾಗಿರುತ್ತಾರೆ.
28. The released materials, if any as per **7th schedule credit estimate** shall be handed over to the concerned divisional stores.
29. The materials used shall conform to the **BESCOM Specifications**, **joint inventory** should be submitted after completion of work.
30. Before execution of work the above mentioned License Electrical contractor has to obtain consent letter from the AEE (Ele) of the concerned sub-division for execution of works taking up all the safety measures and the concerned section officer before issuing the **Line Clear** has to confirm the same with the AEE (Ele) of their respective sub-division & contractor.


31. **Precommissioning report from cables from BESCO authorities**, shall be obtained for the newly laid cables under self execution works before connecting to the net work.
32. As per Govt Notification No. KERC/COS/DDD/1/2018-19/908, Bengaluru dated 22.10.2019. In the conditions of supply of distribution licensees in the state of karnataka, 2006 after the existing clause 9.0, the following new clause shall be insertd, namely-
"9A.00-Applicable to Commercial/Residential Buildings (s)/Complex/MS Building (s) in Metropolitan areas/Urban Development Authority Areas of all Cities/City Corporation areas in the state of karnataka where:
a) The requested load is **250KW or More**; or
b) The built-up area of the building is **more than 5,000** Square meters

The Owner/Promoter/Occupier of the above building shall also provide not less than two number of charging points capable of **Charging Electric Vechicles, i.e four/three/two-wheeler with adcquate space in such buildings.**

33. "ನಿಗಮ ಕಛೇರಿಯ ಪತ್ರ ಸಂಖ್ಯೆ: ಮುಪ್ರವ್ಯ(ಕಾ)/ಉಪ್ರವ್ಯ-3/ಬಿಸಿ-05/ಕ-341/25-26/CYS -02 ದಿನಾಂಕ 04-04-2025 ರ ಪ್ರಕಾರ ಎಲ್ಲಾ ಕ್ಷೇತ್ರಾಧಿಕಾರಿಗಳು ಮಾನ್ಯ ಘನ ಸರ್ವೋಚ್ಚ ನ್ಯಾಯಾಲಯದ ಸಿವಿಲ್ ಅಪೀಲ್ ಸಂಖ್ಯೆ: 14604/2024 ಮತ್ತು 14605/2024 ದಿನಾಂಕ: 17.12.2024 ರಲ್ಲಿ ನೀಡಿರುವ ತೀರ್ಪು/ಆದೇಶವನ್ನು ಯಥಾವತ್ತಾಗಿ ಪಾಲಿಸುವುದು".

NOTE:

For any 765/400/220/66/11 KV lines passing adjacent/near by/on the premises, mandatory clearance certificate should be obtained from the competent authority by the developer / concerned EE of BESCO before servicing of the installation. In case of any deviation in this regard concerned officers will be held responsible.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,
P. R. 
ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್(ವಿ),
ಬೆವಿಕಂ, ರಾಮನಗರ ವೃತ್ತ