

Bangalore Electricity Supply Company Ltd.

Page 1 of 3
Format F-09-14

HT Rating Report

9630

Office of the
Executive Engineer (Ele.),
MT Division, BRAZ, BESCO
3rd Floor, Crescent Tower
Bangalore - 560 001.

Date: 14-12-2025



No. EE MT / AEE(O) / BRAZ / AEE HTR / DYHTP5R

To,
The Asst. Executive Engineer (Ele.),
Devana Halli O&M Sub-Division
BESCOM, Devana Halli

Reduction of load
Existing - 490 kVA
Reduction - 290 kVA
Total - 200 kVA

Sir,
Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 14-12-2025
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :
Previously rated on 25-09-2025
R.R. No. DYHTP5R CD 200 KVA. Meter Constant 1000 Activity Godown
Name & Address of the Consumer M/S L&W Constructions Put Ltd
Ambekar Nagar in Devana Halli Sub division
BESCOM.

2. OBSERVATION & ADVICE ON TECHNICAL MATTER :
As per your letter reference NO: AEE / D.H.L / AEE / 25-26 / 3825 Dt: 12/12/2025 Reduction of load sanctioned from 490 kVA to 200 kVA
3. ADVICE ON REVENUE MATTER : Hence existing 25/1A CTI replaced by 10/1A CTI & meter calibrated before & after replacement of CTI error is within permissible limit 2.50

4. DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.
Summary of analysis if rated against complaint Meter data down loaded & analysed recording found correct.

F.R for K-2500 }
I.R for K-1000 } il - 363.503

Yours faithfully,
V. H. Kote
Asst. Executive Engineer (Ele.),
HT Rating Sub Division, HOSA KOTE
BRAZ, BESCO, Bangalore.

Copy for kind information to :
1. The Executive Engineer Ele., MT Division, BRAZ, Bangalore.
2. Executive Engineer Ele, O&M HOSA KOTE Division, BESCO, HOSA KOTE.

In case of discrepancies :
3. Chief Engineer Ele., BRAZ, B'lore.
4. Superintendent of Police, Vigilance
5. Accounts Officer, Internal Audit.