



AEE/ATBL/AE(T)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, JIGANI Sub Division
BESCOM, JIGANI

DHARMA RAJ
NO.42 KNO.22 PROP NO.31/p SHYANUBHOGANAHALLI

Madam

Sub : Arranging power supply to an extent of 3.00 KW in favor of DHARMA RAJ NO.42 KNO.22 PROP NO.31/p SHYANUBHOGANAHALLI in JIGANI OMU, JIGANI

Ref: 1) Your application registration 1324103250515 dated 20-MAR-2025

2) AEE/ATBL/AE(T) a/ 20-MAR-2025

In reference to your application dated 20-MAR-2025. Requesting for arranging power supply to an extent of 3.00 KW power installations in favor of DHARMA RAJ NO.42 KNO.22 PROP NO.31/p SHYANUBHOGANAHALLI in JIGANI OMU, JIGANI Sub division in hereby mentioned subject to the following Conditions.

You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI Sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1324103250515	13241032505150001	LT1-Rural-DOMESTIC LIGHTING & HEATING - LT2A2	3.00 KW	48.1017-48.1017 - ISD	2310
1324103250515	13241032505150002	LT1-Rural-DOMESTIC LIGHTING & HEATING - LT2A2	2.00 KW	48.1017-48.1017 - ISD	1540
1324103250515	13241032505150003	LT1-Rural-DOMESTIC LIGHTING & HEATING - LT2A2	2.00 KW	55.1067-55.1067 - SERVICE LINE CHARGES	2600
1324103250515	13241032505150003	LT1-Rural-DOMESTIC LIGHTING & HEATING - LT2A2	2.00 KW	55.1077-55.1077 - INFRASTRUCTURE CHARGES - NO TAX	40250
1324103250515	13241032505150003	LT1-Rural-DOMESTIC LIGHTING & HEATING - LT2A2	2.00 KW	48.1017-48.1017 - ISD	1540
Total Amount					48240

The power supply will be arranged at 230V.

The Tariff applicable to your installation will be LT1-Rural, or the Tariff in force From time to time.

You have to enter into an agreement with the BESCOM in the prescribed form.

Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

Energy meter should be placed outside the premises at the height of 5ft from the ground level.

Amount through DD should be paid in the name AEE RSD-01 BESCOM JIGANI.

Sanction is valid up to 90 days from the date of issue.

If the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will be CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., JIGANI Sub-division, BESCOM for information and further needful.