



Bangalore Electricity Supply Company Ltd.

Page 1 of 3
Format F-09-14

HT Rating Report

643

Office of the
Executive Engineer (Ele).,
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

No. EE MT/AEE(O)/BRAZ/AEE HTR/

To,
The Asst. Executive Engineer (Ele).,
O&M Sub-Division
BESCOM, 7 Kudur

*Additional g load 250+150: 400kva
Replacement of old 12.5/11 CTS
by new 20/11 CTS & new MC 2000*

Date: 15.03.25

Sir, Ref: AEE/AET/KSD/25-26/610/18.03.25

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 15.03.25
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION : 250+150

Previously rated on 25.11.94

R.R. No. KSD/11.18 CD. 400. KVA.

Meter Constant 1250 to 2000 Activity plywood (11.7A)

Name & Address of the Consumer. Ankit Bansal

Woodscape Industries Private Limited

Marikuppe

Factory: Survey No. 9/2 & 9/3

Marikuppe Village, Solur Hobli,

Maradi Taluk, Ramanagar District-562127

2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

*The installation meter is calibrated before & after C.T. replacement
work on account of additional g load, the meter records in found to be*

3. ADVICE ON REVENUE MATTER : within permissible limits.

NEW MC 2000

4. DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint.

Yours faithfully,

(ಸಯ್ಯಪ್ಪಾಚ್ ಎ.ಎಸ್)

ಸಹಾಯಕ ಕಾರ್ಯ ನಿರ್ವಹಣಾ ಅಧೀಕ್ಷಕರು (ಎ)

Asst. Executive Engineer (Ele.)

HT Rating Sub Division,

BRAZ, BESCOM, Bangalore.

Copy for kind information to :

- The Executive Engineer Ele., MT Division, BRAZ, Bangalore.
- Executive Engineer Ele, O&M Division, BESCOM,

In case of discrepancies :

- Chief Engineer Ele., BRAZ, B'lore.
- Superintendent of Police, Vigilance
- Accounts Officer, Internal Audit.

