

AEE/ATBL/ (AET)

Office of  
Assistant Executive Engineer  
C,O&M, HULIYURDURGA Sub Division  
BESCOM, HULIYURDURGA

To  
HANUMANTHAIHA D R  
BOLENAHALLI SY NO-6/2

Sir/Madam

Sub : Arranging power supply to an extent of **0.00 KVA 10 HP** in favor of HANUMANTHAIHA D R BOLENAHALLI SY NO-6/2 in HULIYURDURGA OMU, HULIYURDURGA

Ref: 1) Your application registration **2243106250012** dated **05-JUN-2025**

2) AEE/ATBL /AE(T) a/ **05-JUN-2025**

With reference to your application dated **05-JUN-2025** . Requesting for arranging power supply to an extent of **0.00 KVA 10 HP** power installations in favor of HANUMANTHAIHA D R BOLENAHALLI SY NO-6/2 in HULIYURDURGA OMU, HULIYURDURGA Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M HULIYURDURGA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
2243106250012	22431062500120001	LT4A(UM)- IRRIGATION PUMPSETS - LT4A	0.00 KVA/10.00HP	61.9047-61.9047 - SC CHARGES(SUPERVISION CHARGES)	250
2243106250012	22431062500120001	LT4A(UM)- IRRIGATION PUMPSETS - LT4A	0.00 KVA/10.00HP	55.1047-55.1047 - IP PENALTY CHARGES	<del>10000</del> 15000
2243106250012	22431062500120001	LT4A(UM)- IRRIGATION PUMPSETS - LT4A	0.00 KVA/10.00HP	61.9067-61.9067 - TP BOX CHARGES	4300
2243106250012	22431062500120001	LT4A(UM)- IRRIGATION PUMPSETS - LT4A	0.00 KVA/10.00HP	47.6037-47.6037 - MSD	2808
2243106250012	22431062500120001	LT4A(UM)- IRRIGATION PUMPSETS - LT4A	0.00 KVA/10.00HP	48.1017-48.1017 - ISD	16600
Total Amount in Rupees					33958

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT4A(UM), or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level

h. Amount through DD should be paid in the name AEE RSD-01 BESCOM HULIYURDURGA .

i. Intimation is valid up to 90 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., HULIYURDURGA Sub division, BESCOM for information and further needful.