

Date: 11/08/25

ದೊಡ್ಡ ಮುನ್ಸೂಚನೆಗೆ 20:
ಮುಖ್ಯ ಆ.ಇ.ಇ: 14/09/2025



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G125

AEE/JIGANI(AET)

Office of the
Assistant Executive Engineer Ele.,
C.O&M, JIGANI Sub Division
BESCOM, JIGANI

To
K SUBHAS CHANDRA MOULESHWARA REDDY
NO 2532/546/38 K NO 546/38 JIGANI VILLAGE JIGANI JIGANI 562106

Sir/Madam

Sub : Arranging power supply to an extent of 34.00 KW in favor of K SUBHAS CHANDRA MOULESHWARA REDDY NO 2532/546/38 K NO 546/38 JIGANI VILLAGE JIGANI JIGANI 562106 in JIGANI OMU, JIGANI

Ref: 1) Your application registration 61324109250048 dated 18-SEP-2025

2) AEE/JIGANI /AE(T) a/ 03-NOV-2025

With reference to your application dated 18-SEP-2025. Requesting for arranging power supply to an extent of 34.00 KW power installations in favor of K SUBHAS CHANDRA MOULESHWARA REDDY NO 2532/546/38 K NO 546/38 JIGANI VILLAGE JIGANI JIGANI 562106 in JIGANI OMU, JIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61324109250048	4941031	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	34.00 KW	61.9047-(WITH TAX) 5% Supervisory Charge(61.904)+CGST(46.9977)9%+SGST(46.9987)9%=(757 + (757*0.09) + (757*0.09))	893
61324109250048	4941031	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	34.00 KW	48.1037-48.1037 - ASD	38680
Total Amount in Rupees					39573

- The power supply will be arranged at 0V.
- The Tariff applicable to your installation will be LT3A-Urban, or the Tariff in force From time to time.
- You have to enter into an agreement with the BESCOM in the prescribed form.
- Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- Amount through DD should be paid in the name AEE BESCOM JIGANI.
- Sanction is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will be CANCELLED. The registration fee paid will be FORFEITED. You are requested to contact the Asst. Ex. Engineer Ele., JIGANI Sub Division, BESCOM for information and further needful.

Sincerely,

Your's Faithfully,

Assistant Engineer (Technical),
JIGANI, BESCOM

Assistant Executive Engineer Ele.,
JIGANI, BESCOM

ಸ್ವೀಕೃತ:- Ref No: ಸರ್ವೋದ್ಯಮ/ಸಂ.ಇಂ(ಎಂ)/ಜಿಗಣಿ/2024-25
ದಿನಾಂಕ: 11/08/25.

ಸೌಕರ್ಯಕರ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ (ಎ) ಸೀಮಿತ
ಎಲೆಕ್ಟ್ರಿಕ್ ಕಾಂಪೌಂಡ್: 14/08/2025 ರಂದು ಸ್ವೀಕೃತವಾಗಿರುತ್ತದೆ.
ಹುಲ್ಲುಮಂಗಳ ಗ್ರಾಮದ ಸ್ವೀಕೃತ ಸಂ: 156 ರ ಸ್ವೀಕೃತ
ವಿಷಯ: ಸೀಮಿತ ಸ್ವೀಕೃತ ವಿದ್ಯುತ್ ಸ್ಥಳೀಕರಣದ ಅನುಮತಿ
ಈ ಅನುಮತಿಯನ್ನು ತಕ್ಷಣವೇ

ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ (ಸಂಪೂರ್ಣ ಕರ್ನಾಟಕ ರಾಜ್ಯ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)	
ಸಂಖ್ಯೆ: ಅಂ(ವಿ)/ರಾವ್/ಕಾಂ(ಕೆ)/ಸಕಾಂ/2025-26/5448-50 ಲಗತ್ತ: Email: sermgc.work@gmail.com Phone No. 080-28488780 BESCOM GST NO: 29AACCB1412G1Z5	ರವರ ಕಛೇರಿ, ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್(ವಿ), ವಾಣಿಜ್ಯ, ಕಾರ್ಯ & ಪಾಲನಾ ರಾಮನಗರ ವೃತ್ತ, ಬೆಂಗಳೂರು, ಟಿಟಿಎಂಸಿ ಕಟ್ಟಡ, ಕೆಂಗೇರಿ, ಬೆಂಗಳೂರು-560060.

To
Sri. K Subhash Chandra Mouleshwara Reddy S/o
Doddappaiah, No. 546/38,
Jigani Village, Jigani Hobli,
Anekal Taluk,
Bangalore Urban District.

4 OCT 2025

ವರದಿ,

ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ

ವಿಷಯ: ನಿಮ್ಮ ಹಾಲಿ ಬಹುಮಹಡಿ ಕಟ್ಟಡಕ್ಕೆ ಅಧಿಕ 24ಕಿ.ವ್ಯಾ (ಹಾಲಿ 28.34 ಕಿ.ವ್ಯಾ + ಅಧಿಕ 24 ಕಿ.ವ್ಯಾ;
ಒಟ್ಟು 52.34 ಕಿ.ವ್ಯಾ) ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ (ವಾಣಿಜ್ಯ) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ
ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: ಕಾನಿಇಂ(ವಿ)/ಚಂದಾ/ಸಕಾನಿಇಂ(ಕೆ)/ಸಇಂ(ತ್ರಾಂ)/2025-26/7112-13 ದಿನಾಂಕ: 09.10.2025 ಚಂದಾಮರ
ವಿಭಾಗ.

Application ID: 61324109250026

ನಿಮ್ಮ ಮನೆಯಲ್ಲಿ ನೀವು ಕೋರಿರುವಂತೆ ಅಧಿಕ 24 ಕಿ.ವ್ಯಾ (ಹಾಲಿ 28.34ಕಿ.ವ್ಯಾ + ಅಧಿಕ 24ಕಿ.ವ್ಯಾ ಒಟ್ಟು 52.34 ಕಿ.ವ್ಯಾ) ವಿದ್ಯುತ್
ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿಯಮ 3.1.5 ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಷರತ್ತುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ
ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿನಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ.

1. ತಾವು ಹಾಲಿ ಕಟ್ಟಿರುವ ಕಟ್ಟಡದ ವಿಸ್ತೀರ್ಣ 717 ಚ.ಮೀ, Ground Floor+ 2 Upper Floor ಇರುತ್ತದೆ. ಹೊಸದಾಗಿ
ನೀವು ಕೋರಿರುವ ಅಧಿಕ ವಿದ್ಯುತ್ ಪ್ರಮಾಣ 24 ಕಿ.ವ್ಯಾ (ವಾಣಿಜ್ಯ)
2. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಹಾಲಿ ಇರುವ F- 01 Jigani Feeder, 66/11KV Jigani Old MUSS ಉಪಸ್ಥಾಪನೆಯಿಂದ
ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
3. ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಟಿ.-3 ಜಂಟಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲಿರುತ್ತದೆ.
4. ಈ ಕೆಳಕಂಡ ರೇವಣಿ/ಬುಲೆಟ್‌ಗಳನ್ನು ಸ.ಕಾನಿ.ಇಂ(ವಿ), ಜಿಗಣಿ ಉಪ-ವಿಭಾಗದಲ್ಲಿ DD ಮೂಲಕ ಪಾವತಿಸುವುದು.
5. ತಮಗೆ ಸರಬರಾಜು ನೀಡಲು ತಗಲುವ ಸ್ವಯಂ ಕಾಮಗಾರಿ ಅಂದಾಜು ಪಟ್ಟಿಯ ವೆಚ್ಚ ರೂ.15,132/-ಆಗಿರುತ್ತದೆ.

Page 1 of 4

Applicant Name: Sri. K Subhash Chandra Mouleshwara Reddy S/o Doddappaiah

Application ID: 61324109250026

Particulars	Amount (in Rs.)	9 % CGST (in Rs.)	9% SGST (in Rs.)	Total Amount in Rs.
2MMD:				
a) 24KW * 01 Nos: Tariff LT-3 (39,360) on Existing RR No. JJC33881 (EX load 10KW +Add Load 24KW = Total Load 34KW)	39,360/-	0	0	39,360/-
2 5% Supervision Charges on (Total Estimate Cost Rs. 15,132/-)	757/-	68/-	68/-	893/-
Total Amount (Forty thousand Two Hundred and Fifty-Three only)				40,253/-

- As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys 141, dt:05.12. 2024.Dry type transformers required to create infrastructure shall be purchase from **BESCOM** approved Vendors only.
- If Dry type LBS/500KVA/CSS/transformer has been installed under self-execution, an undertaking shall be furnished that the same shall be **maintained for life time by the applicant**.
- As per **BESCOM** order No: **BESCOM/CGM(OP)/DGM (OP--1)/FY 2021-2022/CYS-1 Dt:17.05.2021**. The sub divisional officers ensure the **transformer quality** and rating at the authorized test bench/ Divisional stores **duly collecting transformer test certificate** issued by the concerned MT division before servicing of installation.
- As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys 15, dt:19.04.2024. **All dry type transformers procured under Self-execution shall be got tested at the nearest test bench center** and duly collecting transformer test certificate issued by the concerned MT division.
- As per **BESCOM** Circular vide ref:-BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates 15.02.2025 & CYS-102 dated 25-03-2025. **The power supply shall be arranged to the above said installations through "Smart Energy Meter in line with its capacity and quantum of load requirement in BESCOM jurisdiction"**.
- Guanatee** shall be furnished for a period of not less than one year for the materials used in the works as well as for the quality of the work carried out from date taking over of the lines and equipments by **BESCOM**.
- Provide 1 ETV Meter with suitable CTs.
- ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ **Vendors** ಗಳಿಂದ 5 ಸ್ಟಾರ್ ಹೊಂದಿರುವ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಪರಿವರ್ತಕವನ್ನು ಸ್ವಯಂ-ಕಾಮರ್ಷಿಯೋಜನೆಯಡಿಯಲ್ಲಿ ಅನುಮೋದಿಸಿದ ಅಂದಾಜುಪಟ್ಟಿಯ ಪ್ರಕಾರ ಅಳವಡಿಸುವುದು.
- Before commencement of work, **all material shall be inspected from the BESCOM authorities**.
- ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಅಳವಡಿಸುವ ಮುನ್ನ ನಿಯಮಾನುಸಾರ ಸೋಲಾರ್ ವಾಟರ್ ಹೀಟರ್ ಗಳನ್ನು ಕಡ್ಡಾಯವಾಗಿ ಅಳವಡಿಸುವುದು.

Applicant Name: Sri. K Subhash Chandra Mouleshwara Reddy S/o Doddappaiah
Application ID: 61324109250026

ವಿದ್ಯುತ್ ಸಂಪರ್ಕಕ್ಕಾಗಿ ನೀವು ಸಲ್ಲಿಸಿರುವ ಬಿ.ಬಿ.ಎಂ.ಪಿ./ಬಿ.ಎಂ.ಆರ್.ಡಿ.ಎ./ನಗರ ಪಾಲಿಕೆ/ಗ್ರಾಮ ಪಂಚಾಯತಿಯಿಂದ ಅನುಮೋದನೆಗೊಂಡ ಸ್ಥಳ/ಮಾಲೀಕತ್ವದ ದಾಖಲೆಗಳು ಹಾಗೂ ಇತರೆ ದಾಖಲಾತಿಗಳು ಸಕಲ/ಸುಳ್ಳು ಎಂದು ಕಂಡು ಬಂದಲ್ಲಿ ಯಾವುದೇ ಮುನ್ಸೂಚನೆ ನೀಡದೆ ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ಏರ್ಪಡಿಸಿದ್ದ ವಿದ್ಯುತ್ ಸಂಪರ್ಕವನ್ನು ಕಡಿತಗೊಳಿಸಲಾಗುವುದು ಮತ್ತು ನೀವು ಬಿ.ಬಿ.ಕಂ.ಗೆ ಪಾವತಿಸಿರುವ ಠೇವಣಿಗಳನ್ನು ಮುಟ್ಟುಗೋಲು ಹಾಕಿಕೊಳ್ಳಲಾಗುವುದು.

16. ನಿಮ್ಮ ಕಟ್ಟಡದ ಎತ್ತರ 15 ಮೀ ಮತ್ತು ಅದಕ್ಕಿಂತ ಜಾಸ್ತಿ ಇದ್ದರೆ ನಿಯಮಾನುಸಾರ ವಿದ್ಯುತ್ ಪರಿವೀಕ್ಷಕರ ಅನುಮತಿಯನ್ನು ಪಡೆಯಬೇಕು.
17. (a) An electrical room with RCC roof having clear floor area of **5 metres X 4 metres** with a vertical clearance of 2.75 meters with locking facility, exhaust fans and adequate size of cable duct, shall be provided at the ground floor within the Applicant's premises nearer to the main entrance for installing floor mounted distribution transformer and associated switchgear or
(b) A clear space of **3 metres X 5 metres** open to the sky shall be provided within the Applicant's premises preferably at the main entrance for installing structure mounted distribution transformer and switchgear.
18. ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಸರ್ಕ್ಯೂಟ್ ಬ್ರೇಕರ್ ಮತ್ತು ಇ.ಎಲ್.ಸಿ.ಬಿ.ಯನ್ನು ಮಾಪಕ ಪೆಟ್ಟಿಗೆಯಿಂದ ಒಂದು ಮೀಟರ್ ಒಳಗೆ ಮತ್ತು ಭೂಮಿಯಿಂದ 0.6 - 1.6 ಮೀ ಎತ್ತರದ ಒಳಗೆ ನೆಲ ಮೇಲೆಗಿಟ್ಟು ಅಳವಡಿಸುವುದು.
19. ನಿಮ್ಮ ಆವರಣದಲ್ಲಿ ಹಾಲಿ ಸ್ಥಾಪಿಸಿರುವ **1*63ಕೆ.ವಿ.ಎ (Dry Type DTC)** ಪರಿವರ್ತಕದಿಂದ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸಲಾಗುವುದು.
20. ಈ ಪತ್ರದಲ್ಲಿ ನಮೂದಿಸಿರುವ ಠೇವಣಿಗಳನ್ನು ಪಾವತಿಸಿದ ನಂತರ, ವೈರಿಂಗ್ ನಕ್ಷೆ, ಗುತ್ತಿಗೆದಾರರ ಸಮಾಪನಾ ವರದಿ ಮತ್ತು ಒಪ್ಪಂದ ಪ್ರತಿಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ಉಪ-ವಿಭಾಗದಲ್ಲಿ ಸಲ್ಲಿಸುವುದು.
21. ಹೆಚ್ಚಿನ ಮಾಹಿತಿಗಾಗಿ **ಚಂದಾಮರ ವಿಭಾಗದ** ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ವಿ), ಜಿಗಣಿ ಉಪ-ವಿಭಾಗದ, ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್ (ವಿ) ಅವರನ್ನು ಸಂಪರ್ಕಿಸುವುದು.
22. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಸಂದರ್ಭದಲ್ಲಿ **KERC ರವರ clause-9** ರನ್ವಯ ಹಾಗೂ **KERC upto date Amendment** ಗಳನ್ವಯ ಕ್ರಮ ಕೈಗೊಳ್ಳುವುದು.
23. ಭವಿಷ್ಯದಲ್ಲಿ, ಯಾವುದೇ ವ್ಯತ್ಯಾಸದ ಮೊತ್ತವು ಪಾವತಿಸಬೇಕಾದಲ್ಲಿ ಕೊಡಲೇ ಅದನ್ನು ಬೆವಿಕಂ ಗೆ ಪಾವತಿಸಬೇಕು.
24. ಸದರಿ ಗ್ರಾಹಕರು ಅನುಮೋದಿತ ನಕ್ಷೆಯ ಜೊತೆಗೆ ಹೆಚ್ಚುವರಿಯಾಗಿ ಮಹಡಿಗಳನ್ನು ನಿರ್ಮಿಸಿದ್ದರೆ, ಸದರಿ ಸಂಬಂಧವಾಗಿ ಯಾವುದೇ ಹೆಚ್ಚುವರಿ ಮೊತ್ತ/ದಂಡಕ್ಕೆ ಗ್ರಾಹಕರೇ ಜವಾಬ್ದಾರಾಗಿರುತ್ತಾರೆ.
25. The released materials, if any as per **7th schedule credit estimate** shall be handed over to the concerned divisional stores.
26. The materials used shall conform to the **BESCOM Specifications**, joint inventory should be submitted after completion of work.
27. Before execution of work the above mentioned License Electrical contractor has to obtain consent letter from the AEE (Ele) of the concerned sub-division for execution of works taking up all the safety measures and the concerned section officer before issuing the **Line Clear** has to confirm the same with the AEE (Ele) of their respective sub-division & contractor.

Applicant Name: Sri. K Subhash Chandra Mouleshwara Reddy S/o Doddappaiah
Application ID: 61324109250026

Precommissioning report from cables from BESCOM authorities, shall be obtained for the newly laid cables under self execution works before connecting to the net work.

20. As per Govt Notification No. KERC/COS/DDD/1/2018-19/908, Bengaluru dated:-22.10.2019. In the conditions of supply of distribution licensees in the state of karnataka, 2006 after the existing clause 9.0. the following new clause shall be insertd. namely-

***9A.00-Applicable to Commercial/Residential Buildings (s)/Complex/MS Building (s) in Metropolis areas/Urban Development Authority Areas of all Cities/City Corporation areas in the state of karnataka where:**

- a) The requestioned load is **250KW or More; or**
- b) The built-up area of the building is **more than 5,000 Square meters**

The Owner/Promoter/Occupier of the above building shall also provide not less than two number of charging points capable of **Charging Electric Vechicles, i.e four/three/two-wheeler with adequate space in such buildings.**

Note: For any 765/400/220/66/11 KV lines passing adjacent/nearby/on the premises, mandatory clearance certificate should be obtained from the competent authority by the developer / concerned EE of BESCOM before servicing of the installation. In case of any deviation in this regard concerned officers will be held responsible.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,
P. K. Mouleshwara Reddy
ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್(ವಿ),
ಬೆಂಗಳೂರು, ರಾಮನಗರ ವೃತ್ತ