



**Bengaluru Electricity Supply Company Limited**  
(Wholly Owned Government of Karnataka Undertaking)  
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/ATBL/(AET)

Office of the  
Assistant Executive Engineer Ele.,  
C,O&M, JIGANI Sub Division  
BESCOM, JIGANI

To  
VARUN S  
NO.17 & 9 KNO.235/6 S BINGIPURA

Sir/Madam

Sub : Arranging power supply to an extent of **17.00 KW** in favor of VARUN S NO.17 & 9 KNO.235/6 S BINGIPURA in JIGANI OMU, JIGANI

Ref: 1) Your application registration **1324105250028** dated **21-MAY-2025**

2) AEE/ATBL /AE(T) a/ **06-JUN-2025**

With reference to your application dated **21-MAY-2025**. Requesting for arranging power supply to an extent of **17.00 KW** power installations in favor of VARUN S NO.17 & 9 KNO.235/6 S BINGIPURA in JIGANI OMU JIGANI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M JIGANI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1324105250028	13241052500280001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	17.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
1324105250028	13241052500280001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	17.00 KW	61.9047-( WITH TAX ) 5% Supervisory Charge(61.904)+CGST(46.9977)9%+SGST(46.9987)9%=(24065 + (24065*0.09) + (24065*0.09))	28397
1324105250028	13241052500280001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	17.00 KW	48.1017-48.1017 - ISD	27200 + 578 ⇒ 27778
1324105250028	13241052500280002	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	10.00 KW	48.1017-48.1017 - ISD	16000 + 340 ⇒ 16340
Total Amount in Rupees					72597

- The power supply will be arranged at 400V.
- The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.
- You have to enter into an agreement with the BESCOM in the prescribed form.
- Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- Amount through DD should be paid in the name AEE RSD-01 BESCOM JIGANI.
- Intimation is valid up to 90 days from the date of issue.