



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G125

AEE CHANDAPURA (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, CHANDAPURA Sub Division
BESCOM , CHANDAPURA

To
SAVITHA M
KHATA NO-52/5, HEBBAGODI VILLAGE, ANEKAL TALUK, BANGALORE560105

Sir/Madam

Sub : Arranging power supply to an extent of **35.00 KW** in favor of SAVITHA M KHATA NO-52/5, HEBBAGODI VILLAGE, ANEKAL TALUK, BANGALORE560105 in CHANDAPURA OMU, CHANDAPURA

Ref: 1) Your application registration **61322110250036** dated **27-OCT-2025**

2) AEE CHANDAPURA /AE(T) a/ **05-NOV-2025**

With reference to your application dated **27-OCT-2025** . Requesting for arranging power supply to an extent of **35.00 KW** power installations in favor of SAVITHA M KHATA NO-52/5, HEBBAGODI VILLAGE, ANEKAL TALUK, BANGALORE560105 in CHANDAPURA OMU, CHANDAPURA Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M CHANDAPURA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61322110250036	5195844	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	35.00 KW	55.1177-METER COST(55.1177)	3450
61322110250036	5195844	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	35.00 KW	48.1037-48.1037 - ASD	4410
Total Amount in Rupees					7860

- b. The power supply will be arranged at 0V .
- c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE BESCOM CHANDAPURA .
- i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., CHANDAPURA Sub division, BESCOM for information and further needful.

Your's Faithfully,

Assistant Engineer (Technical),
CHANDAPURA, BESCOM

Your's Faithfully,

Assistant Executive Engineer Ele.,
CHANDAPURA, BESCOM

Copy to:



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಸಂಪೂರ್ಣಕರ್ನಾಟಕರಾಜ್ಯ ಸರ್ಕಾರದ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಸಂಖ್ಯೆ: ಅಇಂ(ವಿ)/ರಾವ್ಯ/ಕಾಇಂ(ಕ)/ಸಕಾಇ/2025-26/

ಲಗತ್ತು:

5943 - 44

Email: sermgc.work@gmail.com

Phone No. 080-28488780 / 723

BESCOM GST NO: 29AACCB1412G1Z5

ರವರಕಛೇರಿ,

ಅಧೀಕ್ಷಕಇಂಜಿನಿಯರ್(ವಿ),

ವಾಣಿಜ್ಯ ಕಾರ್ಯ & ಪಾಲಿಸಿ ರಾಮನಗರ

ವೃತ್ತ,

ಬೆವಿಕಂ, ಟಿಟಿಎಂಸಿ ಕಟ್ಟಡ, ಕೆಂಗೇರಿ,

ಬೆಂಗಳೂರು-560060.

To

Smt Savitha M

D/o Ramesh H

Sy. No52/5 Hebbagodi Village

Chandapura Sub-Division

04 NOV 2025

ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ

ಎಫಾನ್ಯರೆ.

ವಿಷಯ: ನಿಮ್ಮ ಹಾಲಿ ಬಹುಮಹಡಿ ಕಟ್ಟಡಕ್ಕೆ ಅಧಿಕ 30KW on CDPHLS46031
Exis:5KW+Addln:30KW Total = 53KW exis +30KW addln =
83KW) ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ (LT-3) ಉದ್ದೇಶಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕಕ್ಕಿರುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ: ಕಾನಿಇಂ(ವಿ)/ಚಂದಾ/ಸಕಾನಿಇಂ(ಕ)/ಸಇಂ(ತಾಂ)/2025-26/7810-11 ದಿ: 30.10.2025
ಚಂದಾಪುರ ವಿಭಾಗ.

Application ID: 61322110250036

ನಿಮ್ಮ ಮನವಿಯಲ್ಲಿ ನೀವು ಕೋರಿರುವಂತೆ ಅಧಿಕ 30KW on CDPHLS46031 Exis:5KW+Addln:30KW Total = 53KW exis +30KW addln = 83KW) ಅಧಿಕ ವಿದ್ಯುತ್ ಭಾರ (LT-3) ವಿದ್ಯುತ್ ಭಾರವನ್ನು ಕೆ.ಇ.ಆರ್.ಸಿ ನಿಯಮ 3.1.5ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಷರತ್ತುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿವಸಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ.

ತಾವು ಹಾಲಿ ಕಟ್ಟಿರುವ ಕಟ್ಟಡದ ವಿಸ್ತೀರ್ಣ 1006.13 ಚ.ಮೀ ಇರುತ್ತದೆ. ಹೊಸದಾಗಿ ನೀವು ಕೋರಿರುವ ಅಧಿಕ ವಿದ್ಯುತ್ ಪ್ರಮಾಣ 30KW (LT-3)

1. ಸದರಿ ಸ್ಥಾವರಕ್ಕೆ ಹಾಲಿ ಇರುವ F-4, 66/11KV Electronic City MUSS ಉಪಸ್ಥಾವರದಿಂದ ವಿದ್ಯುತ್ ಸರಬರಾಜು ಮಾಡಲಾಗುವುದು.
2. ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಟಿ.-1 ಮತ್ತು ಎಲ್.ಟಿ.-3 ಜ಼ಕಾತಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲ್ಪಡುತ್ತದೆ.
3. ತಮಗೆ ಸರಬರಾಜು ನೀಡಲು ತಗಲುವ ಸ್ವಯಂ ಕಾಮಗಾರಿ ಅಂದಾಜು ಪಟ್ಟಿಯ ವೆಚ್ಚ ರೂ. Nil ಆಗಿರುತ್ತದೆ.
4. ಈ ಕೆಳಕಂಡ ಠೇವಣಿ/ಶುಲ್ಕಗಳನ್ನು ಸ.ಕಾ.ನಿ.ಇಂ(ವಿ), ಚಂದಾಪುರ ಉಪ-ವಿಭಾಗದಲ್ಲಿ DD ಮೂಲಕ ಪಾವತಿಸುವುದು.

Sl No	Particulars	Amount (in Rs.)	9 % CGST (in Rs.)	9% SGST (in Rs.)	Amount in Rs.
	2MMD:				
1	a) 30KW *01 Nos: Tariff LT-3 (on existing RR NO CDPHMS46031)	49,020/-	0	0	49,020/-
	Total				49,020/-

5. As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys-141, dt: 05.12. 2024.Dry **type transformers required to create infrastructure shall be purchased from BESCOM approved Vendors only.**
6. If **Dry type LBS/500KVA/CSS/transformer** has been installed under self-execution, an under taking shall be furnished that the same shall be **maintained for life time by the applicant.**
7. As per **BESCOM order No: BESCOM/CGM(OP)/DGM (OP--1)/FY 2021-2022/CYS-19 Dt:17.05.2021.** The sub divisional officers ensure the **transformer quality** and rating at the authorized test bench/ Divisional stores **duly collecting transformer test certificate** issued by the concerned MT division before servicing of installation.
8. As per **BESCOM** Circular No: BESCOM/ GM (QS&s) / DGM-3 /AGM- I /BC-11 / 2024 -25 /Cys-15, dt:19.04.2024. **All dry type transformers procured under Self-execution shall be got tested at the nearest test bench center** and duly collecting transformer test certificate issued by the concerned MT division.
9. As per **BESCOM** Circular vide ref:-BESCOM/CGM(OP)/DGM(OP3)/2024-25/Cys-95 Dates:- 15.02.2025 & CYS-102 dated 25-03-2025, **The power supply shall be arranged to the above said installations through "Smart Energy Meter in line with its capacity and quantum of load requirement in BESCOM jurisdiction".**
10. **Guarantee** shall be furnished for a period of not less than one year for the materials used in the works as well as for the quality of the work carried out from date taking over of the lines and equipment's by **BESCOM.**
11. Provide 01 Nos of ETV Meter with suitable CTs.
12. ಮುಖ್ಯ ಪ್ಯಾನೆಲ್ ಮತ್ತು ವಿತರಣಾ ಪ್ಯಾನೆಲ್‌ಗಳ ನಕ್ಷೆ ಮತ್ತು ವಿನ್ಯಾಸಗಳನ್ನು ಸಂಬಂಧಪಟ್ಟ ನಿಗಮದ ವಿಭಾಗದಿಂದ ಅನುಮೋದನೆ ಪಡೆಯತಕ್ಕದ್ದು ಮತ್ತು ಮಾಸ್ಟರ್ ಮಾಪಕವನ್ನು ಅಳವಡಿಸುವುದು.
13. ನಿಗಮದಿಂದ ಅನುಮೋದಿಸಲ್ಪಟ್ಟ **Vendors** ಗಳಿಂದ 5 ಸ್ಟಾರ್ ಹೊಂದಿರುವ ಸೂಕ್ತ ಸಾಮರ್ಥ್ಯದ ಪರಿವರ್ತಕವನ್ನು ಸ್ವಯಂ-ಕಾಮಗಾರಿ ಯೋಜನೆಯಡಿಯಲ್ಲಿ ಅನುಮೋದಿಸಿದ ಅಂದಾಜು ಪಟ್ಟಿಯ ಪ್ರಕಾರ ಅಳವಡಿಸುವುದು.
14. Before commencement of work, **all material shall be inspected from the BESCOM authorities.**
15. ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಅಳವಡಿಸುವ ಮುನ್ನ ನಿಯಮಾನುಸಾರ ಸೋಲಾರ್ ವಾಟರ್ ಹೀಟರ್ ಗಳನ್ನು ಕಡ್ಡಾಯವಾಗಿ ಅಳವಡಿಸುವುದು.