

Existing 6000KVA Reduction - 1000KVA After Reduction
AKLHT288 Load - 5000KVA

(FOR E.S.Co.Ltd. USE)
HT MC - 25000

* Type of Premises
Total No. of Points/ Motors
Total connected load
Load connected on phase A

6000 KVA
1000 KVA
5000 KVA
B
C

R. R. No. Painted
Slip inserted in Meter
Book No.
Installation No.
Date of servicing
Service
Tapping

Reduction Load

Distribution Transformer :

Location HT Yard
Voltage ratio 11KV/433V
Capacity Te 2000KVA x 4 NOS
Connected Load

Telephone Crossing

NO.

From pole No.

CT'S

Next R. R. No.

Reading date

250/1A

1st

Kalpa

Meter :

Type and make L&T
Capacity 1A
Initial reading 6475.55
16094286

Service Line :

Conductor Cu/IA

AL

Cable WP/VIR/CTS

Pipe

pvc

General :

Meter sealed intact yes
Meter terminal cover sealed yes
Cutout sealed yes
Does Installation comply with wiring Rules? yes
Are any defects noticed? no
Rotation of meter yes
Checked O. K. yes
Meter Card fixed yes

Earthing :

Aerial Fuse

Cutout

Aerial Fuse

Cutout

Service Distance

Test

Phase to Earth

Neutral to Earth

561865
561866
561867

WLB

25 Gmm

25

25

25

Certified that the installation was tested and rated by me

Consumers Signature

State whether residence, Shop, Office, Hotel, Restaurant, Cinema Theatre, Hospital, Educational, Factory (describe), Agricultural Pumping, Other pumping (describe) Cottage Industry

Sanction No.

W. O. No.

AKASH ENTERPRISES

Super Grade Technician Asst. Signature

License No. SGI000378

Bangalore - 560 044

FOR OFFICE USE ONLY

Chief Engineer (Ele)

BRAZ Office, BESCOM

No. 1-4, 1st Floor, 5th Floor

Rajajinagar, Industrial Area.

Bengaluru-560 044

Ledger

Account No.

Installation

Service No.

CHECKED

NO : EE(E)/CDP/AEE(O)/AE(T)/2025-26/ 6054-58

Date :

15 SEP 2025

-: OFFICIAL MEMORANDUM :-

Sub: Reduction of contract demand of the existing HT installation from 6000 KVA to 5000 KVA (reduction 1000 KVA) bearing RR No. AKLHT-288 under HT-2(a) tariff in favour of M/S CIE Automotive India Ltd, Bill Forge Division, Plant-2, No.98-L & M, 2nd Phase, KIADB Industrial Area, Jigani Town, Jigani KIADB O&M of Jigani Sub Division, Anekal Taluk – under self-execution.

- Ref: 1. Online Application Ref No: 61324105250008 / Dated: 06.05.2025.
2. AEE/JGN/AET/2025-26/398/22.05.2025
3. Intimation Letter Ref No: CE(E)/BRAZ/SE(O)/AEE(1)/2025-26/4217-22/13.08.2025
4. Administration approval: CE(E)/BRAZ/SE(O)/AEE(O)-1/2025-26/2825/Dt: 01.07.2025
5. Payment Certificate Letter Ref No: - AEE/JGN/AAO/SA/2025-26/2522 /29.08.2025.
6. Circular No. BESCOM/GM(QS&S)/BC-35/DGM-4/AGM-5/23-24/CYS-186/
Dated:12.02.2024.


With reference to the above, as per the recommendation of Jigani Sub-Division office vide ref letter No(2), approval was accorded by Chief Engineer (E),BRAZ, BESCOM, vide Ref(3) for Reduction of contract demand of the existing HT installation from 6000 KVA to 5000 KVA (reduction 1000 KVA) bearing RR No. AKLHT-288 under HT-2(a) tariff in favour of M/S CIE Automotive India Ltd, Bill Forge Division, Plant-2, No.98-L & M, 2nd Phase, KIADB Industrial Area, Jigani Town, Jigani KIADB O&M of Jigani Sub Division, Anekal Taluk, as per the clause No. 34.01 KERC Conditions of Supply of Electricity of Distribution licensees in the State of Karnataka, subject to the following conditions:

1. The Consumer has to supply the CTs and in presence of AEE, MT division, BRAZ and the MT Staff the existing 11 KV, CTs of ratio 300/ 1A, 0.2S class of accuracy to be replaced by new CTs of ratio 250/1A, 0.2s class of accuracy. The cost of the Sanctioned estimate is Rs. 53,097/- (Total rupees Fifty Three Thousand Ninety Seven only)
2. Metering standards is as per BESCOM circular cited under ref -5.
3. The Consumer has paid the following amounts in favour of AEE, BESCOM, Jigani sub division

Sl No	A/C Head	Amount in Rs	RT No	Date
1	Augmentation Charges	5,00,000-00	1324101022237	
2	supervision charges @ 5 % on estimate cost	2,655-00	1324101022236	26.08.2025
Total Amount Paid		2341-00		

4. The reduction of contract demand is final and it will not be revoked at later date.
5. The reduction of contract demand shall be with effect from the meter reading date following the expiry of, "two months" period from the date of registration of the application for reduction of contract demand / sanctioned load along with fresh agreement for reduced contract demand/ sanctioned load duly making payment of registration cum processing fee as prescribed under clause 30.01 of KERC.
6. The energy entitlement shall be re-fixed on Pro-rata basis (applicable during Power cut period).
7. Signature of the consumer shall be tallied with the signature in the original docket before effecting the Additional Contract Demand as per Norms.
8. The Consumer has to pay arrears and audit short claims, if any, detected at a later date.

9. The Consumer has to give an undertaking that he will abide by the above Conditions / decisions of the appellate authority in respect of pending appeal/ court cases, if any.
10. The installation shall be rated by M.T Staff before & after implementation of reduction of load.
11. The Consumer shall abide by the rules/regulations, if any, left out and regulations issued on subsequent dates.
12. **The capacity of any individual machinery / equipment installed / connected shall not be more than the approved CD.**
13. The security deposit required shall be recalculated for the reduced contract demand on the basis on average monthly bill of the preceding calendar year as per clause 34.04 and balance deposit shall be refunded to the consumer duly observing the KERC/ BESCOM norms.
14. **If SRTPV Load is sanctioned to this Consumer, then the existing PPA has to be withdrawn with immediate effect and Supplementary PPA to be executed as per prevailing KERC / BESCOM Norms.**
- All Other formalities shall be observed as per the prevailing KERC regulations.


**(Dhananjaya C),
Executive Engineer(Ele),
C, O&M Chandapura Division,
BESCOM.**

Copy to:

1. The Executive Engineer Ele, MT, BRAZ, BESCOM, Bangalore for information
2. The Accounts Officer, BESCOM, Chandapura Division for information
3. The Accounts Officer, Internal Audit, BESCOM, Chandapura Division for information
- ✓ 4. The Assistant Executive Engineer Ele, BESCOM, C, O&M **Jigani** Sub Division, for information **along with file.**
5. M/S CIE Automotive India Ltd, Bill Forge Division, Plant-2, No.98-L & M, 2nd Phase, KIA Industrial Area, Jigani Town, Jigani KIADB O&M of Jigani Sub Division, Anekal Taluk.
6. AE(T) / M.F / OC.

Ref Credit Wo No & Date	461/WDV/16.206.7/ S-61509 Dated : 29-08-2025
Ref ACK No & Date	