



# **BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**

Wholly owned Govt. of Karnataka Undertaking

Ref: ABE(VSR/ABCD) 21-22/1490

Asst. Executive Engineer (Ele.)(Com.  
O&M), BESCOM, Veerasandra, 92, Huskur  
Road, Electronic City Phase II, Electronic City,  
Electronic City Phase II, Electronic City,  
Bengaluru, Karnataka 560100  
Date: 02.03.2022

To,

PIYUSH JISWAL DEEPTI MUNDAKK

-GOPASANDRA

Madam/Sir,

**Sub:** Certificate of synchronization of your SRTPV system

**Ref:** Application Reg No. 1000182849 dated 03.01.2022

Synchronization test of Solar Rooftop PV system of 4.9 kWp, installed on the roof of your installation bearing  
RR No.: GPS160 has been conducted and your SRTPV system successfully synchronized with the BESCOM grid at  
230 voltage level on 16.02.2022

Yours Faithfully

sd/-

Assistant Executive  
Engineer(Ele)

Veerasandra Subdivision,  
BESCOM



# Bangalore Electricity Supply Company Limited

(wholly owned Government of Karnataka undertaking)

## Commissioning & Synchronizing report of SRTPV system (Net / Gross metering)

A	Consumer Details			
1	Name of the Consumer	PRIYUSH ISHWAL & DEEPTI MUNDARR		
2	Category	LT 1(A)		
3	RR No./Account ID/Connection ID	GPS160		
4	Pole Number			
B	Meter Details	Bi-directional Meter		Generation meter
		Main Meter	Check Meter	
1	Meter make: 1ph / 3 ph	Genus		L & G
2	Type	Electronic static		Electronic static
3	Serial number	919732		BC 0963 965
4	Capacity	5-30A		5-30A
5	Meter constant	1		1
6	Initial reading (Tri vector parameters)			
	i) Import	4.7 kWh	FR-16577.5 kWh	
	ii) Export	1.0 kWh		

### Note:

1. The Bi-directional meter records solar generation and existing meter records installation consumption in case of Gross metering.

2. The Bi-directional meter records export of solar energy to grid and Import of energy by the installation. Existing meter records the total solar energy generated.

C	Grid Tied Inverter	
1	Make	Emphase Energy
2	Serial number	Attached to file
3	Capacity	349 Watts

4	Input voltage	230 Vdc
5	Output voltage	230 Vac
6	Whether Anti-islanding feature is in working condition	Yes/No
D	PV Module	
1	Make	WARRER
2	Serial number	Attached to file
3	Type of module	Monocr
4	Capacity of each module	440Wp
5	Number of modules	11
6	Total capacity of module	4.84 kW
E	Earthing verified: DC earthing, AC earthing, LA earthing of SRTPV system	Yes/No
F	Details of protective system available	<ul style="list-style-type: none"> <li>AC &amp; DC DB: Yes/No</li> <li>Manual Switch solar side: Yes/No</li> <li>Relay operated automatic switch at net-meter side: Yes/No</li> </ul>
G	AEE, BESCOM inspection & approval letter obtained	Yes/No
H	Work completion report of SRTPV system obtained from agency	Yes/No
I	Date of synchronizing with BESCOM grid	16/02/2022 dd/mm/yyyy

DEEPTI MUNDAKAL BALAN

AEE(Ele.)/EE(Ele.)  
MT S/D/Dvn, -----, BESCOM

AEE(Ele.)/EE(Ele.)  
ಸಹಾಯಕ ಮುಖ್ಯ ಮಂಡಳಿ (ಎ)

Name &  
Signature of Consumer

ವಿರಸಂದ್ರ ಉಪವಿಭಾಗ  
ಎಂ.ವಿ.ಕೆ. ವಿರಸಂದ್ರ  
Assistant Engineer (Ele)  
Muttanallur O & M Unit  
BESCOM, Veerasandra, Sub-Division  
Bangalore - 560099

Piyush Jainwal

Note: All SRTPV formats should be updated in online portal and no offline format shall be processed.





सत्यमेव जयते

INDIA NON JUDICIAL

**Government of Karnataka**

Rs. 200

**e-Stamp**

Certificate No. : IN-KA04749419825748U  
 Certificate Issued Date : 11-Jan-2022 09:59 AM  
 Account Reference : NONACC/ kakscsa08/ THAWAREKERE/ KA-BA  
 Unique Doc. Reference : SUBIN-KAKAKSCSA0852935020004198U  
 Purchased by : PIYUSH JISWAL AND DEEPTI MUNDACK  
 Description of Document : Article 12 Bond  
 Description : SOLAR PPA FOR BESCOM  
 Consideration Price (Rs.) : 0  
 (Zero)  
 First Party : BANGALORE ELECTRICITY SUPPLY COMPANY LTD  
 Second Party : PIYUSH JISWAL AND DEEPTI MUNDACK  
 Stamp Duty Paid By : PIYUSH JISWAL AND DEEPTI MUNDACK  
 Stamp Duty Amount(Rs.) : 200  
 (Two Hundred only)



Please write or type below this line

## STANDARD FORMAT OF POWER PURCHASE AGREEMENT FOR ROOFTOP SOLAR PV PLANTS WITH NET METERING

This Power Purchase agreement is entered into at Bangalore on this 11th Day of January 2022 between Bangalore Electricity Supply Company Limited

(BESCOM), a Government of Karnataka undertaking, being a Company formed and incorporated in India under the Companies Acts-1956, with its registered office located

### Statutory Alert

1. The authenticity of this stamp certificate should be verified by using the stamp verification module app available at the link provided.
2. Any discrepancy in the details on the certificate and available on the stamp verification module app should be reported to the concerned authorities.
3. In case of any discrepancy, please inform the concerned authorities.

at **Asst. Executive Engineer (Ele.,)(Com.O&M), BESCOM, Veerasandra, Bengaluru.** represented by hereinafter referred to as the "BESCOM", (which expression shall, unless repugnant to the context or meaning thereof, include its successors and permitted assigns), as party of the first part **AEE Veerasandra BESCOM Subdivision.**

**AND**

**PIYUSH JISWAL and DEEPTI MUNDAKK** the consumer of BESCOM residing at **#173-174, Vakil Satellite Township, Gopasandra, Bengaluru - 560069** here in after, referred to as the "Seller" (which expression shall, unless repugnant to the context or meaning thereof, include his successors and permitted assigns) as party of the second part.

Whereas,

- a. The Seller intends to connect and operate the Solar Roof Top Photo Voltaic ( SRTPV ) system with BESCOM's HT/LT Distribution system for sale of Solar Power to BESCOM in terms of **"The Karnataka Electricity Regulatory Commission(KERC) Order "Determination of Tariff in respect of Solar Power Projects (including Solar Rooftop Photovoltaic Projects) for FY-22 & 23" dated:18-08-2021** and by reference **"OM No. BESCOM/BC-51/2021-22/CY-21", Dated:03-09-2021.**
- b. The Seller intends to install a SRTPV system of **4.9kWp** capacity on the existing roof top of the premises, situated at **#173-174, Vakil Satellite Township, Gopasandra, Bengaluru - 560069** bearing number **RR No.GPS160** in the same premises, under **Veerasandra Sub- Division** of BESCOM.
- c. The Seller intends to sell the energy, generated from the SRTPV system to BESCOM on net metering basis, from the date of commissioning of the SRTPV system.

**Explanation:** the „Commissioning means the stage at which the SRTPV system starts generating the power for the use by the Seller and injects surplus power if any, into the grid.

- d. BESCOM intends to purchase the energy, generated by such SRTPV system, on Net-metering basis, at the tariff determined by the KERC.

*M*

*Asst. Engr.*

*Deepti*



Now therefore, in consideration of the foregoing premises, the parties, hereto, intending to be legally bound, hereby agree as under:

**1. Technical and Interconnection Requirements:**

Seller shall ensure his SRTPV system complies with the following technical and interconnection requirement and shall:

- 1.1 Comply with the applicable standards and conditions, in respect of integrating the SRTPV system with the distribution system.
- 1.2 Connect and operate the SRTPV system to BESCOM's distribution system, in accordance with the State Grid code, and distribution Code as amended from time to time.
- 1.3 Install prior to connection of SRTPV system to BESCOM's distribution system an inverter with an automatic inbuilt isolation devise.
- 1.4 Provide external manual isolation mechanism with suitable locking facility, so that SRTPV system will not back-feed into the BESCOM's network in case of power outage of the BESCOM's distribution system, and it shall be accessible for BESCOM to operate, if required, during maintenance / emergency conditions.
- 1.5 Install all the equipment of SRTPV system compliant with relevant International (IEEE/IEC) and Indian standards (BIS).
- 1.6 (a) The SRTPV system shall be designed, engineered and constructed and operated by the Seller or any other person on his behalf, with reasonable diligence, subject to all applicable Indian Laws, Rules, Regulations as amended from time to time and orders having the force of law.  
  
(b) The Seller, shall commission the SRTPV system, within six months from the date of approval of the PPA.
- 1.7 Adhere to the following power quality measures, as per the International and Indian standards and/or such other measures stipulated by KERC/BESCOM:



- i) Harmonic current: Harmonic current injections from a generation unit shall not exceed the limits specified in IEEE519.
- ii) Voltage at the injection point should be in the operating range of 80% to 110% of the nominal connected voltage.
- iii) Flicker: Operation of Photovoltaic system shouldn't cause voltage flicker in excess of the limits stated in the relevant sections of IEC standards or other equivalent Indian standards, if any.
- iv) Frequency: When the system frequency exceeds the upper limit, specified in the IEGC as amended from time to time, the SRTPV system shall shift to island mode.
- v) DC Injection: Photovoltaic system should not inject DC power more than 0.5% of full rated output at the interconnection point or 1% of rated inverter output current into distribution system under any operating conditions.
- vi) Power Factor: While the output of the inverter is greater than 50%, a lagging power factor of greater than 0.9 shall be maintained.
- vii) The SRTPV system, in the event of voltage or frequency variations must island/disconnect itself, as per IEGC/KEGC Regulations, within the stipulated period.

## **2. Safety:**

The Seller shall comply with the following safety measures:

- 21 The Seller shall comply with the Central Electricity Authority (Measures Relating to Safety and Electricity Supply) Regulations, 2010.
- 22 The Seller shall ensure that, the design, installation, maintenance and operation of the SRTPV system, are in a manner conducive to the safety of the SRTPV system, as well as the BESCOM's distribution system.
- 23 If the Seller's SRTPV system either, caused amareto and/or produces adverse effects on the other consumers' or BESCOM's assets, Seller will disconnect SRTPV system immediately, from the distribution system, by himself or upon directions from the BESCOM and rectify the same at his own cost before reconnection.



### 3. Clearances and Approvals

The Seller shall obtain BESCOM's and other statutory approvals and clearances before connecting the SRTPV system to the distribution system.

### 4. Access and Disconnection

- 4.1 BESCOM shall have access to metering equipment and disconnecting device of SRTPV system, both automatic and manual, at all times.
- 4.2 In emergency or outage situation, where there is no access to a disconnecting device either, automatic or manual, the BESCOM shall have the right to disconnect power supply to the premises.

### 5. Liabilities

The Seller, shall be solely responsible for availing any fiscal or other incentive provided by the State/ Central government, at his own expenses.

### 6. Commercial Settlement-

#### 6.1 Tariff:

- a. The BESCOM shall pay for the Net energy at **Rs 4.02/- (Four rupees & Two paise only) per kWh as determined by the KERC in the order dated 18.08.2021, for the terms of this agreement. According to the reference "OM No. BESCOM/BC-51/2021-22/CY-21", Dated:03-09-2021.**
- b. If for any reason the date of commissioning is delayed, beyond the date of commissioning agreed. The tariff payable by the BESCOM shall be lower of the:
  - i) Tariff agreed to in this agreement  
OR
  - ii) Any revised tariff, determined by the Commission, prevailing on the date of commissioning  
OR
  - iii) 90% of the tariff agreed to in this agreement.
- c. The Seller shall pay the Electricity tax and other statutory levies, pertaining to SRTPV generation, as may be levied from time to time.

*[Handwritten signature]*

5

*[Handwritten signature]*

*[Handwritten signature]*



- d. The Seller shall not have any claim for compensation, if the Solar power generated by his SRTPV system could not be absorbed by the distribution system due to failure of power supply in the grid/ distribution system for the reasons, such as line clear, load shedding and line faults, whatsoever.

## **7. Metering:**

- 7.1 The Seller, shall arrange to shift the existing meter to the generation side of SRTPV plant to measure solar power generation and install Bi-directional meter (whole current/CT operated) at the point of interconnection to the distribution system, at a suitable place in the premises, accessible for recording export of energy, from the SRTPV system to the grid and import of energy to the premises of the consumer from the grid. The bi-directional meter, shall comply with the Central Electricity Authority (Installation and operation of meters) Regulations, 2006 and shall have the following features:
- i. Separate registers, for recording export and import energy with facility to download by Meter Reading Instrument (MRI).
  - ii. kVA, kW and kVAR measuring registers for both import and export.
  - iii. The Meter shall have RS232 (or higher) communication optical port / Radio Frequency (RF) port to support Automatic Meter Reading (AMR).

## **8. BILLING AND PAYMENT:**

- 8.1 BESCOM shall issue monthly electricity bill for the net energy on the scheduled date of meter reading.
- 8.2 In case, the exported energy is more than the imported energy, BESCOM shall pay for the net energy exported, as per 'Tariff' agreed in this agreement, within 30 days from the date of issue of bill, duly adjusting the fixed charges and electricity duty, if any.
- 8.3 In case, the exported energy is less than the imported energy, the Seller shall pay BESCOM for the Net energy imported as per the prevailing retail supply tariff, determined by the Commission from time to time.
- 8.4 The BESCOM shall pay interest at the same rates, as is being levied on the consumers, for late payment charges, in case of any delay in payment beyond 30 (thirty) days period from the date of issue of bill, for the Net energy exported.
- [Handwritten signatures and initials are present at the bottom of the page.]*

**Explanation:** *Net metered energy means the difference of meter readings of energy injected by the SRTPV system into the grid (export) and the energy drawn from the grid for use by the Seller (import,) recorded in the bi-directional meter.*

## **9. Term and Termination of the Agreement**

- 9.1 This agreement shall be in force for a period of 25 years from the date of commissioning of the SRTPV system, unless terminated otherwise, as provided here under.
- 92 If the BESCOM commits any breach of the terms of the Agreement, Seller shall serve a written notice specifying the breach and calling upon the BESCOM to remedy/ rectify the same, within 30 (thirty) days or at such other period and at the expiry of 30 (Thirty) days or such other period from the delivery of the notice, Seller may terminate the agreement by delivering the termination notice, if the BESCOM fails to remedy/ rectify the same.
- 93 if the Seller commits any breach of the terms of the Agreement, BESCOM shall serve a written notice specifying the breach and calling upon the Seller to remedy/ rectify the same within 30 (thirty) days or at such other period and at the expiry of 30 (Thirty) days or such other period from the delivery of the notice, the BESCOM may terminate the agreement by delivering the termination notice, if the Seller fails to remedy/ rectify the same.
- 94 Upon termination of this Agreement, Seller shall cease to supply power to the distribution system and any injection of power shall not be paid for by the BESCOM.

## **10. Dispute Resolution:**

All the disputes between the parties arising out of or in connection with this agreement shall be first tried to be settled through mutual negotiation.





The parties shall resolve the dispute in good faith and in equitable manner.

In case of failure to resolve the dispute, either of the parties may approach the appropriate Forum.

7

*[Handwritten signatures and marks]*

IN WITNESS WHEREOF, the Seller and the BESCOM have entered into this Agreement executed as of the date and the year first set forth above

<b>For AND ON BEHALF OF Bangalore Electricity Supply Company Limited</b> 	<b>For AND ON BEHALF OF SELLER</b>
By: Designation: Address:	By: <b>PIYUSH JISWAL and DEEPTI MUNDAKK</b> RR No: GPS160  
1. WITNESS  In Presence of Name: Designation: 	1. WITNESS <i>mangn</i> In Presence of Name: <i>mangn A Jaiswal.</i>
2. WITNESS  In Presence of Name: Designation:	2. WITNESS  In Presence of Name: <i>Sagar R.K</i> 