



**Bengaluru Electricity Supply Company Limited**  
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/TAVAREKERE/ (AET)

Office of the  
Assistant Executive Engineer Ele.,  
C,O&M, TAVAREKERE Sub Division  
BESCOM , TAVAREKERE

To  
**SHIVASHANKARAPPA GANJALA**  
NO 04

Sir/Madam

**Sub :** Arranging power supply to an extent of **2.00 KW** in favor of SHIVASHANKARAPPA GANJALA NO 04 in TAVAREKERE OMU, TAVAREKERE

**Ref :** 1) Your application registration **1343102260037** dated **03-FEB-2026**

2) AEE/TAVAREKERE /AE(T) a/ **07-FEB-2026**

With reference to your application dated **03-FEB-2026** . Requesting for arranging power supply to an extent of **2.00 KW** power installations in favor of SHIVASHANKARAPPA GANJALA NO 04 in TAVAREKERE OMU,TAVAREKERE Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M TAVAREKERE sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1343102260037	13431022600370001	LT7-TEMPORARY - LT7	2.00 KW	61.9047-61.9047 - SC CHARGES(SUPERVISION CHARGES)	50
1343102260037	13431022600370001	LT7-TEMPORARY - LT7	2.00 KW	47.3017-PCC	1700
<b>Total Amount in Rupees</b>					<b>1750</b>

b. The power supply will be arranged at 230V .

c. The Tariff applicable to your installation will be LT7, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM TAVAREKERE .

i. Intimation is valid up to 30 days from the date of issue.

**You are requested to purchase the smart meter from the designated meter outlet by paying the necessary charges.**

SI No	Description	Qty	Rate	GST (%)	Amount
1	LT AC Single Phase 2 Wire, 5-30 Amps Smart Energy Meter, Class 1.0 Accuracy with communication Module without Box	1	4067.8000	18 %	4800.0
2	Polycarbonate Box for Single Phase Whole Current Smart Energy Meter	1	167.8000	18 %	198.0

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., TAVAREKERE Sub division, BESCOM for information and further needful.

Your's Faithfully,

Your's Faithfully,

**Assistant Engineer (Technical),  
TAVAREKERE, BESCO**

**Assistant Executive Engineer Ele.,  
TAVAREKERE, BESCO**

Copy to:

- 1.The Executive Engineer Ele. C, O&M MAGADI Division, BESCO.
- 2.The Asst. Executive Engineer Ele., C,O&M TAVAREKERE Sub division, BESCO.