



**Bengaluru Electricity Supply Company Limited**  
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/SARJAPURA OMU/ (AET)

Office of the  
Assistant Executive Engineer Ele.,  
C,O&M, SARJAPURA OMU Sub Division  
BESCOM , SARJAPURA OMU

To  
**INDUS TOWERS LTD**  
NO 932/1033 Near POLICE STATION SARJAPURA 562125.

Sir/Madam

**Sub :** Arranging power supply to an extent of **10.00 KW** in favor of INDUS TOWERS LTD NO 932/1033 Near POLICE STATION SARJAPURA 562125. in SARJAPURA OMU OMU, SARJAPURA OMU

**Ref :** 1) Your application registration **1323202260031** dated **06-FEB-2026**

2) AEE/SARJAPURA OMU /AE(T) a/ **06-FEB-2026**

With reference to your application dated **06-FEB-2026** . Requesting for arranging power supply to an extent of **10.00 KW** power installations in favor of INDUS TOWERS LTD NO 932/1033 Near POLICE STATION SARJAPURA 562125. in SARJAPURA OMU OMU,SARJAPURA OMU Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M SARJAPURA OMU sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1323202260031	13232022600310001	LT3A-Rural- COMMERCIAL POWER & LIGHTING - LT3-RLB	10.00 KW	55.1077-55.1077 - INFRASTRUCTURE CHARGES - NO TAX	10000
1323202260031	13232022600310001	LT3A-Rural- COMMERCIAL POWER & LIGHTING - LT3-RLB	10.00 KW	48.1017-48.1017 - ISD	16000
<b>Total Amount in Rupees</b>					<b>26000</b>

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM SARJAPURA OMU .

i. Intimation is valid up to 30 days from the date of issue.

**You are requested to purchase the smart meter from the designated meter outlet by paying the necessary charges.**

SI No	Description	Qty	Rate	GST (%)	Amount
1	LT AC 3 Phase 4 Wire, 10-60 Amps Smart Energy Meter, Class 1.0 Accuracy with Communication Module without Box	1	7203.3900	18 %	8500.00

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., SARJAPURA OMU Sub division, BESCOM for information and further needful.

Your's Faithfully,

Your's Faithfully,

**Assistant Engineer (Technical),  
SARJAPURA OMU, BESCOM**

**Assistant Executive Engineer Ele.,  
SARJAPURA OMU, BESCOM**

Copy to:

- 1.The Executive Engineer Ele. C, O&M CHANDAPURA Division, BESCOM.
- 2.The Asst. Executive Engineer Ele., C,O&M SARJAPURA OMU Sub division, BESCOM.