



# BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No. EEMT/AEE(O)/BRAZ/AEE HTR/  
To,

The Asst. Executive Engineer (Ele),  
Dabalpet..... O&M Sub-Division.  
BESCOM..... Melamangala.....

**DPHT001**  
Add'n of Load: 50 KVA  
New (O): 200+50 = 250 KVA  
New (CT): 12.5/1A

Office of the  
Executive Engineer (Ele),  
Division, BRAZ, BESCOM,  
3rd Floor, Crescent towers,  
Bangalore-560001.

Sir,

**New MC: 1250**

Date: 18/11/2025

### Subject: Rating Report of HT/EHT Installation.

The H.T. Installation having the following details has been rated for periodical rating/complaint on 18/11/2025. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

#### 1. DETAILS OF H.T. INSTALLATION:

R.R. NO. **DPHT001** CD... **250** KVA CTR... **12.5/1A** Previously rated on **23/05/2025**  
Activity..... Tariff... **H12A** A Meter Constant... **1250**  
Name & Address of the Consumer... **M/S. Kurian Joseph and Alex Myladu 1st Stage**  
**Sompura, F.A.D.B., Indl. Area, Dabalpet.**

#### 2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

The installation of the meter is calibrated before and after the replacement of C.T. and found ok and the meter are recorded with in the permissible limit. Hence the installation may be serviced duly observing corporate norms.

#### 3. ADVICE ON REVENUE MATTER:

Ex. (O): **200 KVA** New (O): **200 + 50 = 250 KVA**  
Ex. (CT): **10/1A** New (CT): **12.5/1A**  
Ex. MC: **1000** New MC: **1250**

#### 4. DOWNLOADED DATA ANALYSIS ENCLOSED - YES/NO.

Summary of analysis if rated against complaint.....

Modem: NSGW701158

### ANNEXURE

#### 1. DETAILS OF SEALS:

R.R. No... **DPHT001**

SL. No.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter				
2	TC Of Meter				
3	M.D. Reset Knob				
4	Optical Port				
5	T.T.B				
6	Meter Chamber Main Door				
7	Meter Reading Window				
8	C.T./P.T. Chamber				
9	Cable Entry Chamber				
10	Hologram				

#### 2. DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make..... Sl. No.....
- b) Cubicle Conditions & Location..... **Good**.....

#### 3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{1124/\sqrt{3}/110/\sqrt{3} \times 12.5/1}{1 \times 1} \times 1 = 1250$$

#### 4. DETAILS OF Ct's/ Pt's:

**one thousand two hundred fifty only.**