


# Bangalore Electricity Supply Company Limited

(Wholly Owned Government of Karnataka Undertaking)

No: EEE/KKP/AEE(O)/AET/25-26/ 5011 Encl:		Office of the Executive Engineer (Ele), C, O&M, Division, Kanakapura BESCOM, Sangama road Kanakapura- 562117. Date:- 18 NOV 2025
E mail: eekkp.work@gmail.com Phone No: +9180-275524111		

**TO,**  
**M/s FUTHURAA**  
**Rep. by L A Satish.,**  
**Plot No:348, 2nd Phase,**  
**KIADB Industrial Area, Harohalli**  
**Harohalli Taluk.**

**SUB: Arranging Power supply to an extent of 150HP LT power supply by conversion of existing HT installation to an LT installation bearing RR.No: KPUHT-92 in favour of M/s FUTHURAA., Rep. by L A Satish., at Plot No:348, 2nd Phase, KIADB Industrial Area Harohalli in Harohalli O&M Section, Harohalli Sub Division Under SELF EXECUTION SCHEME.**

- Ref:** 1) Application No : 1333111250011 Dated: 05.11.2025  
2) Estimate No: AEH-264 Dated: 10.11.2025  
3) AEE/AE(T)/HSD/2025-26/1478 Dated: 12.11.2025 T O Recvd 18.11.2025

\*\*\*\*\*

With reference to the above subject as requested by yourself for Arranging Power supply to an extent of 150HP LT power supply by conversion of existing HT installation to an LT installation bearing RR.No: KPUHT-92 in favour of M/s FUTHURAA., Rep. by L A Satish., at Plot No:348, 2nd Phase, KIADB Industrial Area Harohalli in Harohalli O&M Section, Harohalli Sub Division Under SELF EXECUTION SCHEME.

As per the request of you are here by requested to pay the following charges to BESCOM within **One month (30 days)** at the office of the Assistant Executive Engineer Ele., Harohalli Sub Division, BESCOM for taking further needful action from this office subject to the following conditions.

- 1 Pay the following charges towards,

a)	2MMD Existing ==>	437520 /-	(Not to be Paid)
b)	2MMD for this Load 150 HP LT-5(b) Rs.==>	91440 /-	(Not to be Paid)
c)	2MMD Balance to be paid Rs.==>	0 /-	(Existing 2MMD Deposit is sufficient for this proposed load)
d)	Supervision Charges @ 5% on Est. Cost 1261508/-) Rs.==>	63075 /-	(Sixty Three Thousand and Seventy Five Rs. Only)
e)	Transformer Testing Charges Rs.==>	1000 /-	(One Thousand Rs. Only)
f)	LTMC Testing Charges Rs.==>	4080 /-	(Four Thousand and Eighty Rs. Only)

**Works Proposed under Self Execution:**

- 1) Releasing of existing HT Metering cubicle
  - 2) It is Proposed to erect LBS & 1\*250kVA CABLE ENTRY Type Distribution Transformer at applicant premises.
  - 3) Releasing of existing HT 3ph 4 Wire CT PT operated Static Meter
  - 4) It is proposed to provide LT Metering Cubicle at applicant premises.
- 2 The above amounts shall be paid at HSD, BESCOM Kanakapura within 30 days from the date of this sanction failing which this intimation stands cancelled.
- 3 The charges paid by DD is to be drawn in the favour of Asst. Executive Engineer(Ele), BESCOM, Harohalli Sub division.

- 4 You shall execute the work as per the estimate prepared and sanctioned by BESCOM through class I Electrical Contractor under the supervision of BESCOM officer / official, using materials (as per specifications confirming to relevant IS) approved by BESCOM with the rates applicable at the time of work execution as per statutory norms and as per the guidelines and supervision of Engineer in-charge of works.
- 5 The materials released as shown in credit estimate as per the 7th Schedule shall be returned to BESCOM Store.
- 6 Electrical inspectorate charges /Road cutting charges if any shall be borne by you and approval of GEI (Govt. Electrical Inspector) should be obtained before charging of lines as per IE rules.
- 7 All materials such as Transformer, poles, conductors, cross arms, HG Fuse units, Metering cubicle, HT/LT UG cable, 11kV Pin insulators and 11kV Single/ double break GOS \ etc., shall be procured by the agencies only from the BESCOM approved vendors and other materials may be procured from authorized dealers of approved vendors to BESCOM.
- 8 Shall use the materials conforming to the BESCOM / KPTCL specification, with ISI mark and shall present copies of the invoices/bills as proof having purchased the materials from authorized dealers of approved vendors to BESCOM before executing the works, to the BESCOM for verification.
- 9 The materials has to be brought inspected by competent authority of QS & S/Assistant Executive Engineer of concerned sub division for its quality and specification as approved by BESCOM before commencement of works.
- 10 Guarantee shall be obtained for a period of one year for the materials used in the works as well as for the quality of the work carried out from the date of taking over of the lines by the Licensee. However the applicant shall execute an agreement on Rs. 200/- stamped paper affirming to replace the defective materials at his cost within the guarantee period which will be one year from the date of Energization of the line.
- 11 After completion of the works, the license shall take inventory of work jointly with the developer. If there are any deficiency compared to the sanctioned estimates and defects in the quality of the works same, shall be set right / rectified by the applicant. There after entire line should be taken over by license without payment of any charges. The ownership of the lines and other equipment would there after vest with the license.
- 12 BESCOM is not responsible in whatsoever manner regarding any of legal disputes that may arise during the execution of work, the same may be solved at your end.
- 13 The BESCOM reserves the right for modification / addition / alteration at any stage of the work as the situation warrants.
- 14 You have to pay any variation/difference of charges payable to BESCOM if any, in future and you should abide by the conditions of KERC regulations 2004 in force with subsequent Amendment.
- 15 **As per the Circular No: BESCOM/CGM(Op)/DGM(Op-1)/AGM-3/AE-1/2023-24/CYS-106 Dated:15.12.2023. The Transformer Purchased for Self Execution Work should be Tested at BESCOM Transformer Testing Center before Errection of Transformer at the field & Test Report of the same should be submitted.**
- 16 **As per Circular No: BESCOM/CGM(Op)/DGM(Op-3)/BC-05/K-341/2025-26/CYS-02 Dated:04.04.2025, Applicant has to submit "Occupancy Certificate" (OC) obtained from concerned department before availing service.**

You are requested to contact the Assistant Executive Engineer (Ele) Harohalli Sub Division, BESCOM for information and further needful.

Yours faithfully,



Executive Engineer (Ele.)

C, O&M, BESCOM.,Kanakapura Division