



AEE/AYALA HALL/CFTD

Office of the
Assistant Executive Engineer Ele.,
C,O&M, AVALAHALLI Sub Division
BESCOM, AVALAHALLI

To
M/S C K INFRA EQUIPMENT PRIVATE LIMITED
SY NO 29/5 AT KANNUR VILLAGE

Sir/Madam

Sub : Arranging power supply to an extent of 95.00 KW in favor of M/S C K INFRA EQUIPMENT PRIVATE LIMITED SY NO 29/5 AT KANNUR VILLAGE in AVALAHALLI OMU, AVALAHALLI

Ref: 1) Your application registration 1125106250004 dated 04-JUN-2025

2) AFF/AVALAHALLI /AE(T) a/ 05-JUL-2025

With reference to your application dated 04-JUN-2025 . Requesting for arranging power supply to an extent of 95.00 KW power installations in favor of M S C K INFRA EQUIPMENT PRIVATE LIMITED SY NO 29/5 AT KANNUR VILLAGE in AVALAHALLI OMU, AVALAHALLI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M AVALAHALLI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
1125106250004	11251062500040001	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	95.00 KW	61.9067-LT METERING CUBICAL TESTING CHARGES=CGST(46.997779%+SGST(46.987779%+ (4080 + (4080*0.09) + (4080*0.09))	4080
1125106250004	11251062500040001	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	95.00 KW	61.9067-61.9067-(WITH TAX)TRANSFORMER TESTING FEE=CGST(46.997779%+SGST(46.987779%+(1000 + (1000*0.09) + (1000*0.09))	1000
1125106250004	11251062500040001	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	95.00 KW	61.9047-(WITH TAX) 5% Supervisory Charge(61.904)+CGST(46.997779%+SGST(46.987779%+ (76966 + (76966*0.09) + (76966*0.09))	76966
1125106250004	11251062500040001	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	95.00 KW	48.1017-48.1017- ISD+CGST(46.997779%+SGST(46.987779%+(155230 + (155230*0.09) + (155230*0.09))	155230
Total Amount In Rupees					237276

b. The power supply will be arranged at 400V.

c. The Tariff applicable to your installation will be LT3A-Urban, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install I.T metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM AVALAHALLI.

i. Intimation is valid up to 30 days from the date of issue.

BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED
(Wholly Owned Government of Karnataka Undertaking)

NO : EEE/HKTD/AEE(O)/AE-1/2025-26/ 2665 -
Date: 19/6/25
Encl:

O/o Executive Engineer (Elec),
C, O&M Hoskote Division,
Hosakote-562114.
Email ID- cehosakote@besscom.co.in
☎: 080-27931033 / 9448279024

To,
M/s C.K Infra Equipment Pvt Ltd,
Rep by Mangiing Director, Sri.B.N.Manjunatha,
At Sy.No.29/5, Kannuru Village,
Bagalore East Taluk.

Sir,

Sub: Sanction of power supply to an extent of 95KW Commercial Power for (Ready Mix Concrete Unit) Installation in favour of M/s C.K Infra Equipment Pvt Ltd, Rep by Mangling Director, Sri.B.N.Manjunatha, At Sy.No.29/5, Kannuru Village, Bidrahalli Hobli, Bangalore East Taluk in Doddagubbi O&M unit of Avalahalli Sub-Division."Under Self Execution".

Ref: 1 Your Online Application Registration No.1125106250004 dt:04.06.2025.

Ref: 1.Your Online Application Registration No.:1251082025-26
2. Estimate No. PJK (HP-74) dt:16.06.2025.
3. Ltr. No. AEE/AVL/AE(T)/2025-26/1154 dt:17.06.2025 of AEE Avalahalli .
4. ಸುತ್ತೋಲೆ ಸಂಖ್ಯೆ: ಬಿಹಂ/ಬಿಸಿ-35/ಪ್ರಸಿದ್ಧಿ/ಗೃಹಸ್ಥಾನ/2022-23/ಭವನ-06 ದಿನಾಂಕ:30.4.2022
5. BESCOM/CGM(OP)/DGM-3/AGM-1/AE-1/BC-18/F-533/22-23/Cys-70 dt:26.07.2022

With reference to your application dt:04.06.2025 requesting for Power sanction to an extent of 95KW for above address, we are pleased to convey you sanction of power to an extent of 95KW subject to the following conditions..

1. The power supply will be arranged at 400 Volts.
2. The tariff applicable to your installation will be under LT-3 (I) Tariff in force.
3. You have to enter into an agreement with the Company in the prescribed form as per Electrical supply regulations within 21 days failing which this intimation lapses.
4. Pay Security Deposit (2 MMD) of **Rs.1,55,230/- x 01 No.** (i.e.95KW x 01 No) in cash or DD under Clause 1&3 of Regulation 31.
5. **Energy Meter should be purchased by consumer from retail outlet of BESCOM.**
6. Submit the contractor's completion-cum-test report along with wiring diagram in duplicate.
7. Pay **Rs.6,966/-** towards 5% Supervision charges on estimate cost Under Self Execution.
8. Pay **Rs.6,927/- x 2 Nos** towards 9% CGST + SGST each on 5% Supervision charges.
9. Pay **Rs.1,000/-** towards Transformer Testing fees.
10. Pay **Rs.90/- x 2 Nos** towards 9% CGST + SGST each on Transformer Testing fees.
11. Pay **Rs.4,080/-** towards 9% CGST + SGST each on Meter Cubicle Testing fees.
12. Pay **Rs.368/- x 2 Nos** towards 9% CGST + SGST each on Meter Cubicle Testing fees.
13. You should provide circuit breaker as prescribed by the Corporate BESCOM Which must be erected with in one meter of the Company's meter Board or in its suitable other position as shall be approved by the Corporation as per Regulation 409. No fuses shall be provided on the neutral conductor.
14. The Materials to be procured by the agencies for execution of works on Total Turnkey, Partial Turnkey and Self execution works shall be invariable got inspected by TA&QC / Jurisdictional Executive Engineer (EL), CO&M as the case may be before commencement of Work.
15. All the Major Materials shall be procured by the agencies only from the BESCOM approved vendors and other materials may be procured from authorized dealers of approved vendors of BESCOM.
16. The firms shall submit copies of the invoices / bills in respect of materials purchased by them for this work.
17. Power supply will be arranged to you only after erection of 250 KVA Oil Type Transformer.
18. Transformer installed Under Self execution schemn has to be tested by the concerned MT Section as per circular cited under reference (4).
19. You have to provide metering arrangements for availing load between 50KW to 150KW at low tension as per circular cited under reference (5).
20. Underwriting should be obtained from the Land Owner if the Lessor not paid the arrears of the installation then land owner is responsible to pay any difference or arrears of the installation.
21. This is provisional intimation, In case the above requirement are not complied WITH IN 90 days from the date of this letter, sanction of power as well as registration will STAND CANCELLED and registration fee paid will stand forfeited.

You are requested to contact the Asst. Executive Engineer(Ele), BESCOM, O&M Sub Division Available for further
needful. Yours faithfully,

Yours faithfully

Executive Engineer, E.L. (C.O & M),
BESCOM, Hosakote Division.