



**GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)**



Scan the above QR Code
for verifying the authenticity of the Approval

Ack No : EI000110884838

Date : 14/10/2025

O/o Electrical Inspector,
Bangalore South,
No 53/2, 1st floor, Behind Nijaguna Kshetra, Bull temple
road, Bangalore-566004
Phone No :08026577477

To

SMT AMITA KAPOOR W/O HEMANT KAPOOR
SITE NO. 8, K H NO. 213/206/8,, TRINITY HOME STEAD, SOMPURA VILLAGE,
ANEKAL BNAGALORE, BENGALURU(District), ANEKAL(Taluk)
Karnataka, India - 562125

Sir,

Sub : Approval of Drawing pertaining to the Electrical Installation- of 1x250kVA, 11kV/433 Volts (Oil Type) Self Execution Transformer Centre on HT basis at **SMT AMITA KAPOOR W/O HEMANT KAPOOR SITE NO. 8,, K H NO. 213/206/8,, TRINITY HOME STEAD,, ANEKAL,, BNAGALORE, BANGALORE SOUTH 2(District), BANGALORE SOUTH 2(Taluk) - 562125**

Ref : Bescom intimation letter No.EEE/CDP/AEE(o)/AET-2/16047-48/2025-26, Dt 15.09.2025

Note :
Approved.

Please find here in the drawings duly approved after effecting necessary corrections and with observations noted in **RED INK**. You may take up the work through a Licenced Electrical Contractor as per the approved drawings and after completing the work, submit the connected documents with completion report to the **undersigned** along with the following particulars to arrange for inspection.

This Approval is valid only for a period of **TWENTY FOUR MONTHS** only from the date of approval and extension may be obtained separately for a further period of Twelve Months only as per sub rule (5) Rule 7 of The Karnataka Electrical Inspectorate (Power, Functions and levy of fees) Rules, 2018.

PARTICULARS OF HT/DG:

1. Manufacturers Test Reports of Generator / Transformer / HT / LT breakers etc.,
2. Completion report of Licensed Electrical Contractor for having completed the works as per the approved drawings along with the following details.
 - a) Description of the motor/equipments, indicating serial numbers.
 - b) Rating in HP/KW/KVA
 - c) Feeder details
 - d) Voltage Rating, insulation test results of the equipments.
 - e) Earth Test Results.
 - f) The completion report should be signed by the Licenced Electrical Contractor and the Electrical supervisor along with their valid licence / Permit number and validity date.
3. Oil Test Results of transformer/oil circuit breaker.
4. Insulation test results of transformer/ generator OCB's cable and other connected equipments.
5. Calibration certificates in original of protective devices, CTs, PTs, Energy meters etc., as calibrated by the relay testing and meter testing division of KPTCL and other approved agencies.
6. Earth test results of all the earth electrodes disconnecting all the earth leads from them.



**GOVERNMENT OF KARNATAKA
(Electrical Inspectorate)**



Scan the above QR Code
for verifying the authenticity of the Approval

7. A List of authorized persons qualified to operate at the sub-station/ at the works (list shall be signed by both the employees and employer with permit number and validity date)

Challan/Receipt for having paid **Rs. 17,000 /-** (*IN WORDS*) **Seventeen Thousand only** towards inspection charges under the following Budget Head Non-Plan 0043-00-102-0-01 other taxes and duties on Electricity through E-payment only.

Drawing Scrutiny Fees of Rs. **2,600/-** (*IN WORDS*) **Two Thousand Six Hundred only** paid vide K2 Challan Ref No **EL1025004300003003** dated **08/10/2025** is hereby acknowledged.

Yours faithfully,

**Note: This is a Digitally Signed Certificate
and Does not require manual signature.**

**Please, Verify authenticity of this certificate
by visiting www.ksei.gov.in and entering
certificate number in Third party
verification.**



**Digitally Signed by : YANKANNA
Electrical Inspector
Bangalore South
Signed Date : 14/10/2025**

Copy To : N.S. ELECTRICALS

NO.401/B , 15TH RAMANJANEYA MAIN ROAD , SRINAGAR , SRINAGAR , BANGALORE , BANGALORE WEST ,
560050

License No: 1CL195182BNG - Valid Upto: 31/07/2026