AFF/CHIKKABALLAPURA URBAN/ (AET)

Office of the Assistant Executive Engineer Ele., COSM, CHIKKABALLAPURA URBAN Sub Division HESCOM, CHIKKABALLAPURA URBAN

To SUMMIT DIGITAL INFRASTRUCTURE JATHAVARAVARAHOSAHALLI562101

## Sir/Madam

Sub: Arranging power supply to an extent of 18.00 KW in favor of SUMMIT DIGITAL INFRASTRUCTURE JATHAVARAHOSAHALLI562101 in CHIKKABALLAPURA URBAN OMU, CHIKKABALLAPURA URBAN

Ref: 1) Your application registration 61214104250002 dated 07-APR-2025

2) AEE/CHIKKABALLAPURA URBAN /AE(T) a/ 07-NOV-2025

With reference to your application dated 07-APR-2025. Requesting for arranging power supply to an extent of 18.00 KW power installations in favor of SUMMIT DIGITAL INFRASTRUCTURE JATHAVARAVARAHOSAHALLI562101 in CHIKKABALLAPURA URBAN OMU,CHIKKABALLAPURA URBAN Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M CHIKKABALLAPURA URBAN sub-division and furnish the payment certificate for taking further action in this matter.

| Application No         | Sub Application No | Thriff   | Requested Load | Account Head                              | Amount(Rs.) |
|------------------------|--------------------|--|----------------|---|-------------|
| 61214104250002         | 3760959            | LT3A-Rual-<br>COMMERCIAL POWER<br>& LIGHTING - LT3-RLB |                | 55:1067-55:1067 -<br>SERVICE LINE CHARGES | 97500       |
| 61214104250002         | 3760959            | LT3A-Runl-<br>COMMERCIAL POWER<br>& LIGHTING - LT3-RLB |                | 48.1037-48.1037 - ASD                     | 5610        |
| Total Amount in Rupees |                    |  |                |   | 103110      |

- b. The power supply will be arranged at 0V.
- c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.
- d. You have to enter into an agreement with the BESCOM in the prescribed form.
- e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate,
- f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- h. Amount through DD should be paid in the name AEE BESCOM CHIKKABALLAPURA URBAN .
- i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., CHIKKABALLAPURA URBAN Sub division, BESCOM for information and further needful.

Your's Failthfully,

Your's Failthfully,

Assistant Engineer (Technical), CHIKKABALLAPURA URBAN, BESCOM Assistant Executive Engineer Ele., CHIKKABALLAPURA URBAN, BESCOM