



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

(Wholly owned Government of Karnataka Undertaking)

No. EEMT/AEE(O)/BRAZ/AEE HTR/

DPHT039

To,
The Asst. Executive Engineer (Ele),
O&M Sub-Division,
BESCOM, Melamangala

Add'l of Load

CD: 150+150=300KVA

CTR: 15/1A

MC: 1500

Office of the
Executive Engineer (Ele),
MT Division, BRAZ, BESCOM,
3rd Floor, Crescent towers,
Bangalore-560001.

Date: 23/05/2025

Sir,

Subject: Rating Report of HT/EHT Installation.

The H.T. Installation having the following details has been rated for periodical rating/complaint on 23/05/2025. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION:

R.R. NO. DPHT039, CD: 300, KVA CTR: 15/1A

Previously rated on: 26/02/2025

A Meter Constant: 1500

Activity: Industry, Tariff: HTA

Name & Address of the Consumer: M/s. S.N. Enterprises H46 plot H46 1st stage Sompura, Small Area, Babarpete.

2. OBSERVATION & ADVICE ON TECHNICAL MATTER:

The installation of the meter is calibrated before and after the replacement of C.T. and found ok and the meter was recorded with in the permissible limit.

3. ADVICE ON REVENUE MATTER:

Ex. CD: 150 KVA

Ex. CTR: 7.5/1A

Ex. MC: 750

New CD: 300 KVA

New CTR: 15/1A

New MC: 1500

Meter No: Nseqw704864

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.

Summary of analysis if rated against complaint

ANNEXURE

R.R. No. DPHT039

1. DETAILS OF SEALS:

SL. N O.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter				
2	TC Of Meter				
3	M.D. Reset Knob				
4	Optical Port				
5	T.T.B				
6	Meter Chamber Main Door				
7	Meter Reading Window				
8	C.T./P.T. Chamber				
9	Cable Entry Chamber				
10	Hologram				

2. DETAILS OF THE EQUIPMENTS:

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make..... Sl. No.....
b) Cubicle Conditions & Location..... Good

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva):

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11kV/110V}{1} \times \frac{15/1}{1} \times 1 = 1500$$

4. DETAILS OF Ct's/ Pt's:

One thousand five hundred only.

