

ANNEXURE-II

R.R. No: EHT-New

5. Meter Reading	24006018/2024-April	24006026/2024-April
Meter Sl.no	12:01 Hrs	12:08 Hrs
a. Time	0.0409/0.0269	0.0371/0.0262
b. Present KVA	0.659/0.789	0.690/0.789
c. Present PF		
d. Cumulative Values		0.139/0.169
1.CkVA	0.142/0.169	0.137/0.142
2.CkWh	0.143/0.142	0.073/0.074
3.CkVArh lag	0.077/0.074	0.038/0.049
4.CkVArh lead	0.038/0.045	0.181/0.171
5.CkVAh	0.190/0.171	
e. Billing values		0.109/0.126
1. B kwh	0.114/0.126	0.0000/0.0000
2. B kVA	0.0000/0.0000	0.000/0.000
3. B PF	0.000/0.000	16
4.MD reset count	16	

Meter Reading	Main Meter		Check Meter	
TOD (kWh) Values	1B1: 0.072	1C1: 0.072	1B1: 0.065	1C1: 0.065
	1B2: 0.041	1C2: 0.070	1B2: 0.043	1C2: 0.072
	1B3: 0.000	1C3: 0.000	1B3: 0.000	1C3: 0.000
	1B4: 0.000	1C4: 0.000	1B4: 0.00	1C4: 0.00

**6.Consumer Equipment Details:**

Capacity	Transformer Make	Current	Voltage	Vector Group	SI No.
2X10000 KVA	Unimag Power transformer pvt. ltd	87.5/874.8A	66000/6600V	Dyn11	OVJC 00146/0001 OVJC 00146/0002

*Caluho*  
Asst. Engineer(Ele)  
H.T. Rating Sub-Division  
BESCOM, Tumkur

*[Signature]*  
Asst. Executive Engineer(Ele)  
H.T. Rating Sub-Division  
BESCOM, Tumkur

Consumer/ Representative  
Signature with Seal

Copy for kind information to:

A. The Executive Engineer (Ele), MT division, CTZ, Chithradurga

Copy to:

B. Office copy to A.E.E. (Ele) H.T. Sub-Division, BESCOM, Tumkur.

BESCOM, Tumkur for information.