



Bangalore Electricity Supply Company Ltd.

Page 1 of 3
Format F-09-14

HT Rating Report

2643

Office of the
Executive Engineer (Ele.),
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

No. EE MT / AEE(O) / BRAZ / AEE HTR /

To,

The Asst. Executive Engineer (Ele.),

Attibele O&M Sub-Division

BESCOM, Attibele

Sir,

ATBHT-173

Add load

Ex1 + Add = Total

230 + 270 = 500 kVA / 195 kVA

12.5/1A by 25/1A

1250 to 2500

Date: 7/7/25

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 7/7/25. You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION :

CTR = 12.5/1A by 25/1A

Previously rated on 16/01/2025

R.R. No. ATBHT-173 CD 230+270 = 500 KVA / 195 kVA

Meter Constant 1250 to 2500 Activity HT2(B)

Name & Address of the Consumer.....

Warehouse



2. OBSERVATION & ADVICE ON TECHNICAL MATTER :

The installation both main & check meter are calibrated before & after replacement of CT's on account of additional load, the error recorded found to be within permissible limits.

3. ADVICE ON REVENUE MATTER :

New CD = 500 kVA / 195 kVA

New MC = 2500

4. DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint.....

Yours faithfully,

Hemalatha

Asst. Executive Engineer (Ele.),

HT Rating Sub Division, R/S

BRAZ, BESCOM, Bangalore.

Copy for kind information to :

1. The Executive Engineer Ele., MT Division, BRAZ, Bangalore.

2. Executive Engineer Ele, O&M Chandayana Division, BESCOM, Chandayana

In case of discrepancies :

3. Chief Engineer Ele., BRAZ, B'lore.

4. Superintendent of Police, Vigilance

5. Accounts Officer, Internal Audit.

2-4

ANNEXURE

Page 2 of 3
Format F-09-14

1. DETAILS OF SEALS :

ATBHT- 173 Addl lead 2643

R.R. No.

Sl. No.	Seals Provided to	Sl. No. of Seals Found		Sl. No. of Seals Left	
		Lead	Plastic	Lead	Plastic
1.	M.C. of Meter	BMC31385/ E813961	BMC31386/ G, 812755	} Retained	
2.	TC of Meter	BRA2A71867	BR78201		
3.	M.D. Reset Knob	BRA252647	BRA252649	BRM1423089	BRM1423091
4.	Optical Port				
5.	T.T.B.	BRA2872307	BRA252649	BRM1423090	BRM1423092
6.	Meter Chamber Main Door	BRA2872308	BRA2876726	BRM1423093	
7.	Meter Reading Window				
8.	C.T. / P.T. Chamber	BRA276928		BRM1423094	
9.	Cable Entry Chamber	BRA252653		BRM1423095	
10.					
11.					

2. DETAILS OF THE EQUIPMENTS :

- a) Cubicle Type : Cable Entry / 6 bushing / 3 bushing / LBS. Make..... AS existing Sl. No.
- b) Cubicle Conditions & Location..... Good
- c) Supply side G.O.S. : In Service / Direct / Removed
- d) Lightning Arrestor - Provided / Not Provided

3. DETAILS OF CTs / PTs :

	Existing	After Replacement	Existing	After Replacement
1. Make	Kalpa	Kalpa	Vyoma/Kalpa	
2. Type	WP			
3. Class	0.2	0.25	0.2	
4. Insulation Level	15/38/95	15/38/95	15/38/95	
5. Burden	2.5	2.5	2.5	
6. Ratio Available	12.5/1A	25/1A	11kV/5/110V/V	
7. Ratio Connected	12.5/1A	25/1A	—U—	
8. Sl. No. 1.	3204	8092	VYP-K-1424-Vyoma	
2.	3228/21	8093	75093	} Kalpa
3.	3122	8094	75095	

4. DETAILS OF METERS :

ETV Meter

	main	check
	Existing	After Replacement
a. Make	LUT	LUT
b. Type	WR300BB1/BEDLMS-2	
c. Class	0.25	
d. Voltage	3X63.5	← same →
e. Ampere	1A	
f. Pulse / Unit	50000	
g. Dial Constant	1	
h. Sl. No.	18037271	18037276

5. MULTIPLYING CONSTANT FOR BILLING (Kwh. Kvah. Kva) :

PT Ratio x CT Ratio x Dial Constant

Meter PT Ratio x Meter CT Ratio

$$= 25/1 \times 11kV/\sqrt{3} / 110V/\sqrt{3} = 2500$$

6. A. CALIBRATION DETAILS :

main mtr
CALIBRATOR2643
check
METERa. Voltage V₁, V₂, V₃

63.25, 63.04, 63.33

63.25, 63.04, 63.17

b. Current I₁, I₂, I₃

1.041 1.159 1.076

0.925 1.026 0.990

c. P.F. / KW

0.999 / 0.1998

0.995 / 0.1859

d. Sequence

Rev

Rev

B. CALIBRATION DATA :

KVAH /

KVARH

a. Reading of Test Meter

sandy

sandy

b. Reading of Reference Meter

0.121 %

0.108 %

c. Percent Error

C. VOLTAGE MEASURED at a) RY

YB

BR

b) RG

YG

BG

7. METER READINGS :

A. Cumulative Parameter

a. Time, Date, Month, Year

Existing
7/7/25 @ 14:52After Replacement
7/7/25 @ 15:04

b. Demand with elapsed time

c. Self diagnostic condition

d. Present KVA, PF

e. Cumulative KWH

ckt good
0.2001 / 0.999
2467.83 / 196.24ckt good
0.1872 / 0.995
2467.93 / 196.24

B. BILLING PARAMETERS :

a. Billing KWH

2458.15 / 195.90

2458.24 / 195.90

b. Billing KVA

0.2173 / 0.0957

0.2131 / 0.0950

c. Billing PF (Universal TOD)

1.000 / 0.930

1.000 / 0.930

d. MD Reset Count

91

91

e. MD Reset Manual / Automatic on

Auto

Auto

8. CONSUMER EQUIPMENT DETAILS

a. Transformer Make

b. Voltage Class

c. Capacity

d. Current

e. Vector Group

f. Sl. No.

g. D.G. Set Capacity

Consumer's Representative Signature



[Signature]

Kemalatta
Asst. Executive Engineer (Ele.),

HT Rating Sub Division, *R/S*
BRAZ, BESCOM, Bangalore.

4-4

ATBHT-173

5. MULTIPLYING CONSTANT FOR BILLING (Kwh. Kvah. Kva) :
PT Ratio x CT Ratio x Dial Constant
Meter PT Ratio x Meter CT Ratio = 2500

6. A. CALIBRATION DETAILS :

a. Voltage V₁, V₂, V₃

b. Current I₁, I₂, I₃

c. P.F. / KW

d. Sequence

main mtr
CALIBRATOR

63.07, 62.72, 63.05

0.255 0.263 0.270

0.990 | 0.0491

Rev

2644
check
METER

62.71, 62.38, 62.74

0.249 0.258 0.262

0.984 | 0.0471

Rev

B. CALIBRATION DATA :

KVAH /

KVARH

a. Reading of Test Meter

b. Reading of Reference Meter

c. Percent Error

sandy

0.112%

sandy

0.109%

C. VOLTAGE MEASURED

at a) RY

YB

BR

b) RG

YG

BG

7. METER READINGS :

A. Cumulative Parameter

a. Time, Date, Month, Year

b. Demand with elapsed time

c. Self diagnostic condition

d. Present KVA, PF

e. Cumulative KWH

Existing

7/7/25 @ 17:16

After Replacement

7/7/25 @ 17:28

main mtr.
TOD

ckt good

ckt good

C1 438.82

C2 1046.71

C3 630.53

C4 351.72

0.0495 | 0.990

2467.83 | 196.24

0.0483 | 0.984

2467.93 | 196.24

B. BILLING PARAMETERS :

a. Billing KWH

b. Billing KVA

c. Billing PF (Universal TOD)

d. MD Reset Count

e. MD Reset Manual / Automatic on

B1 438.82

B2 1046.74

B3 630.53

B4 351.72

2467.83 | 196.24

0.1989 | 0.0865

1.000 | 0.914

92

92

manual

2467.93 | 196.24

0.1973 | 0.0948

1.000 | 0.914

92

92

manual

8. CONSUMER EQUIPMENT DETAILS

a. Transformer Make

c. Capacity

e. Vector Group

g. D.G. Set Capacity

check mtr TOD

C1 434.02

C2 1040.02

C3 641.07

C4 352.81

b. Voltage Class

d. Current

f. Sl. No.

B1 434.02

B2 1040.01

B3 641.07

B4 352.81

Hemalatha

Asst. Executive Engineer (Ele.),

HT Rating Sub Division,

BRAZ, BESCOM, Bangalore.

Consumer / Representative Signature

