



MePDCL

MEGHALAYA POWER DISTRIBUTION CORPORATION LIMITED
OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER
INVESTIGATION & ENFORCEMENT SUB-DIVISION, RIBHOI (D) CIRCLE
MePDCL, UMIAM

No. MePDCL /I&E/RBDC/T-07/2024-25/479

Dated Umiam the 6th September, 2024

To,

The Assistant Executive Engineer,
Umiam Urban Distribution Sub-Division
MePDCL, Umiam.

Sub: Installation of new 150/5A CTs at the LT-CT Metering Unit of M/S L.L.Nongrum Saw Cum Veneer Mill, MIDC, Umiam (Consumer ID: 1000198257).

Sir,

With reference to the subject cited above, this is to inform you that the office of the undersigned has on the 27.08.2024 installed new 150/5A CTs (old 50/5A CTs burnt and replaced) at the LT-CT Metering Unit of **M/S L.L.Nongrum Saw Cum Veneer Mill, MIDC, Umiam** (Consumer ID: **1000198257**). The replacement of CTs with higher ratios has been necessitated following the Load Enhancement from 36kW to 92kVA effected to this consumer w.e.f 19.06.2024. The **M.F** of this consumer may please be updated from the existing 10 to **30** w.e.f 27.08.2024 onwards.

Since the meter was found to be physically normal, only CT replacement work was undertaken on the 27.08.2024 and the same meter was installed with reading **1118.00kWh, 1382.40kVAh, 2.82kW**. During the period from 08.08.2024 to 27.08.2024 where the continuity of power consumption has been allowed bypassing the metering unit, section 135 of the Electricity Act. 2003 cannot be applied to this consumer. However, to compensate for the unmetered power consumption during the same period, Additional Unit of **1194.95kVAh** may please be included in the bill cycle of September, 2024.

This is for your kind information and necessary action.

Encl.: CT Replacement & Installation Report.

Yours faithfully,

(Fullmoon L. Kynshi)
Assistant Executive Engineer
I & E Sub-Division, Ribhoi (D) Circle
MePDCL, Umiam

No. MePDCL /I&E/RBDC/T-07/2024-25/479(a)

Dated Umiam the 6th September, 2024

Copy to:-

1. The Superintending Engineer, Ribhoi (D) Circle, MePDCL, Umiam for kind information.
2. The Superintending Engineer, I & E, MePDCL, Shillong for kind information.
3. The Executive Engineer, Umiam Distribution Division, MePDCL, Umiam for kind information.
4. The Executive Engineer, MTI Division, MePDCL, Shillong for kind information.
5. R/F.


Copy: The Senior Engineer (Central Billing Section) for kind information and necessary action and to kindly update the M.F of this consumer as stated and to also include the additional unit above.

ASSISTANT EXECUTIVE ENGINEER

CT REPLACEMENT REPORT AT THE LT-CT METERING UNIT OF M/S L.L.Nongrum Saw Cum Veneer Mill, MIDC, Umiam UNDERTAKEN ON THE 27.08.2024

SL NO	CONSUMER ID.	NAME OF CONSUMER	ADDRESS	CONTRACT DEMAND (KVA)	METER NO.	OLD CT RATIO	NEW CT RATIO	OLD M.F	NEW M.F	CATEGORY	READINGS						Remark
											KWH	KVAH	KVA	V1	V2	V3	
1	1000198257	M/S L.L.Nongrum Saw Cum Veneer Mill	MIDC, Umiam	92	MS5001736	50/5	150/5	10	30	IHT	1118	1382.40	2.82	245	250	243	<u>Old CT (Ratio 50/5 burnt).</u> <u>Replaced with new CT Ratio 150/5A. The replacement of CTs with higher ratios has been necessitated following the Load Enhancement from 36kW to 92kVA effected to this consumer w.e.f 19.06.2024. The M.F of this consumer may please be updated from the existing 10 to 30 w.e.f 27.08.2024 onwards.</u>

Neer Seal :-
TTB : 0051478
MB : 0051471
0051476



 (F.L. KYNISHI)

ASSISTANT EXECUTIVE ENGINEER
 I & E Sub-Division, Ribhoi Distribution Circle
 MePDCL, Umiam

Energy Consumption Statement
Consumer ID/ Account No. 1000198257

Consumer's Name : M/S L.L.Nongrum Saw Cum Veneer Mill

Bill Cycle	Bill Year	Bill Type name	Reading(KWH/KVAH)	Reading Date	Meter Status	Consumption (kWh)	Usage Days	Average Consumption per Day (kWh)
Aug	2024	OK	923.390/1124.690	07-Aug-24	OK (Manual)	3854.85	20	192.742500
Jul	2024	OK	645.890/739.205	18-Jul-24	OK (Manual)	3408.38	34	100.246471
Jun	2024	OK	375.719/398.367	14-Jun-24	OK (Manual)	1581.86	44	35.951364
May	2024	OK	222.644/240.181	01-May-24	OK (Manual)	203.81	35	5.823143
Mar	2024	OK	202.520/219.800	27-Mar-24	OK (Manual)	541	33	16.393939
Feb	2024	OK	150.970/165.700	23-Feb-24	OK (Manual)	759.7	29	26.196552
Average Per Day Consumption (kWh) of Last 6 (six) months (February 2024-August 2024)								62.89
CT Burnt Date								08-08-2024
New CT Installation Date								27-08-2024
Number of days between 08-08-2024 & 27-04-2024								19
Number of units (in kVAh) to be included as additional units ©								1194.95


(F.L. KVNISHI)

ASSISTANT EXECUTIVE ENGINEER
I & E Sub-Division, Ribhoi Distribution Circle
MePDCL,Umiam