



**GOVERNMENT OF KARNATAKA  
(Electrical Inspectorate)**



Scan the above QR Code  
for verifying the authenticity of the Approval

Ack No : EI000110901912

Date : 02/12/2025

GSC No : EN0010000383503

O/o: Deputy Chief Electrical Inspector,  
Bangalore Additional South,  
No. 119, 1st Floor, Munilakshamma Building,  
Arekere Main Road, Arekere, BTS layout  
B G Road, Bengaluru -560 076.  
Phone No :8026484656

To

M/S VISION PROFILES INDUSTRIES REP BY SRI  
NARESH KUMAR JAIN  
SY NO 78/4, SAKALAWARA VILLAGE,, ANEKAL TALUK,  
BANGALORE, BENGALURU(District), ANEKAL(Taluk)  
Karnataka, India-560083

Sir,

Sub : Approval of electrical installation pertaining to 1x800kVA(Oil Type), 11kV/433V HT Transformer Substation at (LT to HT Conversion) **M/S VISION PROFILES INDUSTRIES REP BY SRI NARESH KUMAR JAIN SY NO 78/4,, SAKALAWARA VILLAGE,, JIGANI HOBLI,, ANEKAL TALUK,, BANGALORE, BANGALORE ADDL SOUTH(District), BANGALORE ADDL SOUTH(Taluk) - 560083**

Drawing Ref No : EI000110897911

Ref : 1. Drawing acknowledgement No: EI000110897911 Dated: 14.11.2025  
2. Work Completion Report Letter No: Nil, Dated: 24.11.2025.(EI000110901912)

With reference to the above, approval is hereby granted for energizing the electrical installation at [ **M/S VISION PROFILES INDUSTRIES REP BY SRI NARESH KUMAR JAIN with SY NO 78/4,, SAKALAWARA VILLAGE,, JIGANI HOBLI,, ANEKAL TALUK,, BANGALORE, BANGALORE ADDL SOUTH, BANGALORE ADDL SOUTH - 560083** ] under Regulation No. [ 45 ] of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 as per details enclosed.

This approval is strictly subject to your full compliance with the relevant provisions of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulation, 2023 (as amended to date) in every respect.

Note :

Conditions :

1. As per Regulation No: 48(5) and 48(6) required records shall be maintained.
2. As per Regulation No: 48(7) the installation shall be maintained and operated in a condition free from danger.
3. As per Regulation No: 3 designated person(s) shall operate and carryout the work on electrical lines and apparatus.

Inspection fee of **Rs. 20,600/- (IN WORDS) Twenty Thousand Six Hundred only** paid vide K2 Challan Ref. No: **EL1125004300011889** dated **24/11/2025**

Electrical Installation Approval

1 of 3

  
Deputy Chief Electrical Inspector  
Bangalore Additional South

Bangalore  
Date : 02/12/2025





**GOVERNMENT OF KARNATAKA  
(Electrical Inspectorate)**



Scan the above QR Code  
for verifying the authenticity of the Approval

**Details of Equipments :**

**Details of the Equipments:**

1. HT Cable: a) 11kV Overhead Line(From Tapping point to GOS)(Existing)  
b) 1Rx 3Cx 95Sqmm 11KV XLPE HT UG Cable.(From GOS to HTMC to VCB to Transformer)
2. HT Switchgear: 11KV, 200A GOS with HG Fuse Unit.(Existing)
3. HT Metering Cubicle: Panel Make: SRINGAR SWITCH GEARS, Panel SI No: 103/2025-26.  
a) Current Transformer: Make: KALPA, Ratio: 25/1A, Class: 0.2S, Burden: 2.5VA,  
SI Nos: 1) 19678/25, 2) 19680/25, 3) 19684/25.  
b) Potential Transformer: Make: KALPA, Ratio: 11KV/Rt3/110V/Rt3, Class: 0.2, Burden: 25VA,  
SI Nos: 1) 21373/25, 2) 21379/25, 3) 21383/25.  
c) Energy Meter: Make: L & T, Class: 0.2S, SI No: 25011639.
4. HT Switchgear: VCB, Panel Make: BANAVATHY, Panel SI No: 25096.  
VCB, 12kV, 800A, Make: Crompton Greaves, SI No: 127522VG.
5. Transformer: 1x800KVA(Oil Type), 11kV/433V, 41.99/1066.70A, Make: VIJAY ELECTRIC CO.,  
SI No: VEC/800/L205-10-25.
6. LT Cable: 4Rx 3.5Cx 300 Sqmm LT UG Cable.
7. LT Switchgear: 3P ACB, Make: ABB, 1250Amps.
8. LT Main Panel: 4P ACB, Make: ABB, 2000Amps.

**Subjected to the condition cites below**

1. A separate approval shall be obtained for D.G set and lift installation
2. Any addition or alteration in the existing system shall be got approved from this office as per regulation 45(6) of central electricity authority ( Measures relating to safety and Electric supply) regulation-2023.
3. The approval accorded as per safety provisions of central Electricity Authority ( Measures relating to safety and Electric supply) regulation- 2023. It shall not be considered for any type bill payments. Bill shall be paid after obtaining the joint inventory reports from ESCOM/ concerned Authority after taking the actual measurements, equipment bills etc.
4. Approval is issued subject to Honorable Supreme court judgment of civil Appeal no: 14604/2024 and 14605/2024 Dt: 17-02-2024 and Ltr No: CEIG/ACEI/EI-1,2/14754-892/24-25 Dt: 28.01.2025, Electricity service provider shall service the building after obtaining the completion/occupation certificate.
5. The responsibility of the authenticity of documents submitted by applicant lies with applicant.
6. Separate approval shall be obtained for LT Loads after completion of internal wiring work from this office.

Yours faithfully,



**Digitally Signed by : DODDAMANE SIDDAPPA**  
**Deputy Chief Electrical Inspector**  
**Bangalore Additional South**  
**Signed Date : 02/12/2025**





**GOVERNMENT OF KARNATAKA  
(Electrical Inspectorate)**



Scan the above QR Code  
for verifying the authenticity of the Approval

This is a Digitally Signed Certificate and Does not require manual signature.

Please, Verify authenticity of this certificate by visiting [www.ksel.gov.in](http://www.ksel.gov.in) and entering certificate number in Third party verification.

Copy To : **MENSA POWER CONTROLS**

NO.359/F, 50 feet road, HANUMANTHA NAGAR, 9TH A MAIN, Bangalore, BANGALORE WEST, 560019

License No: 1CL00622BNG Valid Upto: 31/07/2028

