



(Wholly owned Government of Karnataka Undertaking)

No. DDMT/AEE(O)/BRAZ/AEE HTR/UKT 125 261618

The Asst Executive Engineer (Ele),
Mestak, O&M Sub-Division,

Office of the
Executive Engineer (Sec),
MT Division, BRAZ, 35/20000,
3rd Floor, Crescent Towers,
Bangalore-560003.

Ref:- AEE/HKT/AC/11/0520/27812202¹¹/₂₈ Date 06.11.2023

Subject: Rating Report of HT/~~HT~~ Installation

The N.T. Installation having the following details has been rated for periodical ~~inspections~~ inspections on 06.11.85. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

1. DETAILS OF H.T. INSTALLATION:

8 R NO. 154, CD. 1500, KVA CTR. 75/1

Previously rated on

Activity: Washed Tariff (17: 20-1)

Name & Address of the Consumer..... M/s. Vishal Pocco, Main Street, ...

Name & Address of the Contributor
KINDS OFA, Chokkamballi village, Pallegrua, District, Madurai - 625 001

2. OBSERVATION & ADVICE ON TECHNICAL MATTER

OBSERVATION & ADVICE ON TECHNICAL MATTER:
The Commission has conducted after displaying & scrutiny with by 3 and 4
Unidirectional ADT followed for wheeling through over wheel

3. ADVICE ON REVENUE MATTER:

ADVICE ON REVENUE MATTER:
After fixing of S.M. index, the last values are found satisfactory and correct are found within permissible limits. The last values are enclosed for your reference.

4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO. *Yes*

Summary of analysis if rated against complaint... Modern Fixed for And...

NSW 701527

ANNEXURE

R.R. No. HKMT-5L

1. DETAILS OF SEALS:

1. DETAILS OF SEALS:		Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
Sl. N O.	Seals Provided to	Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter			32A1070306	32A1070306
2	TC Of Meter			32A10846483	32A10846483
3	M.D. Reset Knob			32A10846483	32A10846483
4	Optical Port			-	-
5	T.T.B			32A10846483	32A10846483
6	Meter Chamber Main Door			32A10846483	
7	Meter Reading Window			-	
8	C.T./P.T. Chamber			32A10846483	
9	Cable Entry Chamber			32A1073136	
10	Hologram			-	-

2. DETAILS OF THE EQUIPMENTS:

a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make.....

b) Cubicle Conditions & Location.....

3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :

$$\text{MC} = \frac{\text{PT Ratio} \times \text{CT Ratio} \times \text{Dial Constant}}{100}$$

Meter PT Ratio x Meter CT Ratio

4. DETAILS OF Ct's/ Pt's:

$\boxed{7504}$

	Existing	After Replacement	Existing	After Replacement
1. Make				
2. Type				
3. Class				
4. Specification level				
5. Burden				
6. Ratio Connected				
7. S.No.	1.0	R	2.0	R
	0.1	Y		Y
	0.2	D		D

3. DETAILS OF METERS

	Existing	After Replacement
a. Make	Lowly brand, Schneider	Lowly brand, Schneider
b. Type	WR3002HKLH3	WR3002HKLH3
c. Class	0.2S	0.2S
d. Voltage	2x42.5V	2x42.5V
e. Ampere	1A	1A
f. Pulse / Unit	50000	50000
g. Dial Constant	1	1
h. S.No.	25006145	25010853

4. CALIBRATION DETAILS

	Existing	After Replacement
a. Voltage V1, V2, V3	63.40, 63.12, 63.82	63.45, 63.12, 63.82
b. Current I1, I2, I3	0.228, 0.234, 0.216	0.281, 0.233, 0.215
c. P.F. / KW	0.981 / 0.2394	0.986 / 0.2392
d. Sequence	20V	20V
e. % of Error		
f. Reading of Test Meter		
g. Reading of Reference Meter		
h. Percent Error		

5. METER READINGS

	Existing	After Replacement
a. Cumulative Parameters		
b. Demand with elapsed time	16.87	16.30
c. Self-diagnostic condition	0.00	0.00
d. Present KVA, PF	0.017 / 0.986	0.0166 / 0.989
e. Cumulative KWH	0.000	0.000
	TOD 1: 0.000	TOD 1: 0.000
	2: 0.191	2: 0.238
	3: 0.213	3: 0.000
	4: 0.029	4: 0.000
f. Billing Parameters :		
a. Billing KWH	0.434	0.335
	TOD 1: 0.000	TOD 1: 0.000
	2: 0.191	2: 0.238
	3: 0.213	3: 0.000
	4: 0.029	4: 0.000
b. Billing KVA	0.000	0.000
	TOD 1: 0.000	TOD 1: 0.000
	2: 0.000	2: 0.000
	3: 0.000	3: 0.000
	4: 0.000	4: 0.000
c. Billing PF (Universal TOD)	0.000	0.000
	TOD 1: 0.000	TOD 1: 0.000
	2: 0.000	2: 0.000
	3: 0.000	3: 0.000
	4: 0.000	4: 0.000
d. MD Reset Count	8	8
e. MD Reset Manual / Automatic On	Auto on	Auto on

Consumer's / Representative's Signature
With Seal

Asst. Executive Engineer (Ele.)
MT Rating Sub-Division
MT Division, BHAZ, Bangalore