



9-26
 22

NO: EE(E)/CDP/AEE(O)/AE(T)/2025-26/ 7366-69

Date :

AEE(T)
BT 23/10/25

5 OCT 2025

:- OFFICIAL MEMORANDUM :-

Sub: Reduction of contract demand of the existing HT installation from 320 KVA to 150 KVA (reduction 170 KVA) bearing RR No. JGNHT-965 under HT-2(a) tariff in favour of M/S Euro School Foundation, Sy.No.23/3, Lakshmipura village, Bannerughatta O&M of Jigani Sub Division, Anekal Taluk -- under self-execution.

- Ref:**
1. Online Application Ref No: 61324108250013 / Dated: 07.08.2025.
 2. AEE/JGN/AET/2025-26/2671/09.09.2025
 3. Intimation Letter Ref No: EEE/CDP/AEE(O)/AE(T)/2025-26/6966-67/Dt-04.10.2025.
 4. Payment Certificate Letter Ref No: - AEE/JGN/AAO/SA/2025-26/3578/08.10.2025.
 5. Circular No. BESCOM/GM(QS&S)/BC-35/DGM-4/AGM-5/23-24/CYS-186/
 Dated:12.02.2024.


with reference to the above, as per the recommendation of Jigani Sub-Division office vide ref letter No(2), approval was accorded by Executive Engineer (E),BESCOM, Chandapura Division vide Ref(3) for Reduction of contract demand of the existing HT installation from 320 KVA to 150 KVA (reduction 170 KVA) bearing RR No. JGNHT-965 under HT-2(a) tariff in favour of M/S Euro School Foundation, Sy.No.23/3, Lakshmipura village, Bannerughatta O&M of Jigani Sub Division, Anekal Taluk, as per the clause No. 34.01 KERC Conditions of Supply of Electricity of Distribution licensees in the State of Karnataka, subject to the following conditions:

1. The Consumer has to supply the CTs and in presence of AEE, MT division, BRAZ and the MT Staff the existing 11 KV, CTs of ratio 20/ 1A, 0.2S class of accuracy to be replaced by new CTs of ratio 7.5/1A, 0.2s class of accuracy. The cost of the Sanctioned estimate is Rs. 45,356/- (Total rupees Forty Five Thousand Three Hundred Fifty Six only)
2. Metering standards is as per BESCOM circular cited under ref -5.
3. The Consumer has paid the following amounts in favour of AEE, BESCOM, Jigani sub division

Sl No	A/C Head	Amount in Rs	RT No	Date
1	supervision charges @ 5 % on estimate cost	2,268-00	1324101030845	
2	CGST @ 9%	204-00	1324101030845	06.10.2025
3	SGST @ 9%	204-00	1324101030845	
Total Amount Paid		2,676-00		

4. The reduction of contract demand is final and it will not be revoked at later date.
5. The reduction of contract demand shall be with effect from the meter reading date following the expiry of, "two months" period from the date of registration of the application for reduction of contract demand / sanctioned load along with fresh agreement for reduced contract demand/ sanctioned load duly making payment of registration cum processing fee as prescribed under clause 30.01 of KERC.
6. The energy entitlement shall be re-fixed on Pro-rata basis (applicable during Power cut period).
7. Signature of the consumer shall be tallied with the signature in the original docket before affecting the Additional Contract Demand as per Norms.
8. The Consumer has to pay arrears and audit short claims, if any, detected at a later date.

9. The Consumer has to give an undertaking that he will abide by the above Conditions / clauses of the appellate authority in respect of pending appeal/ court cases, if any.
 10. The installation shall be rated by M.T Staff before & after implementation of reduction of load.
 11. The Consumer shall abide by the rules/regulations, if any, left out and regulations issued on various dates.
 12. **The capacity of any individual machinery / equipment installed / connected shall not be more than the approved CD.**
 13. The security deposit required shall be recalculated for the reduced contract demand on Pro-rata basis on average monthly bill of the preceding calendar year as per clause 34.04 and balance **deposit shall be refunded to the consumer duly observing the KERC/ BESCO norms.**
 14. **If SRTPV Load is sanctioned to this Consumer, then the existing PPA has to be withdrawn with immediate effect and Supplementary PPA to be executed as per prevailing KERC / BESCO norms.**
- All Other formalities shall be observed as per the prevailing KERC regulations.


**(Dhananjaya C),
Executive Engineer(Ele),
C, O&M Chandapura Division,
BESCOM.**

Copy to:

1. The Executive Engineer Ele, MT, BRAZ, BESCOM, Bangalore for information
2. The Accounts Officer, BESCOM, Chandapura Division for information
3. The Accounts Officer, Internal Audit, BESCOM, Chandapura Division for information
4. The Assistant Executive Engineer Ele, BESCOM, C, O&M **Jigani** Sub Division, for information **along with file.**
5. M/S Euro School Foundation, Sy.No.23/3, Lakshmipura village, Bannerughatta O&M Jigani Sub Division, Anekal Taluk.
6. AE(T) / M.F / OC.

Ref Credit Wo No & Date	461/WDV/16.206.7/ S-65303 Dated : 09.10.2025
Ref ACK No & Date	



HT Rating Report

2921



No. EE MT/AEE(O) / BRAZ / AEE HTR /

Office of the
Executive Engineer (Ele.),
MT Division, BRAZ, BESCOM
3rd Floor, Crescent Tower
Bangalore - 560 001.

To,
The Asst. Executive Engineer (Ele.),
Jigani, O&M Sub-Division
BESCOM, Jigani

JG NHT - 965
Reduction of load
Exi - R/L = balance
320 - 170 = 150 kVA
20/1 by 7.5/1A
2000 to 750

Date 23/10/25

Subject : Rating Report of HT / EHT Installation

The H.T. Installation having the following details has been rated for periodical rating / complaint on 23/10/25.
You are requested to take action on the observations and advices recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

DETAILS OF H.T. INSTALLATION :

Previously rated on 5/4/25

R.R. No. JG NHT-965 CD. 320-170 KVA. Meter Constant 2000 to 750 Activity H72(C)

Name & Address of the Consumer = 150
Euro School Bannerghatta
Survey No. 93/3 Lakshmipura Village,
Jigani Hobli, Anekal Taluk,
Bangalore-560 083.
Ph: 9846472003, 9846473822
Email: info@euroschoolindia.com

OBSERVATION & ADVICE ON TECHNICAL MATTER :

The installation meter is calibrated before and after replacement of CT's, the error recorded found to be within permissible limits.

ADVICE ON REVENUE MATTER :

New CD = 150 kVA
New MC = 750

DOWNLOADED TATA ANALYSIS ENCLOSED : YES / NO.

Summary of analysis if rated against complaint.

Yours faithfully,

Demalath

Asst. Executive Engineer (Ele.),

HT Rating Sub Division, e/s

BRAZ, BESCOM, Bangalore.

Copy for kind information to :

The Executive Engineer Ele., MT Division, BRAZ, Bangalore.

Executive Engineer Ele, O&M Chandapura Division, BESCOM, Chandapura

Case of discrepancies :

Chief Engineer Ele., BRAZ, B'lore.

Superintendent of Police, Vigilance

Accounts Officer, Internal Audit.