



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/NELAMANGALA/AE(T)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, NELAMANGALA Sub Division
BESCOM, NELAMANGALA

To
N.B.SHADAKSHARI
VINAYAKANAGARA0

a/Madam

Sub : Arranging power supply to an extent of 20.00 KW in favor of N.B.SHADAKSHARI VINAYAKANAGARA0 in NELAMANGALA OMU, NELAMANGALA

Ref: 1) Your application registration 61112107250003 dated 02-JUL-2025

2) AEE/NELAMANGALA /AE(T) a/ 08-JUL-2025

With reference to your application dated 02-JUL-2025 . Requesting for arranging power supply to an extent of 20.00 KW power installations in favor of N.B.SHADAKSHARI VINAYAKANAGARA0 in NELAMANGALA OMU, NELAMANGALA Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C. O&M NELAMANGALA sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61112107250003	4351839	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	20.00 KW	61.9047-61.9047 - SC CHARGES(SUPERVISION CHARGES)+CGST(46.9977)9%+SGST(46.9987)9%=(150 + (150*0.09) + (150*0.09))	150
61112107250003	4351839	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	20.00 KW	55.1067-55.1067 - SERVICE LINE CHARGES+CGST(46.9977)9%+SGST(46.9987)9%=(14300 + (14300*0.09) + (14300*0.09))	14300
61112107250003	4351839	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	20.00 KW	55.1077-55.1077 - INFRASTRUCTURE CHARGES- NO TAX+CGST(46.9977)9%+SGST(46.9987)9%=(1300000 + (1300000*0.09) + (1300000*0.09))	1300000
Total Amount in Rupees					1314450

b. The power supply will be arranged at 0V .

c. The Tariff applicable to your installation will be LT3A-Urban, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM NELAMANGALA .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FORFEITED. You are requested to contact the Asst. Ex. Engineer Ele., NELAMANGALA Sub division, BESCOM for information and further needful.

