



ಬೆಂಗಳೂರು ವಿದ್ಯುತ್ ಸರಬರಾಜು ಕಂಪನಿ ನಿಯಮಿತ

(ಕರ್ನಾಟಕ ಸರ್ಕಾರದ ಸಂಪೂರ್ಣ ಸ್ವಾಮ್ಯಕ್ಕೆ ಒಳಪಟ್ಟಿದೆ)

ಸಂಖ್ಯೆ: ಅಇಂ(ವಿ)/ಬೆಂಗಳೂರು/ಕಾನಿಇಂ/ಸರ್ಕಾಂ/F-1/2025-26/

Ph No. 080-28482437 / 94482 79007

Email ID: sebrco@bescom.co.in

3356-57

ಅಧೀಕ್ಷಕ ಇಂಜಿನಿಯರ್ (ವಿ), ರವರ ಕಛೇರಿ,
ಬೆಂಗಳೂರು ಗ್ರಾಮೀಣ ವೃತ್ತ, ಬೀದಿ ಭವನ,
5ನೇ ಮಹಡಿ, ಬಳ್ಳಾರಿ ರಸ್ತೆ, ಹೆಬ್ಬಾಳ,
ಬೆಂಗಳೂರು -560024

ದಿನಾಂಕ: 08 SEP 2025

(Handwritten signature)

ಗೆ,

Sri. M.Venkategowda S/o Munegowda,
Sy No. 63/5, Doddagubbi Village, Bidarahalli Hobli,
Bangalore East Taluk.

(Under Self-Execution 3.1.5) (Existing building without additional plinth area)
(Application ID: 61125105250021 / RR No. 3AVC68721) (Existing Building Commercial Installation)
(Enhancing existing 1x25 KVA by 1x250 KVA Cable Entry Type Distribution Transformer)

ಮಾನ್ಯರೇ,

ವಿಷಯ: ಮೇಲ್ಕಂಡ ವಿಳಾಸದಲ್ಲಿರುವ ನಿಮ್ಮ ಹಾಲಿ ಇರುವ ಕಟ್ಟಡದ ಒಂದು ಸ್ಥಾವರ ಸಂಖ್ಯೆ 3AVC68721ಗೆ ವಾಣಿಜ್ಯ ಉದ್ದೇಶಕ್ಕೆ ಹೆಚ್ಚುವರಿ 88 ಕಿ.ವ್ಯಾ + ಹಾಲಿ 12 ಕಿ.ವ್ಯಾ = ಒಟ್ಟಾರೆ 100 ಕಿ.ವ್ಯಾ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಕಲ್ಪಿಸುವ ಬಗ್ಗೆ.

- ಉಲ್ಲೇಖ:**
- As per Clause 3.1.5 of KERC 7th Amendment & 12th Amendment.
 - CGM(OP)/DGM(OP-3)/AGM-1(OP-3)/F-341/2024-25/CYS-25 Dated: 20.05.2024
 - Existing RR No 3AVC68721 Date of Service 11.03.2025.
 - GM, GST Circular Ltr No. BESCOM/BC-49/GM(CT&GST)/DGM/AGM(CT&GST)/F-3/2024-25/CYS-48 Dated: 26.11.2024.
 - ಸುತ್ತೋಲೆ: ಮುಪ್ರವ್ಯ(ಕಾ)/ಉಪ್ರವ್ಯ-3/ಬಿಸಿ-05/ಕ-341/25-26/ಸಿ.ವೈ.ಎಸ್-02 ದಿನಾಂಕ: 04.04.2025.
 - Executive Engineer (Ele), HKTD Ltr No. EEE/HKTD/AEE(O)/AE-1/2025-26/5398 Dated: 06.09.2025.
 - T.O Note approved Dated: 08.09.2025.

ನಿಮ್ಮ ಮನವಿಯಲ್ಲಿ ನೀಡಿದ ಕೋರಿರುವಂತೆ ನಿಮ್ಮ ಹಾಲಿ ಇರುವ ಕಟ್ಟಡದ ಒಂದು ಸ್ಥಾವರ ಸಂಖ್ಯೆ 3AVC68721ಗೆ ವಾಣಿಜ್ಯ ಉದ್ದೇಶಕ್ಕೆ ಹೆಚ್ಚುವರಿ 88 ಕಿ.ವ್ಯಾ + ಹಾಲಿ 12 ಕಿ.ವ್ಯಾ = ಒಟ್ಟಾರೆ 100 ಕಿ.ವ್ಯಾ ಕೆ.ಇ.ಆರ್.ಸಿ. ನಿಯಮ 3.1.5ರ ಪ್ರಕಾರ ಈ ಕೆಳಗೆ ಸೂಚಿಸಿರುವ ಪರತ್ತುಗಳ ಮೇರೆಗೆ ಮಂಜೂರು ಮಾಡಲಾಗಿದೆ ಹಾಗೂ ಮಂಜೂರಾತಿಯು ಈ ದಿನಾಂಕದಿಂದ 90 ದಿವಸಗಳವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ.

- The 11 kV line of F-10 Hosakote Feeder which is feeding from 66/11 kV Geddalahalli MUSS.
- The existing Building having 01 No of connection bearing RR No. 3AVC68721 with sanction load of 12 KW + Additional load of 88 KW = Total 100 KW under LT-3(a).
- ಹಾಲಿ ಕಟ್ಟಡದ ವಿಸ್ತೀರ್ಣ 7200 ಚ.ಅಡಿ (668.88 ಚ.ಮೀ) ಹಾಗೂ ನಿಮ್ಮ ನಿವೇಶನದ ವಿಸ್ತೀರ್ಣ 20778 ಚ.ಅಡಿ (1930.35 ಚ.ಮೀ) ಮತ್ತು ನಿಮ್ಮ ಹಾಲಿ ಇರುವ ಕಟ್ಟಡವು 01 ಅಂತಸ್ತುಗಳು ಇರುತ್ತದೆ.
- ಹಾಲಿ ಚಾಲ್ತಿಯಲ್ಲಿರುವ ಎಲ್.ಟಿ.-3(a) ಜಠಾತಿಯು ನಿಮ್ಮ ಸ್ಥಾವರಕ್ಕೆ ಅನ್ವಯಿಸಲಿರುತ್ತದೆ.
- ಕೆಳಕಂಡ ಠೇವಣಿಗಳನ್ನು ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್(ವಿ), ಆವರಣಕ್ಕೆ ಉಪವಿಭಾಗ ರವರ ಕಛೇರಿಯಲ್ಲಿ ಪಾವತಿ ಮಾಡುವುದು.

Sl No	Account ID	RR No	Tariff	Existing Load	Add Load	Total Load	2MMD Amount	Existing Deposit	To be collect
1	61125105250021	3AVC68721	LT-3(a)	12 KW	88 KW	100 KW	Rs. 1,63,400/-	Rs. 22,552/-	Rs. 1,40,848/-
Rupees One Lakh Forty Thousand Eight Hundred & Forty Eight Only									
2	5% Supervision Charges								Rs. 68,574/-
3	LBS onsite Testing Fee								Rs. 4,080/-
4	Transformer Testing Fee								Rs. 1,000/-

- The work shall be completed within 90 Days from the date of self-Execution approval from division.
- Before execution of work the above mentioned License Electrical contractor has to obtain consent letter from the AEE (Ele) of the concerned sub-division for execution of works taking up all the safety measures and the concerned section officer before issuing the Line Clear has to confirm the same with the AEE (Ele) of their respective sub-division & contractor.
- As per reference-5, the Metering arrangements for consumer availing load between 50 KW to 150 KW at low tension shall be as follows:
 - 01 No of CT & PT operated 0.2s accuracy class meter with provision for check meter.
 - 03 Nos of LT CT's of 0.2s accuracy class with burden of 2.5 VA and secondary current 1A.
 - 03 Nos of LT PT's of 0.2 accuracy class with burden of 5 VA and ration 440/3/110/3 volts.
 - 01 No. 9f Modem
 - 02 No of test terminal Block and suitable bus bar.
- ಸ್ವಯಂ ಕಾಮಗಾರಿ ಅಂದಾಜು ಪಟ್ಟಿಯ ವೆಚ್ಚ ರೂ. 13,71,480/- ಆಗಿರುತ್ತದೆ.
- ನಿಮ್ಮ ಕಟ್ಟಡಕ್ಕೆ ವಿದ್ಯುತ್ ಸಂಪರ್ಕ ಏರ್ಪಡಿಸುವ ಮುನ್ನ ಕ.ವಿ.ವಿ ಆಯೋಗದ ನಿರ್ಧಾರಗಳು ಮತ್ತು ಬೆವಿಕು ನ ಕಾನೂನು ರೀತಿ ಬೇಕಾಗಿರುವ ಸೂಕ್ತ ದಾಖಲೆಗಳನ್ನು ಸಲ್ಲಿಸುವುದು.
- ಎಲ್ಲಾ ಕ್ಷೇತ್ರಧಿಕಾರಿಗಳು ಮಾನ್ಯ ಘನ ಸರ್ವೋಚ್ಚ ನ್ಯಾಯಾಲಯದ ಸಿವಿಲ್ ಅಪೀಲ್ ಸಂಖ್ಯೆ: 14604/2024 ಮತ್ತು 14605/2024 ದಿನಾಂಕ: 17.12.2024 ರಲ್ಲಿ ನೀಡಿರುವ ತೀರ್ಮಾನ / ಆದೇಶವನ್ನು ಮತ್ತು ಮುಖ್ಯ ಆಯುಕ್ತರು, ಬೃಹತ್ ಬೆಂಗಳೂರು ಮಹಾನಗರ ಪಾಲಿಕೆ, ಬೆಂಗಳೂರುರವರು ಉಲ್ಲೇಖ ಮು.ಅ/ಪಿ.ಆರ್/(ಜಿ)/2964/2024-25 ದಿನಾಂಕ 09.01.2025 ರಲ್ಲಿ ತಿಳಿಸಿರುವ ಅಂಶಗಳನ್ನು ಯಥಾವತ್ತಾಗಿ ಪಾಲಿಸಲು ಸೂಚಿಸಿದೆ.



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AIT/AVALAHALLI/(AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, AVALAHALLI Sub Division
BESCOM , AVALAHALLI

To
M. VENKATEGOWDA S/O MUNEGOWDA
NO.63/5 AT DODDAGUBBI VILLAGE

Sir/Madam

Sub : Arranging power supply to an extent of **100.00 KW** in favor of M. VENKATEGOWDA S/O MUNEGOWDA NO.63/5 AT DODDAGUBBI VILLAGE in AVALAHALLI OMU, AVALAHALLI

Ref: 1) Your application registration **61125105250021** dated **06-MAY-2025**

2) AEE/AVALAHALLI /AE(T) a/ **09-SEP-2025**

With reference to your application dated **06-MAY-2025** . Requesting for arranging power supply to an extent of **100.00 KW** power installations in favor of M. VENKATEGOWDA S/O MUNEGOWDA NO.63/5 AT DODDAGUBBI VILLAGE in AVALAHALLI OMU,AVALAHALLI Sub division in hereby sanctioned subject to the following Conditions.

a.You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M AVALAHALLI sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
61125105250021	9023473	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	100.00 KW	61.9067-61.9067-TRANSFORMER TESTING FEE	1000
61125105250021	9023473	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	100.00 KW	61.9067-Load Brake Switch Fees	4080
61125105250021	9023473	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	100.00 KW	61.9047-5% Supervisory Charges (61.904)	68574
61125105250021	9023473	LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB	100.00 KW	48.1037-48.1037 - ASD	163400
Total Amount in Rupees					237054

- The power supply will be arranged at 0V .
- The Tariff applicable to your installation will be LT3A-Urban, or the Tariff in force From time to time.
- You have to enter into an agreement with the BESCOM in the prescribed form.
- Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.
- You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.
- Energy meter should be placed outside the premises at the height of 5ft from the ground level.
- Amount through DD should be paid in the name AEE BESCOM AVALAHALLI .
- Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., AVALAHALLI Sub division, BESCOM for information and further needful

Your's Faithfully,

Your's Faithfully,

AVALAHALLI BESCOM