

Me-PDCL Meghalaya Power Distribution Corporation Limited

UMLYNGKA SUBDIVISION

Legacy Consumer ID	Consumer ID	Bill No	Billing Period	Bill Generated Date	Due Date	Disconnection Date
6700000378	1000816679	24110422351310	30-Sep-2024 to 31-Oct-2024	06-Nov-2024 06:24	25-Nov-2024	30-Nov-2024

	Туре	HT	Meter No	MEB96471
	Category	BS	Bill Type	OK (Normal)
	Sanction Load(KW)	0	Contract Demand(KVA)	2100
Name & Address: Garrison Engineer Air Force-Elephant Falls	Recorded Demand (KVA)	1212	Type Of CT-PT Set	11 KV CT-PT Set 3 Ph-4 Wire
Nonglyer Laitkor Peak, Shillong. #123795	Billing Demand	2100	Meter Connected	HT Meter
	Connection Type	CG	Connection Status	INSERVICE
	Transformer Capacity	0	Connection Location	URBAN
	Monthly Average Units	587980.37		

Meter Readings for New Meter ID:MEB96471 and Meter Status: OK (Normal)					
Description	Date	KWH Meter	Kvah Meter	Recorded Demand	Recorded PF
Current Reading	31-10-2024	11119.72	11170.91	0.303	0.99
Previous Reading	30-09-2024	10957.48	11005.77		
No Of Days	31				
Difference		162.24	165.14		
Multiplying Factor		4000	4000	4000	
Consumption		648960	660560		
Additional Units		0	0		
Meter Change Units		0	0		
Violation Energy Units		0	0		
Net Consumption		648960.00	660560	1212	

Your Detailed Bill	Assessed (Dec)
Description	Amount (Rs.)
Fixed Charges: For 2100 KVA at Rs: 300 per KVA at BM:(32/30)*1	630,000.00
Fixed Charges: For 1100 KVA at Rs: 300 per KVA at BM:(1/30)*1	11,000.00
Energy Charges: For The First Slab Rs: 6.9 per KVAH	4,557,864.00
FPPAS	0
Excess Demand Charges	2,240.00
CPMC Charges	1033.33
Current Bill Amount	5,202,137.33
Previous OutStanding	36,719.44
Adjustment	-36,719.59
Gross Bill Amount	5,202,137.18
Net Bill Amount	5,202,138.00
AMOUNT IN WORDS	Fifty Two Lakhs Two Thousand One Hundred and Thirty Eight Rupees only
Due Date	25-11-2024
Last Payment Details	
Last Payment Date	14-10-2024
Last Payment Amount	3,237,713.00
Sd/- Asst Executive Engineer UMLYNGKA SUBDIVISION	

Save Energy for the Benefit of Self and Nation

This Bill will be Construed as final notice under Section 9.2 of MSERC (Electricity Supply Code) Regulations, 2018. Supply of Electricity shall be disconnected at any date, if dues of Electricity bill is not paid within 15 (fifteen) days (notice period) after due date of the bill. Thanks for paying We really appreciate it.