



BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED

C E R T I F I C A T E

No. EEE/CDP/ AEE (O)/AE (T)/2024-25/ 6854-56

9 AUG 2024

This estimate is sanctioned under self execution works for Arranging power supply to an extent of 10HP to the Proposed Floriculture installation in the name of Sri Ramalinga Reddy S/o Late B Venkata Reddy at sy no 149 Bagganadoddi village, Kasaba Hobli, Anekal Taluk in O&M Unit Indlawadi section Anekal Sub Division. by class-I Licensed Electrical Contractor as per the approved sanctioned estimate cost of Rs.684777/- under self execution, work shall be carried under the supervision of Asst. Engineer (Ele) /Asst. Executive Engineer (Ele) Anekal Sub-Division.

5% Supervision Charges of Rs.33864/- vide Rept No.20240005601 Dated:06.08.2024 at 5% on the cost of the estimate is collected. No work order is assigned under any Head of Account of the Corporation to this work. This Certificate itself is treated as sanction for execution of work. After completion of work, joint inventory as prescribed vide Chief Controller of Accounts circular No. A0/Sa.4/Cys-10/92-93, dated 20-04-92 (page 246 of compendium vol.1) will be taken and asset accounted in the books.

The applicant has to maintain the following corridor width, based on the voltage of EHV line, if any EHT line passes through the layout/M.S Building.

66KV	220KV	400KV
18 mtrs (9 mtrs on either side from the center of the line)	35 mtrs (17.5 mtrs on either side from the center of the line)	51 mtrs (25.5 mtrs on either side from the center of the line)

All the electrical equipments such as LBS, Transformers and Metering cubicle shall be provided in Ground floor only.

As per Circular No. BESCOM/BC-33/ F-2338/ CYS-11/05.05.09 vide Sl. No. 15(a); the materials procured by the contractors for execution of total turnkey/ Partial turnkey and self-execution, works shall be invariably be subjected to inspection by competent authority for its quality and specification as approved by BESCOM before commencement of works. The material placed by you is of 1-year guarantee and you have to maintain the same for 1 year.

Consequent to the amendment by the regulation by the Hon'ble KERC vide reference, the work shall be executed, completed and shall avail service within 180 days of this work order, else the application for power supply will be deemed as CANCELLED. On cancellation of the application, registration/re-registration cum processing charges shall stands forfeited. For any further details you may contact Asst. Executive Engineer Anekal Sub-Division.

NOTE:-1) Materials to be procured by BESCOM approved vendors and materials to be inspected by competent authority before execution /commencement of the work.

2) Vide ref no: GM(QS&S)/DGM(EI)-3/Mgr/BC-11/21-22/CYS-39/Date:12.07.2021. In case of all Self execution works where dry type transformer, cable entry transformers are installed but not commissioned (for which there is no vendor approval) shall be commissioned only after getting specific approval from GM(QS&S).

AEE (O), BESCOM, CDP
 AEE (O), BESCOM, CDP
 AO (F&C), BESCOM, CDP
 Executive Engineer (Ele), BESCOM, Chandapura

A/C Head	Amount in Rs.	Receipt No	Date
5% SC	33864-00	20240005601	06.08.2024
CGST	3048-00	20240005602	06.08.2024
SGST	3048-00	20240005603	06.08.2024
Transformer testing fee	1000-00	20240005604	06.08.2024
CGST 9%	90-00	20240005605	06.08.2024
SGST 9%	90-00	20240005606	06.08.2024
ISD	7190-00	20240005607	06.08.2024

Ref No:-

- Intimation Ltr. No. EEE/CDP/AEE(O)/AE(T)/2024-25/4389-90 Date:08.07..2024
- Payment certificate No.AEE/AKL/AAO/2024-25/702 /dated:07.08.2024.
- KERC/COS/D/13/14-15, Bangalore, dated 25th August, 2014.

Copy to.

- Asst. Executive Engineer (Ele), BESCOM, Anekal Sub-Divison.
- Account Officer (F&C), BESCOM, Chandapura Division, Chandapura.
- Sri Ramalinga Reddy S/o Late B Venkata Reddy at sy no 149 Bagganadoddi village, Kasaba Hobli, Anekal Taluk in O&M Unit Indlawadi section Anekal Sub Division.