



Bangalore Electricity Supply Company Limited
(Wholly owned Govt. of Karnataka Undertaking)

No: BESCOM/MTR-PROC-MC /5769393623/10-JUL-2025

ASSISTANT EXECUTIVE ENGINEERS (Elec)

AVALAHALLI, BESCOM

Dated: 10-JUL-2025

To,
SY NO 24/2 & 24/3 AT SEEGEHALI VILLAGE
M RAJEEV
BANGALORE KAR
IND 560026
Sir,

Sub: Permission to Purchase meter

Ref: (1) BESCOM /DT/GM (T)/BC-20/02-03/5567/Dtd: 21.11.2002

Ref: (2) Letter No: 5769393623, Application Id: 1125107250004

With reference to your applications registered vide Application. No: 1125107250004 with us on 01-JUL-2025 for new service for

DLMS, total sanctioned load 3.00 KW we wish to inform you that as per provisions of BESCOM under cited reference, approval is accorded to purchase the meter for availing new service to Domestic/commercial/Industrial installation subject to the following conditions:

1. You have to purchase the specified meter within 7 days of this letter as shown in below table from the BESCOM's identified/authorized manufacturer's retail outlet, by producing this letter. In addition to meter cost you also have to pay taxes and service charges at the time of purchase.

| SLNo | Meter Description | Quantity | Rate | GST | Amount |
|------|--|----------|------|-----|---------|
| 1. | LT AC Single Phase 2 Wire, 5-30 Amps Smart Energy Meter, Class 1.0 Accuracy with GPRS Communication Module | 1 | 2461 | 18 | 2294.14 |

2. You have to hand over the meter to the respective O&M section immediately.

3. You have to ensure that the purchased meter is in a cardboard carton, duly sealed and shall not be tampered with.

4. You have to produce copies of the meter test certificate, warranty certificate, and cash receipt at the time of service so as to maintain the same in our records.

We thank you for your cooperation and please feel free to contact us for any clarifications.

Yours faithfully

The Assistant Executive Engineer (El)

AVALAHALLI BESCOM



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

AEE/AVALAHALLI (AET)

Office of the
Assistant Executive Engineer Ele.,
C.O&M, AVALAHALLI Sub Division
BESCOM, AVALAHALLI

To
M RAJEEV
SY NO 24/2 & 24/3 AT SEEGEHALI VILLAGE

in/Madam

Sub : Arranging power supply to an extent of 3.00 KW in favor of M RAJEEV SY NO 24/2 & 24/3 AT SEEGEHALI VILLAGE in AVALAHALLI OMU, AVALAHALLI

Ref: 1) Your application registration 1125107250004 dated 01-JUL-2025

2) AEE/AVALAHALLI /AE(T) a/ 03-JUL-2025

With reference to your application dated 01-JUL-2025 . Requesting for arranging power supply to an extent of 3.00 KW power installations in favor of M RAJEEV SY NO 24/2 & 24/3 AT SEEGEHALI VILLAGE in AVALAHALLI OMU, AVALAHALLI Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M AVALAHALLI sub-division and furnish the payment certificate for taking further action in this matter.

| Application No | Sub Application No | Tariff | Requested Load | Account Head | Amount(Rs.) |
|------------------------|--------------------|--|----------------|--|-------------|
| 1125107250004 | 11251072500040001 | LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB | 3.00 KW | 55.1077-55.1077 - INFRASTRUCTURE CHARGES- NO TAX+CGST(46.9977)9%+SGST(46.9987)9%=(19500 + (19500*0.09) + (19500*0.09)) | 19500 |
| 1125107250004 | 11251072500040001 | LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB | 3.00 KW | 48.1037-48.1037 - ASD+CGST(46.9977)9%+SGST(46.9987)9%=(1210 + (1210*0.09) + (1210*0.09)) | 1210 |
| 1125107250004 | 11251072500040001 | LT3A-Urban-COMMERCIAL POWER & LIGHTING - LT3-ULB | 3.00 KW | 48.1017-48.1017 - ISD+CGST(46.9977)9%+SGST(46.9987)9%=(4910 + (4910*0.09) + (4910*0.09)) | 4910 |
| Total Amount in Rupees | | | | | 25620 |

he power supply will be arranged at 230V .

he Tariff applicable to your installation will be LT3A-Urban, or the Tariff in force From time to time.

You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM AVALAHALLI .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FORFEITED. You are requested to contact AEE/AVALAHALLI Sub-Division, BESCOM for information and further needful.

Assistant Executive Engineer (Ele)
BESCOM, Avalahalli Sub-Division
Avalahalli-560 049.