



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)

BESCOM GSTN No: 29AACCB1412G1Z5

AEE/AMRUTHURU OMU/ (AET)

Office of the
Assistant Executive Engineer Ele.,
C,O&M, AMRUTHURU OMU Sub Division
BESCOM , AMRUTHURU OMU

To
GOWRAMMA
AVARAGERE

Sir/Madam

Sub : Arranging power supply to an extent of **30.00 KW** in favor of GOWRAMMA AVARAGERE in AMRUTHURU OMU OMU, AMRUTHURU OMU

Ref : 1) Your application registration **2241210250016** dated **17-OCT-2025**

2) AEE/AMRUTHURU OMU /AE(T) a/ **10-MAR-2026**

With reference to your application dated **17-OCT-2025** . Requesting for arranging power supply to an extent of **30.00 KW** power installations in favor of GOWRAMMA AVARAGERE in AMRUTHURU OMU OMU,AMRUTHURU OMU Sub division in hereby sanctioned subject to the following Conditions.

a. You are requested to pay the following charges by DD/cash (above 10000/- only DD will be Accepted) payable at the Office of C, O&M AMRUTHURU OMU sub-division and furnish the payment certificate for taking further action in this matter.

Application No	Sub Application No	Tariff	Requested Load	Account Head	Amount(Rs.)
2241210250016	22412102500160001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	30.00 KW	48.1037-48.1037 - ASD	1020
2241210250016	22412102500160001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	30.00 KW	61.9047-5% Supervisory Charges (61.904)	23188
2241210250016	22412102500160001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	30.00 KW	61.9067-61.9067- TRANSFORMER TESTING FEE	1000
2241210250016	22412102500160001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	30.00 KW	61.9047-61.9047 - SC CHARGES(SUPERVISION CHARGES)	250
2241210250016	22412102500160001	LT3A-Rural-COMMERCIAL POWER & LIGHTING - LT3-RLB	30.00 KW	48.1017-48.1017 - ISD	48000
Total Amount in Rupees					73458

b. The power supply will be arranged at 400V .

c. The Tariff applicable to your installation will be LT3A-Rural, or the Tariff in force From time to time.

d. You have to enter into an agreement with the BESCOM in the prescribed form.

e. Submit the Contractor's Completion-Cum-Test Report along with diagram in Duplicate.

f. You shall install LT metering panel approved by the BESCOM with suitable Capacity MCCB and/or ELCB.

g. Energy meter should be placed outside the premises at the height of 5ft from the ground level.

h. Amount through DD should be paid in the name AEE BESCOM AMRUTHURU OMU .

i. Intimation is valid up to 30 days from the date of issue.

In case the above requirements are not fulfilled within one month from the date of this communication, the sanction of power and registration will stand CANCELLED. The registration fee paid will be FOREFEITED. You are requested to contact the Asst. Ex. Engineer Ele., AMRUTHURU OMU Sub division, BESCOM for information and further needful.

Your's Faithfully,

**Assistant Engineer (Technical),
AMRUTHURU OMU, BESCOM**

Your's Faithfully,

**Assistant Executive Engineer Ele.,
AMRUTHURU OMU, BESCOM**

Copy to:

- 1.The Executive Engineer Ele. C, O&M KUNIGAL Division, BESCOM.
- 2.The Asst. Executive Engineer Ele., C,O&M AMRUTHURU OMU Sub division, BESCOM.