



Bengaluru Electricity Supply Company Limited
(Wholly Owned Government of Karnataka Undertaking)
BESCOM GSTN No: 29AACCB1412G1Z5

to: Bangalore Electricity Supply

E/JIGANI/2025-2026/61324104250007

1497/ Date: 11/07/2025

Office of
The Assistant Executive Engineer
JIGANI
Bangalore Electricity Supply Company
Limited (BESCOM)
DATED : 07-JUL-2025

OFFICIAL MEMORANDUM

Sub: conversion from one type of use to another type of use [change of Load category]

Ref: Consumer's Application dated :08-APR-2025

In accordance with KERC (S&D) code 2006, section 39.01 approval is hereby accorded to convert the following installations existing in the name of **M/S URBANIZE LAND HOLDINGS LTD** located at **NO 333/1,333/2 HULIMANGALA VILLAGE JIGANI ANEKAL562106** from Existing Load to new Load as noted against each with effect from **01-JUL-2025**

SI NO	Account ID/RRNO	Existing Load	New Load
1	5663061/J3HLMTP3033	25.000/0.000/0.000	49.000/0.000/0.000


Assistant Executive Engineer(EI)
JIGANI SD
Bangalore

ಇವರಿಗೆ,
ಸಹಾಯಕ ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್ (ಎ)
ಜಿ.ಎಸ್.ಎಸ್. ಉಪ ವಿಭಾಗ, ಬಿ.ಎ.ಕೆಂ.
ಮಾನ್ಯರೇ.

ಆರ್.ಆರ್.ನಂ. J3HMT/TP-3055 ಪುನಃ M/S Vijayalakshmi and Associates Pvt
ಕೈಗಾರಿಕೆಯ ಮಾದರಿ Construction ವಿಳಾಸ 335/1, 333/2, A H. Rangla V. H. K. J. J. J.
ಟ್ಯಾರಿಡ್ LT2 SI = 49kw K = 10 to 15 k=10 to 15 25642

ದಿನಾಂಕ 02/07/25 ರಂದು ಮೇಲಿನ ಪದ್ಧತಿ ಇನ್ಸ್ಟಾಲೇಷನ್ ರೇಟ್ ಮಾಡಿದ ಮತ್ತು ಮಾಹಿತಿಗಾಗಿ ಪಟ್ಟಿ
ರೇಟ್ ಮಾಡಲು ಕಾರಣ/ನಿಯಮಿತ/ದೂರು pc test for load ಒಂದಿನ ರೇಟ್ ಮಾಡಿದ ದಿನಾಂಕ 03.06.25

ಮಾಪಕ	ತಯಾರಿಕೆ	ಆವರ್ತ ಪರಿವರ್ತಕ/ಕಿ ವ್ಯಾ	ಸಂಖ್ಯೆ	ಮಾದರಿ	ಘಟಕ	ವೋಲ್ಟ	ಆಂಪ್	ಸಿ.ಬಿ. ಪ್ರಮಾಣ	ಗುಣಕ	ಕಡೆಯಲ್ಲಿ ರೇಡಿಂಗ್	% ದೋಷ		ಮಾಪಕ		
											ಕಂಡು	ಬಿಟ್ಟು	ಪೂರ್ವ	ಕಂಡು	ಬಿಟ್ಟು
Before Rmd After FMD	LT	7500	73225576	ER 500 30	240	SA	50/5	10	7435.01	±0	±0	ಮೇಲೆ ಕಂಡು	ಪೂರ್ವ	73117	ಕಂಡು
	LT	7500	23225526	ER 500 34	240	SA	50/5	15	7435.01	±0	±0	ಮೇಲೆ ಕಂಡು	ಪೂರ್ವ	73117	ಕಂಡು

ಮಾಪಕದಲ್ಲಿ ಕಾಣಿಸಿದ ವಿವರಗಳು				ಪರೀಕ್ಷಾ ವಿವರ			
1. ಸಮಯ	Before	After		ತಯಾರಿಕೆ :	ಪ್ರಮಾಣ :	ಘಟಕ/ವಿವರ :	
2. ಒಟ್ಟು ರೇಡಿಂಗ್	7435.01	7435.01					
3. ಪದರ್ಥ ಫ್ಯಾಕ್ಟರ್	0.76	0.76					
4. ಡಿಮ್ಯಾಂಡ್	2.76	0.00					
5. ಬಿಲ್ಡ್ ರೇಡಿಂಗ್	7408.58	7408.58					
6. ರೇಟ್ ಸಂಖ್ಯೆ	23	23					
7. ಕರಂಟ್	0.36 0.36 0.36	0.24 0.24 0.24					
8. ಪೋಟೆನ್ಷಿಯಲ್	241 241 241	241 241 241					

ವಿದ್ಯುತ್ ಪ್ರಮಾಣ ವಿವರ		ಪರೀಕ್ಷಾ ವಿವರ	
1. ವೋಲ್ಟೇಜ್	241 241 241	241 241 242	1. ಲೆಕ್ಕ ಮಾಡಿದ ಆವರ್ತ ಸಂಖ್ಯೆ (C)
2. ಪೂರ್ಣ ಪ್ರಮಾಣ ಆಂಪ್	3.6 3.6 3.6	3.6 3.6 3.6	2. ಆವರ್ತ ಕಿ.ವ್ಯಾ (R)
3. ಸೂಚಿತ ವ್ಯಾಟ್	0.9 kw	0.9 kw	3. ಸಿ.ಬಿ. ಪ್ರಮಾಣ (K)
4. ಪದರ್ಥ ಫ್ಯಾಕ್ಟರ್	0.76	-	4. ಆಕ್ಟಿವ್ ಆಂಪ್ ಕಂಡು ಬಿಟ್ಟು (A)
5. ಮುಂಜೂರಾದ ಹೆಚ್.ಪಿ	0.25 kw		
6. ಮಾಪಕ ವೆಚ್ಚ	241 kw		

ಪರೀಕ್ಷಾ ವಿವರ		ಪರೀಕ್ಷಾ ವಿವರ	
1. ಲೆಕ್ಕ ಮಾಡಿದ ಆವರ್ತ ಸಂಖ್ಯೆ (C)	5	5	
2. ಆವರ್ತ ಕಿ.ವ್ಯಾ (R)	2500	2500	
3. ಸಿ.ಬಿ. ಪ್ರಮಾಣ (K)	50/5	50/5	
4. ಆಕ್ಟಿವ್ ಆಂಪ್ ಕಂಡು ಬಿಟ್ಟು (A)	10	15	
% Error = $\frac{(C \times K) - A}{A} \times 100$	±0	±0	

ಪರಿಶೀಲನೆ : Conducted pre-commission test & de-commission test on Energizing meter
with a rating from 50/5 to 75/5. Found within the permissible
limit. Constant to be changed from 50/10 to 15. Further action may
be taken at your end as per BESCOM norms

ಪ್ರತಿ : 1 ಕಾರ್ಯ ನಿರ್ವಾಹಕ ಇಂಜಿನಿಯರ್ (ಎ),
ಮಾಪಕ ವಿಭಾಗ, BRAZ, ಬಿ.ಎ.ಕೆಂ, ಬೆಂಗಳೂರು.

ಹಸ್ತಾಂತರ : 5-11-25

ಪರಿಶೀಲನೆ : 5-11-25

ಪರಿಶೀಲನೆ : 5-11-25