



Meter changed in system on 11/08-2026 Narasimha

**BANGALORE ELECTRICITY SUPPLY COMPANY LIMITED**

(Wholly owned Government of Karnataka Undertaking)

No. EEMT/AEE(O)/BRAZ/AEE HTR/

To,  
The Asst. Executive Engineer (Ele), **DPHT199**  
**Dabaspete** O&M Sub-Division, **Meter Change**  
BESCOM, **Melamangala**..... **ART Features**

Office of the  
Executive Engineer (Ele),  
MT Division, BRAZ, BESCOM,  
3rd Floor, Crescent towers,  
Bangalore-560001.

Sir,

**CD: 250 KVA**  
**CTR: 12.5/1A**  
**MC: 1250**

Date: 27/02/2026

**Subject: Rating Report of HT/EHT Installation.**

The H.T. Installation having the following details has been rated for periodical rating/complaint on 27/02/2026. You are requested to take action on the observations and advice recorded in the report. Compliance report shall be sent to this office on the observations pointed out in the report. Details are furnished in the Annexure enclosed.

**1. DETAILS OF H.T. INSTALLATION:**

Previously rated on 19/02/2026  
R.R.NO. **DPHT199**.....CD: **250**.....KVA CTR: **12.5/1A**.....A Meter Constant: **1250**  
Activity..... Tariff: **HTA**  
Name & Address of the Consumer: **M/S Syn park Zippers Bags Pvt Ltd plot #42-P**  
**1st Stage Souppura ELADB, Indl Area Dabaspete**

**2. OBSERVATION & ADVICE ON TECHNICAL MATTER:**

The installation of the meter is calibrated before and after the replacement of **ART** meters and found ok, and the meters are readable within the limit. The HTMC wiring, TTB and CT/PT wiring connections are checked and found ok.

**3. ADVICE ON REVENUE MATTER:**

**Polarity Test** conducted and found that wiring are in order.  
**CD: 250 KVA**  
**CTR: 12.5/1A**  
**MC: 1250**

**4. DOWNLOADED DATA ANALYSIS ENCLOSED: YES/NO.**

Summary of analysis if rated against complaint.....

**ANNEXURE**

**1. DETAILS OF SEALS:**

R.R. No. **DPHT199**

SL.N O.	Seals Provided to	Sl. No. of Seals Found Plastic		Sl. No. of Seals Left Plastic	
		Main Meter	Check Meter	Main Meter	Check Meter
1	M.C. of Meter	BMK 24037		BRM0459710	BRM0459709
2	TC Of Meter	BR12B 93944		BRM1167160	BRM1167163
3	M.D. Reset Knob	BR12B 93945		BRM1167161	BRM1167164
4	Optical Port	-	-	-	-
5	T.T.B	BRM1167079		BRM1167162	BRM1167165
6	Meter Chamber Main Door	BRM1167080		BRM1167166	
7	Meter Reading Window	-	-	-	-
8	C.T./P.T. Chamber	BR12B 93948		BRM1167167	
9	Cable Entry Chamber	BR12B 93949		Retained	
10	Hologram	MT104666		MT113882	MT113881

**2. DETAILS OF THE EQUIPMENTS:**

**nsw 714870**

- a) Cubicle Type : Cable Entry / 6 bushing / 3 busing / LBS. Make.....Sl. No.....
- b) Cubicle Conditions & Location..... **Good**.....

**3. MULTIPLYING CONSTANT (MC) FOR BILLING (Kwh. Kvah. Kva) :**

$$MC = \frac{PT \text{ Ratio} \times CT \text{ Ratio} \times \text{Dial Constant}}{\text{Meter PT Ratio} \times \text{Meter CT Ratio}} = \frac{11kV/\sqrt{3}/110/\sqrt{3} \times 12.5/1}{1 \times 1} \times 1 = 1250$$

**4. DETAILS OF Ct's/ Pt's:**

**One thousand two hundred fifty only.**